

Recommended Practice for Classification of Locations for Electrical Installations at Petroleum Facilities Classified as Class I, Zone 0, Zone 1, and Zone 2

API RECOMMENDED PRACTICE 505
SECOND EDITION, AUGUST 2018



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Copyright © 2018 American Petroleum Institute

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 1220 L Street, NW, Washington, DC 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

Contents

	Page
1	Scope 1
1.1	Purpose 1
1.2	Application. 1
2	Normative References 2
2.1	General. 2
2.2	Industry Codes, Guides, and Standards. 2
2.3	Government Codes, Rules, and Regulations 4
3	Terms, Definitions, and Acronyms 4
3.1	Terms and Definitions 4
3.2	Acronyms. 12
4	Basic Conditions for a Fire or Explosion 13
5	Flammable and Combustible Liquids, Gases, and Vapors 13
5.1	General. 13
5.2	Flammable and Combustible Liquids 13
5.3	Flammable Highly Volatile Liquids 14
5.4	Flammable Lighter-than-air Gases 14
5.5	National Electrical Code Grouping of Atmospheric Mixtures. 15
6	Classification Criteria 16
6.1	General. 16
6.2	Sources of Release (ANSI/ISA 60079-10-1). 17
6.3	Zone Designation (ANSI/ISA 60079-10-1) 17
6.4	Extent of Zone (ANSI/ISA 60079-10-1). 17
6.5	Classification Criteria and Considerations. 20
6.6	Ventilation 25
6.7	Adjacent Areas 29
6.8	Use of Combustible Gas Detection Equipment 31
7	Extent of a Classified Location 33
7.1	General. 33
7.2	Outdoor Locations 33
7.3	Enclosed Locations 34
8	Recommendations for Determining Degree and Extent of Classified Locations—Common Applications 34
8.1	General. 34
8.2	Recommendations for Areas Surrounding Specific Equipment 35
9	Recommendations for Determining Degree and Extent of Classified Locations in Petroleum Refineries 52
9.1	Introduction 52
9.2	Recommendations 53
10	Recommendations for Determining Degree and Extent of Classified Locations at Drilling Rigs and Production Facilities on Land and on Marine Fixed Platforms. 59
10.1	General. 59
10.2	Drilling Areas. 60
10.3	Production Facilities. 61
10.4	Drilling Wells 62

Contents

	Page
10.5 Producing Oil and Gas Wells	71
10.6 Oil and Gas Processing and Storage Equipment	77
10.7 Automatic Custody Transfer (ACT) Units	80
10.8 Produced/Processed Water Handling Equipment	80
10.9 Compressor or Pump Handling Flammable Liquids, Gases, or Vapors	81
10.10 Drip Pans	84
10.11 Instruments	85
10.12 Sumps	87
10.13 Drains	89
10.14 Reserved For Future Use	94
10.15 Screwed Connections, Flanges, Valves, and Valve Operators	95
10.16 Control Panels Containing Instrumentation Utilizing or Measuring Flammable Liquids	95
10.17 Gas Meters	97
11 Recommendations for Determining Degree and Extent of Classified Locations on Mobile Offshore Drilling Units (MODUs)	97
11.1 General	97
11.2 Definitions Specific To MODUs	98
11.3 Reserved For Future Use	99
11.4 Classified Locations on MODUs	99
11.5 Basis for Area Classification	100
11.6 Classification of Hazardous (Classified) Locations	101
11.7 Drill Floor and Derrick Areas	103
11.8 Substructure or Moonpool Areas	103
11.9 Mud System Processing Equipment Overview	110
11.10 Mud Tanks (After Discharge of Final Degasser)	110
11.11 Mud Ditches or Troughs	114
11.12 Mud Pumps	114
11.13 Mud Processing Equipment (Between the Bell Nipple and Mud Discharge of Final Degasser)	114
11.14 Desander or Desilter (Between Mud Discharge of Final Degasser and the Mud Pit)	114
11.15 Choke Manifold	118
11.16 Cement Unit	118
11.17 Degasser	118
11.18 Vents	119
11.19 Diverter Line Outlet	120
11.20 Blowout Preventer (BOP)	120
11.21 Well Test Equipment Areas	121
11.22 Rooms Used To Store Paint (Paint Lockers)	121
11.23 Battery Rooms	121
11.24 Helicopter Fuel Storage Areas	121
11.25 Classification of Adjacent Spaces	121
12 Recommendations for Determining Degree and Extent of Classified Locations at Drilling Rigs and Production Facilities on Floating Production Units	122
12.1 General	122
12.2 Floating Production Storage and Offloading Units (FPSOs)	123
12.3 Tension Leg Platforms (TLPs)	123
12.4 Spars, Caissons, and Similar Units	123
12.5 Classification of Adjacent Spaces	126

Contents

	Page
13 Reserved for Future Use	127
14 Recommendations for Determining Degree and Extent of Classified Locations at Petroleum Pipeline Transportation Facilities	127
14.1 General	127
14.2 Use of Figures	128
14.3 Figures	128
Annex A (informative) Sample Calculation to Achieve Adequate Ventilation of an Enclosed Area by Natural Means Using Equation 1 and Equation 2	142
Annex B (informative) Calculation of Minimum Air Introduction Rate to Achieve Adequate Ventilation Using Fugitive Emissions	144
Annex C (normative) Symbols for Denoting Class I, Zone 0, Zone 1, and Zone 2 Hazardous (Classified) Areas	147
Annex D (informative) An Alternate Method for Area Classification	148
Annex E (informative) Procedure for Classifying Locations	159
Bibliography	162

Figures

1 Increase in Flow Caused by Excess of One Opening Over Another	28
2 Adequately Ventilated Non-enclosed Area Adjacent to a Classified Area	29
3 Enclosed Area Adjacent to a Classified Area	30
4 Enclosed Area Adjacent to a Classified Area	30
5 Enclosed Area Adjacent to a Classified Area	31
6 Fixed-roof Flammable Liquid Storage Tank in a Non-enclosed, Adequately Ventilated Area	36
7 Open Top Floating Roof Flammable Liquid Storage Tank in a Non-enclosed, Adequately Ventilated Area	37
8 Combustible Liquid Storage Tank in a Non-enclosed, Adequately Ventilated Area	38
9 Tank Car or Tank Truck Loading and Unloading via Closed System—Product Transfer Through Dome Only	39
10 Tank Car or Tank Truck Loading and Unloading Via Closed System—Product Transfer Through Dome Only	40
11 Tank Car or Tank Truck Loading and Unloading Via Closed System—Product Transfer Through Bottom Only	40
12 Tank Car or Tank Truck Loading and Unloading Via Open System—Product Transfer Through Top or Bottom	41
13 Tank Car or Tank Truck Loading and Unloading Via Closed System—Product Transfer Through Bottom Only	42
14 Process Equipment Vent in a Non-enclosed Adequately Ventilated Area	43
15 Instrument or Control Device Vent in a Non-enclosed, Adequately Ventilated Area	44
16 Atmospheric Vent From a Zone 1 Area	44
17 Atmospheric Vent From a Zone 2 Area	45
18 Relief Valve in a Non-enclosed, Adequately Ventilated Area	46
19 Marine Terminal Handling Flammable Liquids	47
20 Adequately Ventilated Process Location with Heavier-than-air Gas or Vapor Source Located Near Grade	54

Contents

Page

21	Adequately Ventilated Process Location with Heavier-than-air Gas or Vapor Source Located Above Grade	54
22	Inadequately Ventilated Process Location with Heavier-than-air Gas or Vapor Source.	55
23	Adequately Ventilated Compressor Shelter with Lighter-than-air Gas or Vapor Source	56
24	Adequately Ventilated Process Location with Lighter-than-air Gas or Vapor Source	56
25	Inadequately Ventilated Compressor Shelter with Lighter-than-air Gas or Vapor Source.	57
26	Inadequately Ventilated Process Location with Lighter-than-air Gas or Vapor Source	57
27	Separators, Dissolved Air Flotation (DAF) Units, Biological Oxidation (BIOX) Units, and Enclosed Sumps	58
28	Mechanical Draft Cooling Tower Handling Process Cooling Water	59
29	Drilling Rig, Adequate Ventilation in Substructure, and Derrick is Not Enclosed, but Is Equipped with a Windbreak, Open Top, and Open V-door	63
30	Drilling Rig, Adequate Ventilation in Enclosed Derrick (Open Top), and Inadequately Ventilated Substructure	64
31	Platform Drilling Rig, Adequately Ventilated in Substructure and Inside Derrick, Several Producing Wells Beneath in an Adequately Ventilated Area	65
32	Platform Drilling Rig, Adequate Ventilation in Substructure and Inside Derrick, Several Producing Wells Beneath in an Inadequately Ventilated Location	66
33	Mud Tank in a Non-enclosed, Adequately Ventilated Area	67
34	Mud Tank in an Enclosed Inadequately Ventilated Area.	67
35	Shale Shaker in a Non-enclosed, Adequately Ventilated Area.	68
36	Desander or Desilter in a Non-enclosed, Adequately Ventilated Area	69
37	Desander or Desilter in an Adequately Ventilated Enclosed Area.	69
38	Degasser or Gas Buster Vent in Non-enclosed, Adequately Ventilated Area	70
39	Flowing Well in a Non-enclosed, Adequately Ventilated Area and Without a Cellar or Below-grade Sump	71
40	Flowing Well in a Non-enclosed, Adequately Ventilated Area with an Inadequately Ventilated Cellar or Below-grade Sump	72
41	Flowing Well in an Inadequately Ventilated Enclosed Area	72
42	Non-enclosed Beam Pumping Well in an Adequately Ventilated Area Without a Cellar.	73
43	Non-enclosed Beam Pumping Well in an Adequately Ventilated Area with an Inadequately Ventilated Cellar	74
44	Electric Submersible Pumping Well in a Non-enclosed, Adequately Ventilated Area Without a Cellar	74
45	Electric Submersible Pumping Well in a Non-enclosed, Adequately Ventilated Area with an Inadequately Ventilated Cellar	75
46	Junction Box in a Non-enclosed, Adequately Ventilated Area Connected to an Electric Submersible Pump	75
47	Non-enclosed, Adequately Ventilated Well on Which Wireline Work is Being Performed	77
48	Hydrocarbon Pressure Vessel or Protected Fired Vessel in a Non-enclosed, Adequately Ventilated Area	78
49	Ball or Pig Launching or Receiving Installation in a Non-enclosed, Adequately Ventilated Area	80
50	Flammable Gas-blanketed and Produced/Processed/Injected Water-handling Equipment (Tank and Flotation Cell) in a Non-enclosed, Adequately Ventilated Area	82
51	Compressor or Pump in an Adequately Ventilated Non-enclosed Area	83
52	Compressor or Pump in an Adequately Ventilated Non-enclosed Area	83
53	Compressor or Pump in an Adequately Ventilated Enclosed Area.	84
54a	Compressor or Pump in an Inadequately Ventilated Enclosed Area	85
54b	Compressor or Pump in an Adequately Ventilated Non-enclosed Area	86

Contents

Page

55	Flammable Gas–operated Instruments in an Adequately Ventilated Enclosed Area with All Devices Vented to the Outside	87
56	Flammable Gas–operated Instruments in an Inadequately Ventilated Enclosed Area	88
57	Open Sump in Non-enclosed, Adequately Ventilated Area	88
58	Type 1 Open Drain System	90
59	Type 2 Open Drain System	90
60	Type 3 Open Drain System in Non-enclosed Area	91
61	Type 3 Drain System in Enclosed Area	92
62	Type 4 Open Drain System in Non-enclosed Area	92
63	Type 4 Open Drain System in Enclosed Area	93
64	Control Panel with Flammable Gas Vented to the Inside of the Enclosure	96
65	Inadequately Ventilated Control Panel with Instruments Inside	96
66	Adequately Ventilated Control Panel with Instruments Inside	97
67	Drilling Rig Open Derrick	104
68	Drilling Rig Semi-enclosed Derrick	105
69	Drilling Rig Derrick Fully Enclosed (Open Top)	106
70	Drilling Rig Open Substructure and Semi-enclosed Derrick	107
71	Drilling Rig With Total Containment Substructure and Semi-enclosed Derrick Drilling Rig	108
72	Semi-enclosed Substructure and Semi-enclosed Derrick	109
73	Drilling Rig Enclosed Moonpool and Semi-enclosed Derrick	110
74	Mud System Processing Equipment in Adequately Ventilated Enclosed Spaces	111
75	Mud System Processing Equipment in Open Spaces	112
76	Mud Tanks in Open Areas	113
77	Open Top Mud Tanks in Enclosed or Semi-enclosed Locations with Adequate Ventilation	113
78	Closed Top Mud Tanks in Enclosed or Semi-enclosed Locations With Adequate Ventilation	113
79	Open Mud Trough in Open Space Before Degasser	114
80	Open Mud Trough in Enclosed Space with Adequate Ventilation Before Degasser	115
81	Open Mud Trough in Enclosed Space with Adequate Ventilation Downstream of Degasser	115
82	Open Mud Trough in Open Space Downstream of Degasser	116
83	Shale Shaker in Enclosed or Semi-enclosed Space with Adequate Ventilation	116
84	Shale Shaker in Open Area with Adequate Ventilation	117
85	Desander or Desilter in Enclosed or Semi-enclosed Space with Adequate Ventilation	117
86	Desander or Desilter in Open Area	118
87	Discharges of Ventilation Vents and Equipment Vents Originating in Zone 1 Areas	119
88	Discharges of Ventilation Vents and Equipment Vents Originating in Zone 2 Areas	119
89	Diverter Line Outlet	120
90	Typical Floating Production Storage and Offloading Unit (FPSO)	124
91	Typical Tension Leg Platform (TLP)	125
92	Typical Spar, Caisson, or Similar Unit	126
93	Outdoors—Pump or Compressor Handling Flammable Liquids or Highly Volatile Liquids	129
94	Adequately Ventilated Building—Pump or Compressor Handling Flammable Liquids or Highly Volatile Liquids	130
95	Inadequately Ventilated Building Pump or Compressor Handling Flammable Liquids or Highly Volatile Liquids	131
96	Outdoors—Piping With Valves, Screwed Fittings, Flanges, or Similar Accessories Handling Flammable Liquids or Highly Volatile Liquids	132
97	Adequately Ventilated Building—Piping With Valves, Screwed Fittings, Flanges, or Similar Accessories Handling Flammable Liquids or Highly Volatile Liquids	133

Contents

Page

98	Inadequately Ventilated Building—Piping With Valves, Screwed Fittings, Flanges, or Similar Accessories Handling Flammable Liquids or Highly Volatile Liquids.	134
99	Elevated Storage Tank or Pressure Vessel	135
100	Below-grade Closed Sump Tank and Oil–water Separator	136
101	Below-grade Vault—Piping With Valves, Screwed Fittings, Flanges, or Similar Accessories Handling Flammable Liquids or Highly Volatile Liquids	137
102	Above-grade Source With Closure	138
103	Storage Cavern	139
104	Outdoors—Compressor or Other Source Handling Lighter-Than-Air Flammable Gas	139
105	Adequately Ventilated Building—Compressor or Other Source Handling Lighter-than-air Flammable Gas	140
106	Inadequately Ventilated Building—Compressor or Other Source Handling Lighter-than-air Flammable Gas	141
C.1	Symbols for Denoting Class I, Hazardous (Classified) Zones	147
D.1	Vapor Pressure–temperature Volatility Chart.	150
D.2	Volatility—Release Rate Matrix for Determining Hazard Radius	152
D.3	Adequately Ventilated Process Area with Heavier-than-air Gas or Vapor Source Located Near or Above Grade	157

Tables

1	Approximate Comparison of Zone and Division Gas Groups.	16
2	Showing the Relationship Between Grade of Release and the Presence of Flammable Mixtures	24
3	Pressure Adjustment Factor	60
D.1a	Pumps Handling Heavier-than-air Gases or Vapors Located in Non-enclosed, Adequately Ventilated Process Areas	153
D.1b	Pumps Handling Heavier-than-air Gases or Vapors Located in Non-enclosed, Adequately Ventilated Process Areas (Metric)	153
D.2	Determining Hazard Radius for Sources with Restrictions for Heavier-than-air Gases or Vapors	154
D.3	Atmospheric Vents and Drains Handling Heavier-than-air Gases or Vapors	155
D.4	Flanges Containing Heavier-than-air Gases or Vapors with a Higher Probability of Leakage	155

Introduction

This recommended practice (RP) is under the joint jurisdiction of the API Exploration and Production (E&P) Department Committee on Production Equipment Standards, the API Manufacturing Distribution Marketing (MDM) Department, Committee on Refinery Equipment, and the Pipeline Operations Technical Committee. It is based upon a level of knowledge gained through experience and through the successful application of this practice in refining; drilling, and producing, and pipeline segments of the petroleum industry.

The first edition of API 505 was prepared as a supplement to the 1996 edition of the National Electrical Code (NEC), Article 505, with a scope limited to those petroleum facility locations classified as Class I, Zone 0, Zone 1, and Zone 2. It was issued in November 1997, reaffirmed in November 2013, and has been referenced in all issues of the NEC since the 1999 edition.

Recommended Practice for Classification of Locations for Electrical Installations at Petroleum Facilities Classified as Class I, Zone 0, Zone 1, and Zone 2

1 Scope

1.1 Purpose

1.1.1 The purpose of this recommended practice (RP) is to provide guidelines for classifying locations Class I, Zone 0, Zone 1, and Zone 2 at petroleum facilities for the selection and installation of electrical equipment. Basic definitions given in the 2014 edition of NFPA 70, the *National Electrical Code (NEC)*, have been followed in developing this RP. This publication is only a guide and requires the application of sound engineering judgment.

NOTE Recommendations for determining the degree and extent of classified locations Class I, Division 1, and Division 2 are addressed in API 500, *Recommended Practice for Classification of Electrical Installations at Petroleum Facilities Classified as Class I, Division 1, and Division 2*.

1.1.2 Electrical installations in areas where flammable liquids, gases, or vapors are produced, processed, stored, or otherwise handled can be suitably designed if the locations of potential sources of release and accumulation are clearly defined. Once a location has been classified, requirements for electrical equipment and associated wiring shall utilize applicable publications that apply this document such as NFPA 70 (*NEC*), CSA C22.1 (*Canadian Electrical Code*), or API 14FZ.

NOTE There are other publications that establish area classification criteria that may differ from those in this document. Refer to those documents for installation requirements, protection techniques, and wiring methods that align with the area classification criteria applied.

1.2 Application

1.2.1 This RP applies to the classification of locations for both temporarily and permanently installed electrical equipment. It is intended to be applied where there may be a risk of ignition due to the presence of flammable gases, flammable liquid produced vapors, or combustible liquid produced vapors mixed with air under normal atmospheric conditions. Normal atmospheric conditions are defined as conditions that vary above and below reference levels of 101.3 kPa (14.7 psia) and 20 °C (68 °F) provided that the variations have a negligible effect on the explosion properties of the flammable materials.

The following items are beyond the scope of this document:

- a) piping systems used for odorized natural gas used as fuel for cooking, heating, air conditioning, laundry, and similar appliances;
- b) catastrophes such as well blowouts or process vessel ruptures—such extreme events are not predictable and require emergency measures at the time of occurrence;
- c) the suitability of locations for the placement of non-electrical incendiary equipment;
- d) classification for locations containing combustible dust, ignitable fibers, or flyings;
- e) installations underground in mines;
- f) areas for the processing and manufacture of explosives; and
- g) areas where the presence of flammable mist may give rise to an unpredictable risk and that require special consideration.