

NEMA Standards Publication

NEMA ICS 14-2007

Application Guide for Electric Fire Pump Controllers

National Electrical Manufacturers Association



NEMA ICS 14

**APPLICATION GUIDE
FOR ELECTRIC FIRE
PUMP CONTROLLERS**

NEMA Standards Publication ICS 14-2007

Application Guide for Electric Fire Pump Controllers

Published by:

National Electrical Manufacturers Association

1300 North 17th Street, Suite 1752
Rosslyn, Virginia 22209

www.nema.org

© Copyright 2007 by the National Electrical Manufacturers Association. All rights including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

The National Electrical Manufacturers Association (NEMA) standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

CONTENTS

Foreword.....	ii
1 GENERAL	1
1.1 Scope.....	1
1.2 Definitions	1
1.3 Referenced Publications.....	1
1.4 Special Considerations for Fire Pump Controllers	1
2 DESIGN CONSIDERATIONS	2
2.1 Power Conductors Connected to the Fire Pump Controller and Motor.....	2
2.2 Environmental Considerations for Enclosures	4
2.3 Transformer Sizing	5
2.4 Transfer Switch Considerations.....	6
2.5 Considerations for Specifying Short Circuit Rating (RMS SYM)	10
2.6 Reduced Voltage Starting Methods.....	14
2.7 Limited Service Controller Limitations	14
2.8 Listed Fire Pump Motor Applications.....	15
2.9 Pressure Recorders.....	16
2.10 Stand-By Generator Sizing for Fire Pumps	16
2.11 Medium Voltage Fire Pump Controllers (7.2 kV Max)	17
2.12 Variable Speed Pressure Limiting Electric Fire Pump Controllers	18
3 INSTALLATION CONSIDERATIONS	19
3.1 Phase Sequence	19
3.2 Normal Starting with On-Site Generators.....	20
3.3 Induced Voltages on Contacts For Remote Signaling.....	20
3.4 Grounded Circuit Conductor (Neutral or Neutral Conductor) Considerations.....	20
4 OTHER CONSIDERATIONS	21
4.1 Listed and Approved Equipment	21
4.2 Testing and Maintenance	21

Tables

1	Comparison of Specific Applications of Enclosures for Indoor Non-hazardous Locations.....	5
2	Fire Pump Controller Short Circuit Current Rating.....	11
3	Transformer Secondary Voltage and Available Secondary Short-Circuit Current.....	13
4	Reduced Voltage Starting Methods.....	14

Figures

1	Typical Fire Pump Controller and Transfer Switch Arrangements I and II Normal Source from a Utility and Alternate Source from an On-Site Generator	8
2	Typical Fire Pump Controller and Transfer Switch Arrangements III and IV Normal Source from a Utility and Alternate Source from a Second Utility and On-Site Generator	9
3	Variable Speed Pressure Limiting Electric Fire Pump Controller.....	19

Foreword

This Application Guide was prepared by a technical committee of the NEMA Industrial Control and Systems Section. It was approved in accordance with the bylaws of NEMA.

This Application Guide provides practical information concerning the general technical considerations in the installation of electric fire pump controllers. It is intended to be used by specifiers, purchasers, installers, and owners of fire pump controllers.

This Application Guide represents the result of many years of research, investigation, and experience by the members of the NEMA Industrial Control and Systems Subcommittee on Fire Pump Control. It was written as a service in response to the many questions from the user public, specifiers, and inspection authorities regarding fire pump controller installations. The intent is to pursue excellence in design, manufacture, and service of products made by NEMA member companies. It has been developed through continuing consultation among manufacturers, users, and national engineering societies. It is not intended to instruct the user of fire pump control equipment except insofar as to provide recommendations and some application guidance.

This Application Guide is necessarily confined to providing recommendations for a successful installation. When equipment conforming with these recommendations is properly selected, is installed in accordance with the *National Electrical Code (NFPA 70)* and the *Standard for the Installation of Stationary Pumps for Fire Protection (NFPA 20)*, and is properly maintained, the hazards to persons and property will be reduced. However, since any piece of industrial control equipment can be installed, operated, and maintained in such a manner that hazardous conditions may result, following the recommendation of this Guide does not by itself assure a safe installation.

NEMA publications are subject to periodic review. They are revised frequently to reflect user input and to meet changing conditions and technical progress. Users should secure the latest editions.

Proposed revisions to this Application Guide should be submitted to:

Vice President, Engineering Department
National Electrical Manufacturers Association
1300 North 17th Street, Suite 1752
Rosslyn, Virginia 22209

1 GENERAL

1.1 SCOPE

This Application Guide is intended to provide general guidelines for the proper application of fire pump controllers. The emphasis of these guidelines is to stress those considerations specific to fire pump installations. Applicable NEMA standards and the standards of other standards developing organizations should also be consulted.

1.2 DEFINITIONS

There are no definitions unique to fire pump controllers.

1.3 REFERENCED PUBLICATIONS

NFPA 20-2007	<i>Standard for the Installation of Stationary Pumps for Fire Protection¹</i>
NFPA 25-2002	<i>Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems</i>
NFPA 70-2005	<i>National Electrical Code²</i>
IEEE 242-2001	<i>IEEE Recommended Practice for Protection and Coordination of Industrial and Commercial Power Systems</i>
NEMA 250	<i>Enclosures for Electrical Equipment (1000 Volts Maximum)</i>
NEMA ICS 3-1993 (R2000)	<i>Industrial Control and Systems: Medium Voltage Controllers Rated 2001 to 7200 Volts AC</i>
NEMA ICS 3.1-1997	<i>Industrial Control and Systems. Handling, Storage and Installation Guide for AC General Purpose contactors and class E Controllers, 50 & 60 Hz.</i>
NEMA ICS 15-2004	<i>Instructions for the Handling, Installation, Operation and Maintenance of Electric Fire Pump Controllers Rated Not More Than 600V</i>

1.4 SPECIAL CONSIDERATIONS FOR FIRE PUMP CONTROLLERS

Installation requirements of fire pump controllers, by virtue of their special considerations, are covered in Article 695 of the National Electrical Code (NFPA 70) and the performance, maintenance, and acceptance testing of the fire pump system and the internal wiring of the components of the system are covered in NFPA 20. Periodic testing of the complete fire protection system is addressed in NFPA 25. These requirements, in many significant ways, are uniquely different from those pertaining to industrial, commercial and residential installations in order to increase the reliability of the system. As an overview, some of these differences are:

NOTE—See 2.12 for significant deviations for medium voltage fire pump controllers and refer to NEC Article 490.

- a) Service Disconnects: Special rules pertaining to the service disconnects in order to minimize inadvertent disconnection. (NFPA 70, 695.3 which refers to 230.82(5), 230.2, and 230.72(B))
- b) Conductor Protection:
 1. Special overcurrent and physical protection requirements for the power supply conductors exist to minimize potential interruption during a fire. (NFPA 70, 695.3(A), 695.4(B)(1), and 695.5(C)(2))
 2. Coordinated overcurrent protection of the motor branch circuit conductors to trip the circuit breaker in the fire pump controller rather than an upstream device. (NFPA 70, 240.12)
- c) No Motor Overload Protection: Fire pump motor protection is limited to locked rotor and short circuit protection only. (NFPA 20, 10.4.3 and 10.4.4)

¹ Particular attention should be given to Chapters 9 and 10.

² Particular attention should be given to Article 695.