

Burners for Fired Heaters in General Refinery Services

API STANDARD 535
FOURTH EDITION, JULY 2024



Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

Users of this standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be used. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001-5571.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

Contents

	Page
1 Scope.....	1
2 Normative References	1
3 Terms, Definitions, and Abbreviations.....	1
3.1 General Terms and Definitions.....	1
3.2 Specific Definitions	2
3.3 Symbols and Abbreviations	8
4 Proposals and Documentation.....	8
4.1 Purchaser’s Responsibilities	8
4.2 Vendor’s Responsibilities.....	9
4.3 Documentation Requirements	9
4.4 Performance Tests and Guarantees	11
5 Functional Requirements—Burners.....	11
5.1 Airside Design.....	11
5.2 Basis of Flame Shape and Dimension Requirements	12
5.3 Burner Ignition	12
5.4 Flame Detection Requirements	13
5.5 Required Stable Operating Envelope	13
5.6 Optional Stability Requirements	14
6 Functional Requirements—Pilots	14
6.1 General.....	14
6.2 Airside Design.....	14
6.3 Flame Ignition Requirements.....	14
6.4 Flame Detection Requirements	15
6.5 Stable Operating Envelope.....	15
6.6 Transient Operations	15
7 Mechanical Requirements—Burners	15
7.1 General Requirements.....	15
7.2 Tiles	16
7.3 Manifold Gas Distribution Systems.....	16
7.4 Tip-Riser Assembly Systems	17
7.5 Air Plenums/Individual Windbox	18
7.6 Ports and Connections	20
8 Mechanical Requirements—Pilots	20
8.1 General.....	20
8.2 Flame Detection.....	21
9 Fabrication	21
9.1 Welding.....	21
9.2 Flange Face.....	21
9.3 Piping.....	21
9.4 Paint.....	21
9.5 Tiles	22
10 Inspection and Component Testing.....	22

Contents

	Page
10.1 Visual Inspection.....	22
10.2 Dimensional Inspection.....	22
10.3 Mechanical Function Inspection	23
10.4 Materials Inspection.....	23
10.5 Additional Checks	23
11 Identification, Handling, Storage, and Shipment.....	24
11.1 General	24
12 Burner Testing.....	24
12.1 General	24
12.2 Test Furnace Requirements.....	24
12.3 Test Fuels	25
12.4 Air Supply	25
12.5 Ignition and Flame Detection Devices	26
12.6 Burner Test Points.....	26
12.7 Optional/Exploratory Test Points.....	26
12.8 Test Instrumentation	27
12.9 Measurements	27
12.10 Acceptance Criteria	29
Annex A (informative) Equipment Datasheets.....	30
Annex B (informative) Burner Test Procedure	53
Annex C (informative) Purchaser’s Checklist.....	58
Annex D (normative) Oil/Liquid Fuel Firing.....	60
Bibliography.....	64

Tables

1 Fuel Gas Burner Components	17
2 Burner Casing and Burner Damper/Register	20
C.1 Purchaser’s Checklist for Burners for Fired Heaters in General Refinery Services.....	58
D.1 Liquid Burner Materials of Construction.....	62
D.2 Liquid Burner Testing	63

Introduction

Burners are devices that mix air and fuel to provide stable combustion and hot gas for the transfer of heat to process fluids in general refinery services. A burner design basis is developed in consideration of the specified performance expectations, functional requirements, and mechanical details required to fulfill the operating goals established for each application. This standard provides the basis for design, functional and mechanical requirements, and burner testing requirements to provide safe, reliable, and efficient combustion of fuel to enable the heater to satisfy its operating requirements.

The burner types addressed in this standard are commonly used and available in a variety of configurations and sizes. Burner types generally include premix, raw gas, staged air, staged fuel, and others. Most types are available in either natural-draft or forced-air arrangements, or both. The burner types listed are not intended to imply that other burner types are not available or applicable. Many of the individual features described in this standard are applicable to most burner types.

Burners designed to this standard are used in a wide range of petrochemical and refinery applications, and are influenced by the fired heater design. These burners may need to be capable of handling a large variation in fuel composition, be subjected to different ignition methods, and be monitored by a variety of different flame-detection techniques. Generally, burners built to this standard are engineered for the specific application while addressing the owner specifications/standards and the jurisdictional regulatory requirements to which the owner's facility is subjected.

For new designs, the development of a design can be advanced using the direction and examples of good engineering practice identified in this standard.

Users of this standard should be aware that further or differing requirements may be needed for individual applications. This standard is not intended to inhibit a vendor from offering, or the purchaser from accepting, alternative equipment or engineering solutions for the individual application. This may be particularly applicable where there is innovative or developing technology. Where an alternative is offered, the vendor should identify any variations from this standard and provide details.

In API standards, the International System of Units (SI) is used. In this standard, where practical, U.S. Customary (USC) units are included in brackets for information.

A bullet [●] at the beginning of a clause or sub-clause indicates that either a decision is required, or further information is to be provided, by the purchaser. This information should be indicated on the purchaser's checklist (see [Annex C](#)) or stated in the inquiry or purchase order.

Burners for Fired Heaters in General Refinery Services

1 Scope

This standard provides requirements and direction for the selection, specification, materials, and testing of burners for fired heaters in general refinery services designed in accordance with API 560. Details of fired heater and related equipment designs are considered only where they interact with the burner selection.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API 556, *Instrumentation, Control, and Protective Systems for Gas Fired Heaters*

API 560, *Fired Heaters for General Refinery Services*

3 Terms, Definitions, and Abbreviations

For the purposes of this document, the following terms and definitions apply.

3.1 General Terms and Definitions

The following general definitions are provided to better define and distinguish the multidisciplined workforce and the typical areas of responsibility involved in the specification, design, and supply work processes required in the overall procurement process for burners in fired heaters in general refinery services. These definitions are intended to build upon the typical definitions of “purchaser” and “vendor” normally used in API standards.

Recognizing that the work process and areas of responsibility may differ between projects and owner organizations, the terms and definitions contained in the purchaser’s procurement documentation take precedence over definition of parties of the multidisciplined workforces and their respective areas of responsibility.

3.1.1

owner

purchaser

The owner or purchaser is the party with responsibility for all or part of the process and thermal design/definition, the mechanical specification, procurement, and installation of the purchased equipment.

NOTE The owner or purchaser may, at times, work through an engineering contractor (contractor) as an agent undertaking the owner’s requirement for the engineering, procurement, and/or construction phases of work, including representation of the owner on decisions related to operation and maintenance as may be required. The term “purchaser” within this document will be considered synonymous with the terms “contractor” or “owner.”

3.1.2

vendor

The party that supplies the design, manufacturing, equipment, and any services required as specified by the purchaser.

NOTE 1 The vendor typically has the prime responsibility for the detailed engineering, material procurement, project management, and manufacturing processes involved in the physical supply of the burner, including all aspects of quality assurance and quality control for work of their own and others whom they qualify for providing work, products, or services on their behalf.