

Standard for Fire Test for End Connectors

API STANDARD 6FB
FOURTH EDITION, MAY 2019



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These standards are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be used. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001-5571.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows:

Shall: As used in a standard, “shall” denotes a minimum requirement to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, publishes a catalog of API publications and materials annually.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

Contents

	Page
1 Scope	1
2 Normative References	1
3 Terms, Definitions, Acronyms, Abbreviations, Symbols, and Units	1
3.1 Terms and Definitions	1
3.2 Acronyms and Abbreviations	2
3.3 Symbols and Units	2
4 Fire Test	2
4.1 General	2
4.2 Test Article	3
4.3 Test Facility	4
4.4 Test Procedure	9
4.5 Marking Requirements	14
5 Scaling	14
5.1 General	14
5.2 Validation Testing Based on Other Designs	14
5.3 Allowances of Scaling by Size	15
5.4 Allowances of Scaling by Pressure Rating	15
5.5 Allowances of Scaling for Nonmetallic Materials	15
5.6 Allowances of Scaling for Metallic Materials	15
6 Certificate of Conformance	16
Bibliography	17

Figures

1 Schematic of Suggested Systems for Fire Testing of End Connectors	5
2 Calorimeter Cube Design Details	6
3 Schematic of Suggested Leak Measurement System	7
4 Typical Bend Test Arrangement with One Ram Cylinder	8
5 Typical Bend Test Arrangement with Two Ram Cylinders	9
6 Location of Thermocouples and Calorimeters—Onshore Conditions	10
7 Location of Burner, Calorimeter, and Thermocouple—Offshore Well Bay Conditions	12

Introduction

This standard is under the jurisdiction of the API Subcommittee on Valves and Wellhead Equipment (API Subcommittee 6). This standard is the result of updating the requirements from API Specification 6FB, Third Edition. This standard covers the requirements for test and evaluation of the performance of API 6A and API 6D end connectors when exposed to specifically defined fire conditions.

Standard for Fire Test for End Connectors

1 Scope

The purpose of this standard is to establish the requirements for testing and evaluating the pressure-containing performance of end connectors designated in API standards when exposed to fire or fire with bending. The performance requirements of this standard establish standard qualification criteria for all sizes and pressure ratings of end connectors.

This standard establishes acceptable levels for external leakage through an end connector after exposure to a fire for a 30-minute time period. The fire exposure has been established on the basis that it represents the maximum time required to extinguish most fires. Fires of greater duration are of a major magnitude with consequences greater than those anticipated in this test.

This standard covers but is not limited to API 6A and API 6D end connectors.

This standard does not intend to address the qualification of valves, wellhead seals, or other related equipment.

2 Normative References

The following referenced documents are indispensable for the application of this standard. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies, except that new editions may be used on issue and shall become mandatory upon the effective date specified by the publisher or 6 months from the date of the revision (where no effective date is specified).

API Specification 6A, *Specification for Wellhead and Tree Equipment*

API Specification 6D, *Specification for Pipeline Valves and Piping Valves*

API Technical Report 6AF, *Technical Report on Capabilities of API Flanges Under Combinations of Load*

API Technical Report 6AF1, *Technical Report on Temperature Derating on API Flanges under Combination Loading*

API Technical Report 6AF2, *Technical Report on Capabilities of API Integral Flanges Under Combinations of Loading—Phase II*

3 Terms, Definitions, Acronyms, Abbreviations, Symbols, and Units

3.1 Terms and Definitions

For the purpose of this standard, the following definitions and the definitions in API 6A and API 6D shall apply. When identical terms are defined in API 6A and API 6D and this standard, the following definitions shall apply.

3.1.1

connector family

Group of connectors that are based on the same design specifications or standards.

3.1.2

pressure class

Numerical pressure design class expressed in accordance with the ASME rating class.