



PROCESS
INDUSTRY
PRACTICES

REAFFIRMATION
September 2022

Process Control

PIP PCSPA001
Instructions for Process Analyzer System
Documentation Requirements Sheets

PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

In an effort to minimize the cost of process industry facilities, this Practice has been prepared from the technical requirements in the existing standards of major industrial users, contractors, or standards organizations. By harmonizing these technical requirements into a single set of Practices, administrative, application, and engineering costs to both the purchaser and the manufacturer should be reduced. While this Practice is expected to incorporate the majority of requirements of most users, individual applications may involve requirements that will be appended to and take precedence over this Practice. Determinations concerning fitness for purpose and particular matters or application of the Practice to particular project or engineering situations should not be made solely on information contained in these materials. The use of trade names from time to time should not be viewed as an expression of preference but rather recognized as normal usage in the trade. Other brands having the same specifications are equally correct and may be substituted for those named. All Practices or guidelines are intended to be consistent with applicable laws and regulations including OSHA requirements. To the extent these Practices or guidelines should conflict with OSHA or other applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by the Practice.

This Practice is subject to revision at any time.

© Process Industry Practices (PIP), Construction Industry Institute, The University of Texas at Austin, 3925 West Braker Lane (R4500), Austin, Texas 78759. PIP Member Companies and Subscribers may copy this Practice for their internal use. Changes or modifications of any kind are not permitted within any PIP Practice without the express written authorization of PIP. Authorized Users may attach addenda or overlays to clearly indicate modifications or exceptions to specific sections of PIP Practices. Authorized Users may provide their clients, suppliers and contractors with copies of the Practice solely for Authorized Users' purposes. These purposes include but are not limited to the procurement process (e.g., as attachments to requests for quotation/ purchase orders or requests for proposals/contracts) and preparation and issue of design engineering deliverables for use on a specific project by Authorized User's client. PIP's copyright notices must be clearly indicated and unequivocally incorporated in documents where an Authorized User desires to provide any third party with copies of the Practice.

PUBLISHING HISTORY

<i>August 2000</i>	<i>Issued</i>	<i>June 2012</i>	<i>Reaffirmation with Editorial Revision</i>
<i>February 2001</i>	<i>Editorial Revision</i>	<i>May 2017</i>	<i>Complete Revision</i>
<i>August 2006</i>	<i>Complete Revision</i>	<i>September 2022</i>	<i>Reaffirmation</i>

Not printed with State funds



PIP PCSPA001

Instructions for Process Analyzer System Documentation Requirements Sheets

Table of Contents

1. Scope.....	2
2. References	2
Process Industry Practices	2
3. Requirements.....	2
3.1 General	2
3.2 <i>PIP PCSPA001-R</i> Data Sheet Instructions.....	3

Data Form

PIP PCSPA001-R - Process Analyzer System
Documentation Requirements Sheet

1. Scope

This Practice provides instructions for preparing a Process Analyzer System Documentation Requirements Sheet, *PIP PCSPA001-R*, which provides the requirements for project documentation to design, procure, install, and operate an analyzer system. *PIP PCSPA001-R* helps to establish contractual obligations regarding the technical aspects of the purchase agreement.

This Practice describes documents to be furnished by the purchaser, and documents to be provided by an analyzer system vendor for a given analyzer product.

PIP PCSPA001-R may apply to a single process analyzer system or to any number of analyzer systems and any associated shelters, enclosures, and other support equipment. A process analyzer system typically consists of a sample conditioning system, a process analyzer, and one or more data output devices.

2. References

Applicable parts of the following Practices shall be considered an integral part of this Practice. The edition of the Practice in effect on the date of contract award shall be used, except as otherwise noted. Short titles are used herein where appropriate.

Process Industry Practices (PIP)

- PIP PCCPA001 - *Process Analyzer System Design Criteria*
- PIP PCEPA002 - *Process Analyzer Project Implementation Guidelines*
- PIP PCSPA001-R - *Process Analyzer Project Documentation Requirements Sheet* (included in this Practice)
- PIP PCSPA002-D - *Process Analyzer System Data Sheet*
- PIP PCSPA003-D - *Process Analyzer Shelter Data Sheet*
- PIP PCSPA004-D - *Process Analyzer Bid Proposal Data Sheet*
- PIP PCTPA001 - *Testing of Process Analyzer Systems*

3. Requirements

3.1 General

- 3.1.1 Purchaser's data sheet, *PIP PCSPA001-R*, shall be furnished for each process analyzer system.
- 3.1.2 If not furnished by the purchaser, *PIP PCSPA001-R* may be provided by the Analyzer System Vendor (ASV) as part of their bid package.
- 3.1.3 *PIP PCSPA001-R* is divided into seven sections:
 - a. *1.0 - Documents Furnished to Bidders*: List of general documents furnished by purchaser
 - b. *2.0 - Completed Data Sheets Furnished to Bidders*: List of purchaser furnished data sheets