



PROCESS
INDUSTRY
PRACTICES

TECHNICAL REVISION
March 2024

Process Control

PIP PCCPR001
Pressure Measurement Design Criteria

PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

This Practice has been prepared by harmonizing technical requirements from existing standards of major industrial operators, contractors, and standards development organizations. While this Practice is intended to incorporate the majority of requirements, individual applications may have requirements which take precedence over this Practice. Determinations concerning fitness for purpose or application of this Practice to specific project or engineering situations should not be made solely on information contained in this Practice. All Practices are intended to be consistent with applicable laws and regulations. Should this Practice conflict with applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by this Practice.

Use of trade names should not be viewed as an expression of preference. Other brands having the same specifications are equally correct and may be substituted for those named.

This Practice is subject to revision at any time. For more information refer to PIP ADG001, *Specification for Developing Practices*.

© 1997 Process Industry Practices (PIP), Construction Industry Institute, and The University of Texas at Austin on behalf of the Board of Regents of the University of Texas System

Process Industry Practices
3925 West Braker Lane (R4500)
Austin, Texas 78759

PUBLISHING HISTORY

July 1997	Issued	December 2017	Complete Revision
April 2007	Complete Revision	March 2024	Technical Revision
July 2013	Complete Revision		

Not printed with State funds



PIP PCCPR001

Pressure Measurement Design Criteria

Table of Contents

1. Scope	2
2. References	2
2.1 Process Industry Practices	2
2.2 Industry Codes and Standards	2
3. Requirements	2
3.1 General	2
3.2 Pressure Gauges	4
3.3 Pressure Switches	4
3.4 Pressure Transmitters	5
3.5 Differential Pressure	5

1. Scope

This Practice provides requirements criteria for pressure measurement equipment selection and for design of pressure measurement systems. This Practice describes the design requirements for pressure and differential pressure measurement systems excluding DP level and flow measurements.

2. References

Applicable parts of the following Practices and industry codes and standards shall be considered an integral part of this Practice. The edition in effect on the date of contract award shall be used, except as otherwise noted. Short titles are used herein where appropriate.

2.1 Process Industry Practices (PIP)

- PIP PCIDP100 - *Differential Pressure Transmitter Installation Details*
- PIP PCIPR100 - *Pressure Transmitter Installation Details*

2.2 Industry Codes and Standards

International Society of Automation (ISA)

- ISA S20 - *Specification Forms for Process Measurement and Control Instruments, Primary Elements and Control Valves*

3. Requirements

3.1 General

3.1.1 Data

- 3.1.1.1 A data set shall be provided for each sensor.
- 3.1.1.2 The data set may be in electronic or hard-copy format.
- 3.1.1.3 The minimum data set shall be in accordance with *ISA S20* specification forms.

3.1.2 Root (isolation) valves shall be provided for each instrument.

3.1.3 Provision for relieving pressure (vent/drain) between root valve and instrument before removal shall be provided.

3.1.4 Flush-mounted seals may be installed without root (isolation) valves with owner approval.

3.1.5 As a minimum, all pressure devices shall be specified with over-range protection to 1-1/2 times the maximum system operating pressure.

3.1.6 Material selection for pressure device wetted parts shall be stainless steel, unless other materials are required to meet process conditions.