



**CSA
Group**

CSA B52-13

Mechanical refrigeration code



Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

CSA B52-13 December 2013

Title: *Mechanical refrigeration code*

To register for e-mail notification about any updates to this publication

- go to shop.csa.ca
- click on **CSA Update Service**

The **List ID** that you will need to register for updates to this publication is **2422548**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at csagroup.org/legal to find out how we protect your personal information.

CSA B52-13

Mechanical refrigeration code



™A trade-mark of the Canadian Standards Association, operating as “CSA Group”

*Published in December 2013 by CSA Group
A not-for-profit private sector organization
5060 Spectrum Way, Suite 100, Mississauga, Ontario, Canada L4W 5N6*

*To purchase standards and related publications, visit our Online Store at shop.csa.ca
or call toll-free 1-800-463-6727 or 416-747-4044.*

ISBN 978-1-77139-237-2

© 2013 CSA Group

All rights reserved. No part of this publication may be reproduced to any form whatsoever without the prior permission of the publisher.

Contents

| | |
|---|-----------|
| Mechanical Refrigeration Code (B52) | 4 |
| Preface | 8 |
| 1 Scope | 10 |
| 1.1 Purpose | 10 |
| 1.2 Application | 10 |
| 1.3 Mandatory language | 10 |
| 1.4 Units of measurement | 11 |
| 2 Reference publications | 11 |
| 3 Definitions and abbreviations | 12 |
| 3.1 Definitions | 12 |
| 3.2 Abbreviations | 18 |
| 4 System selection and application requirements | 19 |
| 4.1 Application procedure | 19 |
| 4.2 Classification by occupancy | 19 |
| 4.2.1 General | 19 |
| 4.2.2 Institutional occupancy | 19 |
| 4.2.3 Public assembly occupancy | 19 |
| 4.2.4 Residential occupancy | 20 |
| 4.2.5 Commercial occupancy | 20 |
| 4.2.6 Industrial occupancy | 20 |
| 4.2.7 Mixed occupancy | 20 |
| 4.2.8 Adjacent locations | 20 |
| 4.3 Classification of refrigeration systems | 20 |
| 4.3.1 Classification by type | 20 |
| 4.3.2 Classification by leakage probability | 23 |
| 4.4 Classification by refrigerant | 24 |
| 4.5 System application requirements | 27 |
| 4.5.1 General | 27 |
| 4.5.2 System application rules | 27 |
| 4.5.3 Equipment applied in a high-probability system | 29 |
| 4.6 Additional requirements for institutional, public assembly, residential, and commercial occupancies | 29 |
| 4.6.1 Public stairway, stair landing, or exit | 29 |
| 4.6.2 Public hallway or lobby | 29 |
| 5 Equipment design and construction | 29 |
| 5.1 Drawings, specifications, and data reports | 29 |
| 5.2 Refrigeration systems rated 125 kW or less | 30 |
| 5.3 Filing of drawings | 30 |
| 5.3.1 Submission of drawings and specifications | 30 |
| 5.3.2 Contents of drawings | 30 |
| 5.4 Materials | 31 |

| | | |
|--------|--|----|
| 5.5 | Design pressures | 31 |
| 5.6 | Refrigerant-containing pressure vessels | 34 |
| 5.7 | Refrigerant piping, fittings, evaporator and condenser coils, and associated headers | 34 |
| 5.7.1 | Refrigerant piping and fittings | 34 |
| 5.7.2 | Minimum requirements for unprotected refrigerant piping and tubing | 34 |
| 5.7.3 | Evaporator and condenser coils and associated headers | 35 |
| 5.8 | Components other than pressure vessels, piping, and fittings | 35 |
| 5.9 | Design provisions for service | 36 |
| 5.10 | Pressure testing | 37 |
| 5.10.1 | General | 37 |
| 5.10.2 | Test medium | 37 |
| 5.10.3 | Factory tests | 37 |
| 5.10.4 | Field tests | 38 |
| 5.11 | Marking and labelling | 38 |
| 5.11.1 | Signs (all systems) | 38 |
| 5.11.2 | Nameplates for unit systems, condensing units, compressors, and compressor units | 39 |
| 5.11.3 | Signs for systems containing more than 45 kg (100 lb) of refrigerant | 39 |
| 5.11.4 | New signs for changed refrigerant | 39 |
| 5.11.5 | Posting of instructions | 39 |
| 5.12 | Substitution of refrigerant type | 39 |

6 Installation 40

| | | |
|-------|---|----|
| 6.1 | General | 40 |
| 6.2 | Machinery rooms | 40 |
| 6.2.1 | General | 41 |
| 6.2.2 | Doors | 41 |
| 6.2.3 | Refrigerant vapour detector | 41 |
| 6.2.4 | Explosion protection | 41 |
| 6.2.5 | Ventilation | 42 |
| 6.3 | Class T machinery rooms | 43 |
| 6.4 | Machinery rooms — Electrical requirements for ammonia systems | 44 |
| 6.4.1 | Class T machinery rooms | 44 |
| 6.4.2 | Machinery rooms | 44 |
| 6.5 | Water supply and discharge connections | 44 |
| 6.6 | Electrical wiring | 44 |
| 6.7 | Gas devices | 45 |
| 6.8 | Location of refrigerant piping | 45 |
| 6.9 | Joints and refrigerant-containing parts in air ducts | 45 |
| 6.10 | Emergency discharge | 46 |
| 6.11 | Purge discharge | 46 |

7 Overpressure protection 46

| | | |
|-------|---|----|
| 7.1 | Pressure vessel protection | 46 |
| 7.1.1 | ASME <i>Boiler and Pressure Vessel Code</i> requirements | 46 |
| 7.1.2 | Pressure vessels with an internal gross volume of 0.085 m ³ (3 ft ³) or less | 46 |
| 7.1.3 | Pressure vessels with an internal gross volume exceeding 0.085 m ³ (3 ft ³) | 46 |
| 7.1.4 | Pressure-relief devices for pressure vessels used as, or as part of, evaporators | 47 |
| 7.2 | System protection | 47 |
| 7.2.1 | Pressure-limiting devices | 47 |

| | | |
|-----------------------|--|-----------|
| 7.2.2 | Setting of pressure-limiting devices | 47 |
| 7.2.3 | Pressure-imposing device protection | 48 |
| 7.2.4 | Hydrostatic Expansion | 49 |
| 7.3 | Pressure-relief devices | 49 |
| 7.3.1 | General | 49 |
| 7.3.2 | Location of pressure-relief devices | 50 |
| 7.3.3 | Setting of pressure-relief devices | 50 |
| 7.3.4 | Capacity of pressure-relief devices | 51 |
| 7.3.5 | Marking of fusible plugs and other pressure-relief devices | 52 |
| 7.3.6 | Discharge of fusible plugs and other pressure-relief devices | 53 |
| 8 | Maintenance of systems | 66 |
| 8.1 | Charging and withdrawal of refrigerants | 66 |
| 8.1.1 | General | 66 |
| 8.1.2 | Charging R-744 systems | 67 |
| 8.1.3 | Charging or withdrawal of refrigerants into or out of heat transfer systems utilizing secondary heat transfer fluids subject to solidification. | 67 |
| 8.2 | Refrigerants withdrawn from refrigeration systems | 67 |
| 8.2.2 | Secondary refrigerants and lubricants withdrawn from refrigeration systems | 68 |
| 8.3 | Refrigerant storage | 68 |
| 8.4 | Maintenance | 68 |
| 9 | Precautions | 70 |
| 9.1 | Protective equipment | 70 |
| 9.2 | Enclosed spaces | 70 |
| <hr/> | | |
| Annex A (informative) | — Maximum allowable concentration of mixtures | 71 |
| Annex B (informative) | — Guidelines for emergency discharge of refrigerants | 72 |
| Annex C (informative) | — Worst-case composition of fractionation | 74 |
| Annex D (informative) | — Conversion factors | 75 |
| Annex E (informative) | — A method for calculating the discharge capacity of pressure-relief devices for positive displacement compressors | 76 |
| Annex F | — Reserved | 78 |
| Annex G | — Reserved | 79 |
| Annex H (normative) | — Allowable equivalent length of discharge piping | 80 |
| Annex I (informative) | — CSA B52 Information Bulletin on use of hydrocarbon refrigerants in new equipment and as drop-in replacements for other classes of refrigerants in existing systems | 82 |
| Annex J (normative) | — Working with R-744 (CO ₂) systems — Precautions and potential hazards | 84 |
| Annex K (informative) | — Characteristics of carbon dioxide | 86 |
| Annex L (Informative) | — Infrequently used refrigerants: classification, quantity, design pressure, and discharge capacity | 87 |

Mechanical Refrigeration Code (B52)

| | | |
|------------------------|---|-------------------|
| L.W. Burgett | Trane a Business of Ingersoll Rand, La Crosse, Wisconsin, USA | <i>Chair</i> |
| K.T. Lau | ABSA, Edmonton, Alberta | <i>Vice-Chair</i> |
| S. Ahmed | British Columbia Safety Authority (BCSA), Coquitlam, British Columbia | |
| A. Ali | Government of Nunavut Community & Government Services, Iqaluit, Nunavut | |
| S. Alison | Carrier Canada Limited, Mississauga, Ontario | |
| E. Bergshoeff | Hager Industries Inc., Burlington, Ontario | |
| W.S. Burnat | Enviroaire Heating & Cooling, Newcastle, Ontario | |
| P. Christensen | Yukon Government Community Services, Whitehorse, Yukon Territory | |
| E. Creaser | Province of New Brunswick Dept of Public Safety, Fredericton, New Brunswick | |
| G. DiFebo | UA Local 787, Joint Apprentice and Training Committee, Brampton, Ontario | |
| P.L. Dodge | Nova Scotia Department of Labour Advanced Education, Halifax, Nova Scotia | |
| D. Eastman | Service NL, Newfoundland & Labrador, St. John's, Newfoundland and Labrador | |
| B.D. Fierheller | Office of the Fire Commissioner, Winnipeg, Manitoba | |

| | | |
|------------------------|---|------------------|
| I.D. Frost | United Association Local 787, Brampton, Ontario | |
| K.M. Greenwood | Praxair Canada Inc, Mississauga, Ontario | |
| A.D. Hantelmann | Alberta Municipal Affairs, Edmonton, Alberta | <i>Associate</i> |
| Y. Huang | Royal & SunAlliance Insurance Company of Canada, Toronto, Ontario | |
| J.G. Inglis | ArcelorMittal Dofasco, Hamilton, Ontario | |
| J. Jakob | CSA Group, Toronto, Ontario | <i>Associate</i> |
| S. Katz | S. Katz and Associates Inc., North Vancouver, British Columbia | |
| H. Klaver | British Columbia Safety Authority (BCSA), New Westminster, British Columbia | |
| B. Krasium | ASFALEIA Inspection & Management Services Ltd, Regina, Saskatchewan | |
| D. Landry | Department of Labour and Advanced Education, Halifax, Nova Scotia | <i>Associate</i> |
| M. Mailman | Government of the Northwest Territories, Yellowknife, Northwest Territories | |
| D. Malinauskas | Cimco Refrigeration Division of Toromont Industries Ltd, Toronto, Ontario | |
| D. McMorrow | Mitsubishi Electric Sales Canada Inc., Markham, Ontario | <i>Associate</i> |
| P. Morel | Toromont Industries Ltd. / Industries Toromont Ltée, Ville d'Anjou, Québec | <i>Associate</i> |

| | | |
|------------------------|--|------------------|
| D.A. Murphy | Frick by Johnson Controls, East Berlin, Pennsylvania, USA | |
| A. Park | Compressed Gas Association, Ottawa, Ontario | |
| D.P. Reiter | Ontario Power Generation Inc, Pickering, Ontario | <i>Associate</i> |
| J.P. Scott | Natural Resources Canada, Varenes, Québec | |
| C. Selinger | Technical Safety Authority of Saskatchewan, Regina, Saskatchewan | |
| J. Sénéchal | Air Liquide Canada Inc., Montréal, Québec | |
| D. Srnic | ABSA, Edmonton, Alberta | <i>Associate</i> |
| P. Sterescu | Boiler Inspection & Insurance Company of Canada, Toronto, Ontario | |
| M. St-Georges | Régie du bâtiment du Québec, Montréal, Québec | |
| R.L. Strickland | ISS Facility Services, Virgil, Ontario | |
| C.S. Sucher | Sucher Consulting Engineering Inc, Toronto, Ontario | |
| I. Svorinic | British Columbia Safety Authority (BCSA), New Westminster, British Columbia | <i>Associate</i> |
| S.R. Townsend | Government of Prince Edward Island, Charlottetown, Prince Edward Island | |
| C. Turylo | Technical Standards & Safety Authority (TSSA), Toronto, Ontario | |
| L. VanBerkel | Golen Engineering Inc, Burlington, Ontario | |

| | | |
|---------------------|--|------------------------|
| P. Yeung | ABSA, Edmonton, Alberta | <i>Associate</i> |
| J. Zimmerman | Emerson Climate Technologies - Canada, Brantford, Ontario | <i>Associate</i> |
| A. Holbeche | CSA Group, Mississauga, Ontario | <i>Project Manager</i> |
| O. Simonetta | CSA Group, Mississauga, Ontario | <i>Project Manager</i> |

Preface

This is the eleventh edition of CSA B52, *Mechanical refrigeration code*. It supersedes the previous editions published in 2005, 1999, 1995, 1992, 1991, 1983, 1977, 1965, 1951, and 1939.

The 11th edition of this Standard provides the minimum requirements for the design, construction, installation, inspection, and maintenance of the mechanical refrigeration systems, and is complemented by the practical implementation guidance B52 Handbook, helping to minimize the risk of personal injury. The Code applies to all refrigeration systems installed, whether in new or existing premises, to systems that undergo a substitution of refrigerant, and to parts that are replaced in or added to the system.

Changes to this edition include:

- a) Clause 2 has been updated to add the following definitions:
 - i) Automated control;
 - ii) Fade-out vessel;
 - iii) Gas cooler;
 - iv) Manual control;
 - v) Pressure-regulating relief valve;
 - vi) Primary refrigerant;
 - vii) Secondary refrigerant;
 - viii) Subcritical;
 - ix) Subcritical system;
 - x) Systems;
 - xi) Supercritical;
 - xii) Thermal relief device (or thermal expansion relief device);
 - xiii) Transcritical system; and
 - xiv) Triple point;
- b) Updates to Clause 4.3.1.2.3;
- c) Updates to Clauses 5.5.1, 5.6, 5.7.1, and 5.8.1, addition of Clause 5.9.2.1(c);
- d) The addition of a note to Clause 6.3 and an update to Clause 6.3(d);
- e) Updates to Clauses 7.2.2.1, the addition of Clause 7.2.2.4;
- f) Updates to Clause 7.2.3 to include
 - i) renumbering of Clauses 7.2.3.1.1, 7.2.3.1.2, and 7.2.3.3 of the 2005 edition; and
 - ii) the addition of Clauses 7.2.3.2, 7.2.3.2.1, and 7.2.3.2.2;
- g) Updates to Clause 7.2.4,;
- h) Updates to Table 6;
- i) The addition of Clause 7.3.6.5;
- j) Updates to Clauses 8.1, 8.2, 8.3, 8.4.1, 8.4.3, and the addition of Clause 8.4.4;
- k) Updates to Annex I;
- l) The addition of Annex J;
- m) The addition of Annex K; and
- n) The addition of Annex L.

This Standard contains recommendations only and does not have the force of law until adopted officially by a jurisdiction. The regulatory authorities having jurisdiction, including those that have adopted this Standard, should be consulted on the extent of such adoption, as the Standard could have been adopted with exemptions or with additional requirements.

This Standard was prepared by the Technical Committee on Mechanical Refrigeration Code, under the jurisdiction of the Strategic Steering Committee on Mechanical Industrial Equipment Safety, and has been formally approved by the Technical Committee.

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include “Request for interpretation” in the subject line:*
 - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - b) *provide an explanation of circumstances surrounding the actual field condition; and*
 - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca.

- 5) *This Standard is subject to review five years from the date of publication, and suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line:*
 - a) *Standard designation (number);*
 - b) *relevant clause, table, and/or figure number;*
 - c) *wording of the proposed change; and*
 - d) *rationale for the change.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are published in CSA's periodical Info Update, which is available on the CSA Web site at www.csa.ca.

CSA B52-13

Mechanical refrigeration code

1 Scope

1.1 Purpose

The purpose of this Standard is to minimize the risk of personal injury by providing minimum requirements for the design, construction, installation, inspection, and maintenance of the mechanical refrigeration systems and volatile direct refrigeration systems specified in Clauses 1.2.1 and 1.2.2.

Note: This Standard does not directly address protection of property and preservation of the environment.

1.2 Application

1.2.1

Except as specified in Clause 1.2.3, this Standard applies to the design, construction, installation, inspection, and maintenance of every refrigeration system as provided for by the “Act” (as defined in Clause 3) and identified in this Standard.

1.2.2

This Standard applies to

- a) all refrigeration systems installed subsequent to its adoption. This includes refrigeration systems installed in a new or existing premises. It also applies to all premises, including the machinery room if required, in which a refrigeration system is to be installed;
- b) refrigeration systems that undergo a substitution of refrigerant in a premises defined in Item (a); and
- c) those parts of a refrigeration system that are replaced in, or added to, systems installed prior to its adoption.

Note: When adding or replacing parts (see Item (c)), consideration should be given to the premises requirements of Item (a).

1.2.3

This Standard does not apply to the following:

- a) the use of water or air as a refrigerant;
- b) bulk-storage gas tanks not permanently connected to a refrigeration system;
- c) refrigeration systems installed on railroad cars, motor vehicles, motor-drawn vehicles, aircraft, or ships; and
- d) refrigeration systems used for air conditioning in private residences.

1.3 Mandatory language

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; “should” is used to express a recommendation or that which is advised but not required; and “may” is used to express an option or that which is permissible within the limits of the standard.