

Performance of general service fluorescent lamps



Legal Notice for Standards

Canadian Standards Association (CSA) standards are developed through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. CSA does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA makes no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA is a private not-for-profit company that publishes voluntary standards and related documents. CSA has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA and the users of this document (whether it be in printed or electronic form), CSA is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA's and/or others' intellectual property and may give rise to a right in CSA and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.

CSA Standards Update Service

C819-11

January 2011

Title: *Performance of general service fluorescent lamps*

Pagination: **15 pages** (vii preliminary and 8 text), each dated **January 2011**

To register for e-mail notification about any updates to this publication

- go to **www.ShopCSA.ca**
- click on **E-mail Services** under **MY ACCOUNT**
- click on **CSA Standards Update Service**

The **List ID** that you will need to register for updates to this publication is **2421019**.

If you require assistance, please e-mail techsupport@csa.ca or call 416-747-2233.

Visit CSA's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

CSA Standard

C819-11
***Performance of general service
fluorescent lamps***



**CANADIAN STANDARDS
ASSOCIATION**

®Registered trade-mark of Canadian Standards Association

*Published in January 2011 by Canadian Standards Association
A not-for-profit private sector organization
5060 Spectrum Way, Suite 100, Mississauga, Ontario, Canada L4W 5N6
1-800-463-6727 • 416-747-4044*

Visit our Online Store at www.ShopCSA.ca



The Canadian Standards Association (CSA) prints its publications on Rolland Enviro100, which contains 100% recycled post-consumer fibre, is EcoLogo and Processed Chlorine Free certified, and was manufactured using biogas energy.

*To purchase CSA Standards and related publications, visit CSA's Online Store at **www.ShopCSA.ca** or call toll-free 1-800-463-6727 or 416-747-4044.*

ISBN 978-1-55491-532-3

© Canadian Standards Association — 2011

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

Contents

Technical Committee on Lighting *iv*

Subcommittee on Fluorescent Lamps *vi*

Preface *vii*

1 Scope 1

2 Reference publications 2

3 Definitions 3

4 General requirements 4

5 Sampling 4

5.1 Principle 4

5.2 Whole production testing 4

6 Preparation for testing 5

6.1 Seasoning 5

6.2 Lamp operation 5

7 Performance requirements 5

7.1 Wattage 5

7.2 Efficacy 5

8 Photometry and electrical testing 5

8.1 Ambient conditions 5

8.2 Power supply 5

8.3 Reference ballast 5

8.4 Test circuits and electrical instrumentation 5

8.5 Luminous flux 6

8.6 Colour-rendering index 6

9 Marking 6

Annexes

A (normative) — Uniform test method for measuring average lamp efficacy (LE), colour rendering index (CRI), and correlated colour temperature (CCT) of electric lamps 7

Tables

1 — Efficacy and CCT 6

Technical Committee on Lighting

R.F. Hughes	Hughes Engineering, North Vancouver, British Columbia	<i>Chair</i>
A. Silbiger	Andrew Silbiger Management Inc., Thornhill, Ontario	<i>Vice-Chair</i>
M.J. Barry	MJB Technologies, Caledon East, Ontario	
C. Coimbra	Osram Sylvania Ltd., Mississauga, Ontario	
M.Y. Cole	Hubbell Canada LP, Pickering, Ontario	
K.N. Delves	Natural Resources Canada, Ottawa, Ontario	<i>Associate</i>
K. Elsey	Canadian Energy Efficiency Alliance (CEEA), Mississauga, Ontario	
P. Gallant	Natural Resources Canada, Ottawa, Ontario	<i>Associate</i>
M. Gamble	SOLA Canada Lighting & Power Inc., Mississauga, Ontario	<i>Associate</i>
E. Grzesik	Ontario Ministry of Energy, Toronto, Ontario	
G.R. Hamer	BC Hydro, Burnaby, British Columbia	<i>Associate</i>
G.D. Henriques	Henriques Consulting, Richmond, British Columbia	<i>Associate</i>
J. Hodge	Toronto, Ontario	<i>Associate</i>
A. Kelly	Canadian Electricity Association (CEA), Ottawa, Ontario	<i>Associate</i>
W.H. Khella	W.H. Khella Enterprises, Mississauga, Ontario	
K. Krueger	Philips Lighting Company, A Division of Philips Electronics North America, Corp., Somerset, New Jersey, USA	<i>Associate</i>
T.K. Lau	BC Hydro, Burnaby, British Columbia	<i>Associate</i>
P. LeBlanc	Natural Resources Canada, Ottawa, Ontario	

R. Liscum	Genesis Lighting Control Ltd., Burlington, Ontario	<i>Associate</i>
J. Maddaloni	BC Ministry of Energy, Mines and Petroleum Resources, Victoria, British Columbia	<i>Associate</i>
P. Martineau	Hydro-Québec — Distribution, Montréal, Québec	
E. Mendoza	Philips Lighting Electronics, N.A., Rosemont, Illinois, USA	
S. Michaud	Thomas & Betts Fabrication Inc./ Thomas & Betts Manufacturing Inc., Dorval, Québec	<i>Associate</i>
J.P. Neu	Electro-Federation Canada, Toronto, Ontario	
M.J. Ouellette	National Research Council Canada, Ottawa, Ontario	<i>Associate</i>
D. Rittenhouse	Maple Ridge, British Columbia	
L. Rocha	Lightstudio, Burlington, Ontario	
A.W. Serres	General Electric Company, Cleveland, Ohio, USA	<i>Associate</i>
W.A. Smelser	American Electric Lighting, Rockwood, Ontario	
C. Suvagau	BC Hydro, Burnaby, British Columbia	
M.K. Timmings	Canlyte-Philips Professional Luminaires NA, Toronto, Ontario	<i>Associate</i>
K.A. Veerman	FortisBC Inc., Kelowna, British Columbia	<i>Associate</i>
T. Waterfield	Philips Lighting, A Division of Philips Electronics Ltd., Markham, Ontario	<i>Associate</i>
E. Witkowski	Manitoba Hydro, Winnipeg, Manitoba	<i>Associate</i>
H.L. Wolfman	Lumispec Consulting, Northbrook, Illinois, USA	<i>Associate</i>
J.L. Hernandez	Canadian Standards Association, Mississauga, Ontario	<i>Project Manager</i>

Subcommittee on Fluorescent Lamps

K. Krueger	Philips Lighting Company, A Division of Philips Electronics North America, Corp., Somerset, New Jersey, USA	<i>Chair</i>
Y. Andraous	Osram Sylvania Ltd., Mississauga, Ontario	
C. Coimbra	Osram Sylvania Ltd., Mississauga, Ontario	
M.E. Duffy	GE Consumer & Industrial, Cleveland, Ohio, USA	
P. Gallant	Natural Resources Canada, Ottawa, Ontario	
E. Grzesik	Ontario Ministry of Energy, Toronto, Ontario	
R.F. Hughes	Hughes Engineering, North Vancouver, British Columbia	
A. Kelly	Canadian Electricity Association (CEA), Ottawa, Ontario	
A. Laperrière	LTE Hydro Québec, Shawinigan, Québec	
P. LeBlanc	Natural Resources Canada, Ottawa, Ontario	
M.J. Ouellette	National Research Council Canada, Ottawa, Ontario	
A.L. Rosemann	BC Hydro, Burnaby, British Columbia	
A.W. Serres	General Electric Company, Cleveland, Ohio, USA	
T. Waterfield	Philips Lighting, A Division of Philips Electronics Ltd., Markham, Ontario	
J. Waymouth	Osram Sylvania Products, Inc., Danvers, Massachusetts, USA	
J.L. Hernandez	Canadian Standards Association Mississauga, Ontario	<i>Project Manager</i>

Preface

This is the second edition of CSA C819, *Performance of general service fluorescent lamps*.

The following revisions are included in this new edition:

- (a) types of lamps covered by this Standard have been clarified;
- (b) references and definitions have been updated;
- (c) CRI exemption has been increased to 87 or greater;
- (d) efficacy and CCT levels have been revised; and
- (e) a normative Annex, “Uniform test method for measuring average lamp efficacy (LE), colour rendering index (CRI), and correlated colour temperature (CCT) of electric lamps”, has been added.

CSA acknowledges that the development of this Standard was made possible, in part, by the financial support of Hydro Québec, BC Hydro, Manitoba Hydro, SaskPower, Ontario Ministry of Energy, Canadian Electricity Association, Ontario Power Authority, and Conserve Nova Scotia.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the Subcommittee on Fluorescent Lamps under the jurisdiction of the Technical Committee on Lighting and the Strategic Steering Committee on Performance, Energy Efficiency, and Renewables, and has been formally approved by the Technical Committee.

January 2011

Notes:

- (1) Use of the singular does not exclude the plural (and vice versa) when the sense allows.
- (2) Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.
- (3) This publication was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this publication.
- (4) To submit a request for interpretation of CSA Standards, please send the following information to inquiries@csa.ca and include “Request for interpretation” in the subject line:
 - (a) define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;
 - (b) provide an explanation of circumstances surrounding the actual field condition; and
 - (c) where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are published in CSA’s periodical Info Update, which is available on the CSA website at <http://standardsactivities.csa.ca>.
- (5) CSA Standards are subject to periodic review, and suggestions for their improvement will be referred to the appropriate committee. To submit a proposal for change to CSA Standards, please send the following information to inquiries@csa.ca and include “Proposal for change” in the subject line:
 - (a) Standard designation (number);
 - (b) relevant clause, table, and/or figure number;
 - (c) wording of the proposed change; and
 - (d) rationale for the change.

C819-11

Performance of general service fluorescent lamps

1 Scope

1.1

This Standard specifies performance requirements and related test procedures used to evaluate fluorescent lamps intended for general service applications.

1.2

This Standard includes performance requirements for lamp efficacy.

1.3

This Standard applies to

- (a) any straight-shaped lamp, commonly referred to as 4-foot medium bipin lamps, with a medium bipin base of 1200 mm (48 in) nominal overall length and a rated wattage of 25 W or more;
- (b) any U-shaped lamps, commonly referred to as 2-foot U-shape lamps, with a medium bipin base between 560 mm and 635 mm (22 and 25 in) nominal overall length and a rated wattage of 25 W or more;
- (c) any rapid-start lamps, commonly referred to as 8-foot high-output lamps, with a recessed double-contact base of 2400 mm (96 in) nominal overall length;
- (d) any instant-start lamp, commonly referred to as 8-foot slimline lamps, with a single-pin base of 2400 mm (96 in) nominal overall length and a rated wattage of 52 W or more;
- (e) any straight-shaped lamp, commonly referred to as 4-foot miniature bipin standard output lamps, with a miniature bipin base between 1143 mm and 1200 mm (45 and 48 in) nominal overall length and a rated wattage of 26 W or more; and
- (f) any straight-shaped lamp, commonly referred to as 4-foot miniature bipin high output lamps, with a miniature bipin base between 1143 mm and 1200 mm (45 and 48 in) nominal overall length and a rated wattage of 49 W or more.

1.4

This Standard does not apply to the following:

- (a) fluorescent lamps designed to promote plant growth;
- (b) fluorescent lamps specifically designed for cold temperature applications;
- (c) coloured fluorescent lamps;
- (d) fluorescent lamps designed to be impact-resistant;
- (e) reflector or aperture lamps;
- (f) fluorescent lamps designed for use in reprographic equipment;
- (g) fluorescent lamps designed to produce radiation primarily in the ultraviolet region of the spectrum; and
- (h) lamps with a CRI of 87 or greater.