


Aging management requirements for nuclear power plants



Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

N290.20:21

March 2021

Title: *Aging management requirements for nuclear power plants*

To register for e-mail notification about any updates to this publication

- go to www.csagroup.org/store/
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **2428199**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

N290.20:21

***Aging management requirements
for nuclear power plants***



®A trademark of the Canadian Standards Association, operating as "CSA Group"

*Published in March 2021 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at www.csagroup.org/store/
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ICS 27.120
ISBN 978-1-4883-2995-1*

*© 2021 Canadian Standards Association
All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.*

Contents

Technical Committee on Reactor Control Systems, Safety Systems, and Instrumentation for Nuclear Power Plants 3

Subcommittee on Aging Management Requirements for Nuclear Power Plants 6

Preface 8

1 Scope 9

2 Reference publications 10

3 Definitions and abbreviations 12

3.1 Definitions 12

3.2 Abbreviations 16

4 Systematic approach to aging management 17

4.1 AM program 17

4.1.1 General 17

4.1.2 AM program requirements 18

4.1.3 Systematic approach to aging management 20

4.2 Scoping, screening, and selection of SSCs 22

4.2.1 General 22

4.2.2 Scoping 22

4.2.3 Screening 25

4.2.4 Selection 27

4.2.5 Data and records 28

4.3 SSC assessment and aging review 28

4.3.1 Assessment of a SSC's aging 28

4.3.2 Assessment of degradation mechanisms and obsolescence 29

4.3.3 Assessment of preventive actions 29

4.3.4 Limits to acceptable degradation 29

4.3.5 Operational factors 29

4.3.6 Review of applicable operating history and experience 29

4.3.7 Review of information sources 30

4.3.8 Evaluation of physical condition of SSCs 30

4.3.9 SSC condition classification 30

4.4 AM plans 31

4.4.1 General 31

4.4.2 Addressing attributes 31

4.4.3 Other NPP programs 31

4.5 Periodic reviews and improvements 31

4.5.1 General 31

4.5.2 AM program 32

4.5.3 AM plans 32

4.6 Program and plans improvement and action resolution 33

4.6.1 Process 33

4.6.2 Performance indicators 33

4.7	Obsolescence management	33
4.7.1	General	33
4.7.2	Obsolescence management	34
5	Aging management during the life cycle of a NPP	34
5.1	General	34
5.1.1	Proactive strategy for aging management	34
5.1.2	Transition between life cycle phases	34
5.1.3	Safety analysis	35
5.1.4	Review and update of safety analysis	35
5.2	Design phase	36
5.2.1	General	36
5.2.2	Aging management elements	37
5.3	Construction phase	38
5.3.1	General	38
5.3.2	Construction	38
5.3.3	Delayed construction	38
5.3.4	Data collection and records	39
5.4	Commissioning phase	39
5.4.1	General	39
5.4.2	Aging management activities	39
5.4.3	Data collection and records	39
5.5	Operation phase	40
5.5.1	General	40
5.5.2	Long-term operation	40
5.5.3	Extended shutdown	41
5.6	Decommissioning phase	42
6	Documentation and records	42
6.1	General	42
6.1.1	Documentation and records management	42
6.1.2	Stakeholder input	43
6.2	Records supporting AM attributes	43
6.3	Records of AM plan actions	44
<hr/>		
Annex A (informative)	— Sample methodology for aging evaluation	45
Annex B (normative)	— Generic attributes of an effective AM program	47
Annex C (informative)	— Sample SSC condition classification	49
Annex D (informative)	— Examples of good practices for management of obsolescence	50
Annex E (informative)	— Criteria for scoping, screening, and selection of SSCs specific to the transition to decommissioning life cycle phase	51
Annex F (informative)	— Examples of support program inputs and outputs associated with the AM program	54
Annex G (informative)	— Aging management activities and typical inputs and outputs at all life cycle phases of the NPP	57
Annex H (informative)	— Guidance for use of a graded approach to aging management	62
Annex I (informative)	— Bibliography	64

Preface

This is the first edition of CSA N290.20, *Aging management requirements for nuclear power plants*.

The CSA N-Series Standards provide an interlinked set of requirements for the management of nuclear facilities and activities. CSA N286 provides overall direction to management to develop and implement sound management practices and controls, while the other CSA Group Nuclear Standards provide technical requirements and guidance that support the management system. This Standard works in harmony with CSA N286 and does not duplicate the generic requirements of CSA N286; however, it might provide more specific direction for those requirements.

This Standard reflects the operating experience of the Canadian nuclear power industry.

Users of this Standard are reminded that the design, manufacture, construction, commissioning, operation, and decommissioning of nuclear facilities in Canada are subject to the provisions of the *Nuclear Safety and Control Act* and its supporting Regulations.

This Standard was prepared by the Subcommittee on Aging Management Requirements for Nuclear Power Plants, under the jurisdiction of the Technical Committee on Reactor Control Systems, Safety Systems, and Instrumentation for Nuclear Power Plants and the Strategic Steering Committee on Nuclear Standards, and has been formally approved by the Technical Committee.

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include “Request for interpretation” in the subject line:*
 - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - b) *provide an explanation of circumstances surrounding the actual field condition; and*
 - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca.

- 5) *This Standard is subject to review within five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line:*
 - a) *Standard designation (number);*
 - b) *relevant clause, table, and/or figure number;*
 - c) *wording of the proposed change; and*
 - d) *rationale for the change.*

N290.20:21

Aging management requirements for nuclear power plants

1 Scope

1.1

This Standard specifies requirements and guidance for the aging management of nuclear power plants (NPPs). Specifically, this Standard addresses the aging management of

- a) structures, systems, and components (SSCs) that are important to safety; and
- b) SSCs that, in the case of failure, would prevent SSCs important to safety from performing their safety function.

Note: *Other nuclear facilities may apply this Standard using a graded approach commensurate with risk.*

1.2

This Standard addresses the integration of NPP programs to support aging management.

1.3

This Standard applies to the following life cycle phases of the NPP:

- a) design;
- b) construction (including procurement, fabrication and installation, delayed construction, storage, and transportation activities);
- c) commissioning;
- d) operation (including long-term operation and extended shutdown, if applicable); and
- e) decommissioning.

1.4

This Standard addresses two aspects of aging management of SSCs: physical aging and non-physical aging (obsolescence).

1.5

This Standard excludes management of obsolescence that is due to non-equipment-related drivers.

Note: *For example, changes to current regulations, codes and standards, or loss of staff knowledge due to workforce changes.*

1.6

This Standard does not address the broader topic of asset management.

Note: *Although asset management is not addressed in this Standard, the concepts and guidance may be adapted and used for establishing strategies to optimize the management of facility assets.*

1.7

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the Standard; “should” is used to express a recommendation or that