



Shielded power cable for commercial and industrial applications, 5–46 kV



Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

CSA C68.10:20 February 2020

Title: *Shielded power cable for commercial and industrial applications, 5–46 kV*

To register for e-mail notification about any updates to this publication

- go to store.csagroup.org
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **2427099**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

Canadian Standards Association (operating as “CSA Group”), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Group’s standards development by volunteering their time and skills to Committee work and supporting CSA Group’s objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Group’s total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Group’s standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects products that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard
Toronto, Ontario, M9W 1R3
Canada



A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at www.scc.ca.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Standards Council of Canada
600-55 Metcalfe Street
Ottawa, Ontario, K1P 6L5
Canada



Standards Council of Canada
Conseil canadien des normes

Cette Norme Nationale du Canada n'est disponible qu'en anglais.

Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users to judge its suitability for their particular purpose.

®A trademark of the Canadian Standards Association, operating as “CSA Group”

National Standard of Canada

CSA C68.10:20
Shielded power cable for
commercial and industrial
applications, 5–46 kV



*®A trademark of the Canadian Standards Association,
operating as “CSA Group”*



*Published in February 2020 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at store.csagroup.org
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ICS 29.060.20
ISBN 978-1-4883-2135-1*

*© 2020 Canadian Standards Association
All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.*

Contents

Technical Committee on Insulated Power Cable	6
Subcommittee on Shielded and Concentric Neutral Power Cables Rated 5–46 kV	8
Preface	10
1 Scope	12
2 Reference publications	13
3 Definitions and abbreviations	16
3.1 Definitions	16
3.2 Abbreviations	20
4 Conductors	20
4.1 General	20
4.2 Physical and electrical properties	20
4.2.1 General	20
4.2.2 Copper conductors	21
4.2.3 Aluminum conductors	21
4.3 Optional water-blocking component for stranded conductors	21
4.4 Conductor size	21
4.5 Conductor dc resistance per unit length	21
4.6 Conductor diameter	22
5 Conductor shield (stress control layer)	22
5.1 Material	22
5.2 Extruded shield thickness	22
5.2.1 General	22
5.2.2 Reduced extruded shield thickness	22
5.3 Protrusions and convolutions	22
5.4 Voids	23
5.5 Physical requirements	23
5.6 Electrical requirements	23
5.6.1 Extruded semiconducting material	23
5.6.2 Extruded nonconducting material (for EPR insulation only)	23
5.6.3 Semiconducting tape	23
5.7 Crosslinked (thermoset) requirements	23
6 Insulation	24
6.1 Material	24
6.2 Insulation thickness	24
6.2.1 General	24
6.2.2 Selection of insulation thickness	24
6.3 Physical and aging requirements	24
6.4 Electrical requirements	25
6.4.1 Partial-discharge extinction level (for discharge-free designs only)	25

6.4.2	Discharge (corona) resistance (for discharge-resistant designs only)	25
6.4.3	Voltage test	25
6.4.4	Dielectric constant and dissipation factor	25
6.5	Ambers, agglomerates, gels, contaminants, and voids	25
6.5.1	XLPE and TRXLPE insulation	25
6.5.2	EPR insulation	25
6.6	Shrinkback (XLPE and TRXLPE)	25
7	Extruded insulation shields and coverings	26
7.1	Material	26
7.1.1	General	26
7.1.2	Discharge-free cables	26
7.1.3	Discharge-resistant cables	26
7.2	Thickness	26
7.3	Protrusions	26
7.4	Voids	26
7.5	Removability	26
7.5.1	Discharge-free designs	26
7.5.2	Discharge-resistant designs	27
7.6	Physical requirements	27
7.7	Electrical requirements	27
7.8	Crosslinked (thermoset) requirements	27
7.9	Semiconducting tape	27
8	Metallic shielding	27
8.1	General	27
8.2	Metal tape	28
8.2.1	General	28
8.2.2	Helically applied tape	28
8.2.3	Longitudinally applied corrugated tape shield	28
8.3	Wire shield	28
8.4	Braid shield	29
8.4.1	General	29
8.4.2	Metallic braid shield	29
8.4.3	Combination braid shield	29
8.5	Combination of tape and wire	30
8.6	Lead sheath	30
8.7	Multiple-conductor cables	30
8.8	Optional water blocking components for metallic shield	30
9	Jackets and metallic and associated coverings	30
9.1	Jackets	30
9.1.1	General	30
9.1.2	Thermoset jacket materials	30
9.1.3	Thermoplastic jacket materials	31
9.1.4	Limited-smoke halogen-free jackets	31
9.1.5	Repairs	31
9.1.6	Test for suitability for exposure to sunlight	31
9.1.7	Flame test on finished cable	31

- 9.1.8 Separator under jacket 31
- 9.1.9 Jacket thickness 31
- 9.1.10 Spark test on jackets 31
- 9.2 Metallic and associated coverings 32
 - 9.2.1 General 32
 - 9.2.2 Bedding over cable cores with metallic sheath or armour 32
 - 9.2.3 Cables with metallic coverings — Typical applications 32
 - 9.2.4 Metallic sheath 33
 - 9.2.5 Metallic armours 34
 - 9.2.6 Jackets over metallic sheath and armour 36
 - 9.2.7 Outer servings 36

10 Construction of specific cable types 37

- 10.1 General 37
- 10.2 Shaft, vertical riser, and borehole cable 37
 - 10.2.1 Construction 37
 - 10.2.2 Safety factors 37
 - 10.2.3 Armour and sheath 38
- 10.3 Submarine cable 39
 - 10.3.1 Armour 39
 - 10.3.2 Interlocked steel tape armour 39
 - 10.3.3 Steel wire armour 39
 - 10.3.4 Copper wire armoured submarine cable 39
- 10.4 Armoured buried land cable 40
 - 10.4.1 Armour 40
 - 10.4.2 Interlocked metal tape armour 40
 - 10.4.3 Steel wire armour 40
- 10.5 Dredge cable 40
 - 10.5.1 Armour 40
 - 10.5.2 Pitch ratio 40
- 10.6 Pre-assembled aerial cable 41

11 Cable assembly and fillers 41

- 11.1 Assembly of multiple-conductor cables 41
 - 11.1.1 General 41
 - 11.1.2 Length of lay 41
 - 11.1.3 Common covering 41
 - 11.1.4 No common covering 41
- 11.2 Fillers 41
- 11.3 Bonding conductors 42
 - 11.3.1 General 42
 - 11.3.2 Single-conductor cable 42
 - 11.3.3 Multiple-conductor cable 42
- 11.4 Conductor identification 42

12 Cable identification 42

- 12.1 Jacketed cable 42
- 12.2 Cable reels 43

13	Production tests	43
13.1	Testing	43
13.2	Sampling frequency	43
13.3	Conductor test methods	43
13.3.1	Determination of dc resistance	43
13.3.2	Determination of diameter	44
13.4	Test samples and specimens for physical and aging tests	44
13.4.1	General	44
13.4.2	Measurement of thickness	44
13.4.3	Number of test specimens	44
13.4.4	Size of specimens	44
13.4.5	Preparation of insulation and jacket specimens	45
13.4.6	Specimens for aging tests	45
13.4.7	Calculation of test specimen area	45
13.4.8	Test procedures for unaged samples	46
13.4.9	Test procedures for aged samples	46
13.4.10	Hot creep test	47
13.4.11	Wafer boil test for conductor and insulation shields	47
13.4.12	Amber, agglomerate, gel, contaminant, protrusion, convolution, void, and insulation shield indentation test	47
13.4.13	Internal irregularity test procedure for TRXLPE insulation	48
13.4.14	Physical tests for semiconducting material intended for extrusion	49
13.4.15	Retests for physical and aging properties and thickness	49
13.4.16	Retest for thickness	49
13.5	Dimensional measurements of the metallic shield	49
13.5.1	Tape shield	49
13.5.2	Wire shield	50
13.5.3	Lead sheath	50
13.6	Jacket deformation test	50
13.7	Volume resistivity	50
13.7.1	General	50
13.7.2	Two-electrode method	50
13.7.3	Four-electrode method	51
13.7.4	Test equipment	51
13.7.5	Measurement	51
13.7.6	Extruded semiconducting coverings radial resistivity test	51
13.8	Adhesion (insulation shield removability) test	52
13.9	Shrinkback test	52
13.9.1	Sample preparation	52
13.9.2	Test procedure	53
13.9.3	Acceptance criteria and procedure	53
13.10	Sample retests	53
13.11	AC voltage test	54
13.11.1	General	54
13.11.2	Test procedure	54
13.12	Partial-discharge test procedure	54
13.13	Method for determining dielectric constant and dielectric strength of extruded nonconducting polymeric stress control layers	54
13.14	Other tests	54

13.14.1	Water content	54
13.14.2	Longitudinal water penetration test — Optional sealant for stranded conductors	55
13.14.3	Longitudinal water penetration test — Optional water blocking components for metallic shield	55
13.14.4	Spark test on jackets, coverings, and nonconducting shield	55
13.14.5	Tightness of polyethylene jacket to sheath test	56
14	Qualification tests	56
14.1	General	56
14.2	Core qualification tests	56
14.2.1	Accelerated water absorption test — Electrical method at 60 Hz	56
14.2.2	Insulation resistance test	56
14.2.3	Dry electrical test for 105 °C insulations	57
14.2.4	Test for discharge-resistant EPR insulation	58
14.2.5	Dissipation factor characterization test	58
14.3	Extruded shield qualification	58
14.3.1	Dielectric constant and voltage withstand for nonconducting stress control layers	58
14.3.2	Resistance stability	59
14.3.3	Brittleness temperature for semiconducting shields	59
14.3.4	Physical tests for semiconducting material intended for extrusion	59
14.4	Qualification tests for jacket material	59
14.4.1	General	59
14.4.2	Deformation test	59
14.4.3	Weather resistance of jacket and striping material	60
14.4.4	Environmental stress-cracking test of jackets — Polyethylene and polypropylene jackets	60
14.4.5	Heat shock — Polyvinyl chloride and TPE jackets	60
14.5	Tests on finished cable	61
14.5.1	Cold impact test on finished cable	61
14.5.2	Cold bend test on finished cable	61
14.5.3	Flexibility	61
14.6	Other qualification tests	62
14.6.1	CV extrusion qualification test	62
14.6.2	Longitudinal water penetration — Optional water-blocking components for stranded conductors	63
14.6.3	Compatibility of optional water-blocking components	63
14.6.4	Flame test on finished cable (optional)	63
14.6.5	Material combustion (halogen-free cables only)	63

Annex A (informative)	— Operating limits	109
Annex B (informative)	— Information to be supplied by purchaser	110
Annex C (informative)	— Shielding	112
Annex D (informative)	— Handling, installation, and testing parameters	115
Annex E (informative)	— Ethylene alkene copolymer (EAM)	122
Annex F (normative)	— Procedure for determining dimensional requirements of jackets and associated coverings	123

Technical Committee on Insulated Power Cable

E. H. Wiebe	Innovative Solutions Engineering Inc., Winnipeg, Manitoba, Canada <i>Category: General Interest</i>	<i>Chair</i>
S. K. Alibhay	Hydro-Québec, Montréal, Québec, Canada <i>Category: User Interest</i>	
M. D. Bell	Hydro One Networks Inc., Toronto, Ontario, Canada <i>Category: User Interest</i>	
E. Cometa	CSA Group, Toronto, Ontario, Canada <i>Category: General Interest</i>	
J. Conrad	RSCC Wire & Cable LLC, East Granby, Connecticut, USA <i>Category: Producer Interest</i>	
W. A. Crawford	The Okonite Company, Ramsey, New Jersey, USA <i>Category: Producer Interest</i>	
K. C. Hamilton	Manitoba Hydro, Winnipeg, Manitoba, Canada <i>Category: User Interest</i>	
M. Hartley	Toronto, Ontario, Canada	<i>Non-voting</i>
A. S. Jones	Toronto, Ontario, Canada	<i>Non-voting</i>
C. Mateo	FortisAlberta Inc., St. Albert, Alberta, Canada <i>Category: User Interest</i>	
J. A. McFadgen	Nova Scotia Power Inc., Halifax, Nova Scotia, Canada <i>Category: User Interest</i>	

M. Moradi	Prysmian Power Cables and Systems Canada, Richmond Hill, Ontario, Canada <i>Category: Producer Interest</i>	
K. M. Nuckles	Southwire Company, Carrollton, Georgia, USA <i>Category: Producer Interest</i>	
D. S. Parikh	Hydro One Networks Inc., Toronto, Ontario, Canada <i>Category: User Interest</i>	
S. Sahota	Prysmian Power Cables and Systems Canada Ltd., Johnstown, Ontario, Canada	<i>Non-voting</i>
W. S. Temple	General Cable Industries, Inc., Highland Heights, Kentucky, USA <i>Category: Producer Interest</i>	
S. Attarde	CSA Group, Toronto, Ontario, Canada	<i>Project Manager</i>

Subcommittee on Shielded and Concentric Neutral Power Cables Rated 5–46 kV

L. J. Hiivala	Toronto, Ontario, Canada	<i>Chair</i>
S. K. Alibhay	Hydro-Québec, Montréal, Québec, Canada	
E. Cometa	CSA Group, Toronto, Ontario, Canada	
W. F. Constantine	Draka Cableteq USA, North Dighton, Massachusetts, USA	
W. A. Crawford	The Okonite Company, Ramsey, New Jersey, USA	
M. Côté	Hydro-Québec, Distribution, Montréal, Québec, Canada	
D. Drysdale	Nexans Canada Inc., Fergus, Ontario, Canada	
A. Filion	Marmon Utility LLC, Milford, New Hampshire, USA	
K. C. Hamilton	Manitoba Hydro, Winnipeg, Manitoba, Canada	
D. Harris	Northern Cables Inc., Brockville, Ontario, Canada	
M. Hartley	Toronto, Ontario, Canada	
G. Jones	The Okonite Company, Ramsey, New Jersey, USA	
E. Majdi	Toronto Hydro, Toronto, Ontario, Canada	

J. A. McFadgen	Nova Scotia Power Inc., Halifax, Nova Scotia, Canada	
M. Moradi	Prysmian Power Cables and Systems Canada, Richmond Hill, Ontario, Canada	
N. Moubed	Anixter Canada Inc., Mississauga, Ontario, Canada	
K. M. Nuckles	Southwire Company, Carrollton, Georgia, USA	
D. S. Parikh	Hydro One Networks Inc., Toronto, Ontario, Canada	
S. Sahota	Prysmian Power Cables and Systems Canada Ltd., Johnstown, Ontario, Canada	
A. Schimmoeller	Southwire, Brecksville, Ohio, USA	
G. Simion	Anixter Canada Inc., Mississauga, Ontario, Canada	
W. S. Temple	General Cable Industries, Inc., Highland Heights, Kentucky, USA	
S. Wetzel	Southwire Company, Cambridge, Wisconsin, USA	
E. H. Wiebe	Innovative Solutions Engineering Inc., Winnipeg, Manitoba, Canada	
C. Chan	CSA Group, Toronto, Ontario, Canada	<i>Project Manager</i>

Preface

This is the third edition of CSA C68.10, *Shielded power cable for commercial and industrial applications, 5–46 kV*. It supersedes the previous editions published in 2014 and 2008.

The first edition of this Standard replaced the requirements for shielded power cable in commercial and industrial installations specified in CAN/CSA-C68.3, *Shielded and concentric neutral power cables rated 5–46 kV*. A related standard in the CSA C68 series, CSA C68.5, specifies the requirements for application of shielded and concentric neutral cables used by electric utilities.

This Standard was originally adapted from NEMA WC 74/ICEA S-93-639. CSA Group gratefully acknowledges the co-operation of the Insulated Cable Engineers Association (ICEA) and the contribution of its members.

The main revisions incorporated in this edition include the following:

- a) updated reference publications (Clause [2](#));
- b) removed “filled or unfilled” from the XLPE and TRXLPE descriptions (Clause [6.1.1](#));
- c) clarified on the four classifications of EPR (Clause [6.1.1](#));
- d) deleted reference to test methods in CSA C22.2 No. 0.3 and replaced with CSA C22.2 No. 2556;
- e) added additional marking requirements for jacketed cables (Clause [12.1](#)); and
- f) removed “Class III” classification for 105C rated XLPE and TRXLPE and clarified temperature ratings for EPR classes I, II, III and IV (Tables [4](#) and [10](#)).

Funding in support of the consensus process of this Standard was provided by the following funders, whose assistance is acknowledged with thanks: Canadian Electricity Association (CEA), S&C Electric Canada Ltd., Fortis BC, Fortis Alberta, Maritime Electric, Newfoundland Hydro, Newfoundland Power, Schneider Electric Canada Inc., and IFD Corporation.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the Subcommittee on Shielded and Concentric Neutral Power Cables Rated 5–46 kV, under the jurisdiction of the Technical Committee on Insulated Power Cable and the Strategic Steering Committee on Power Engineering and Electromagnetic Compatibility, and has been formally approved by the Technical Committee.

This standard has been developed in compliance with Standards Council of Canada requirements for National Standards of Canada. It has been published as a National Standard of Canada by CSA Group.

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include “Request for interpretation” in the subject line:*
 - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - b) *provide an explanation of circumstances surrounding the actual field condition; and*

- c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca.

- 5) *This Standard is subject to review within five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line:*
 - a) *Standard designation (number);*
 - b) *relevant clause, table, and/or figure number;*
 - c) *wording of the proposed change; and*
 - d) *rationale for the change.*

CSA C68.10:20

Shielded power cable for commercial and industrial applications, 5–46 kV

1 Scope

1.1

This Standard applies to the materials, construction, and testing of one- to four-conductor cross-linked polyethylene and ethylene propylene rubber-insulated shielded power cables, rated 5–46 kV, that are used for the distribution of electrical energy under normal conditions of installation and service in indoor, outdoor, aerial, underground, or underwater locations.

1.2

This Standard specifies requirements for conductors, insulation, and protective coverings as well as for the construction and dimensions of most standard types of shielded cable.

1.3

This Standard does not preclude the use of optional components such as polymeric layers for additional mechanical protection, moisture-impervious laminated sheath, individually covered steel wire armour, or optical fibres, provided that the components meet the performance requirements of this Standard.

Test procedures for these optional components are not included in this Standard.

1.4

The values given in SI units are the units of record for the purposes of this Standard. Where values are given in parentheses they are for information and comparison only.

1.5

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; “should” is used to express a recommendation or that which is advised but not required; and “may” is used to express an option or that which is permissible within the limits of the standard.

Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material.

Notes to tables and figures are considered part of the table or figure and may be written as requirements.

Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.