



Control of hazardous energy — Lockout and other methods



Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

CSA Z460:20 February 2020

Title: *Control of hazardous energy — Lockout and other methods*

To register for e-mail notification about any updates to this publication

- go to store.csagroup.org
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **2427899**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

Canadian Standards Association (operating as “CSA Group”), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Group’s standards development by volunteering their time and skills to Committee work and supporting CSA Group’s objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Group’s total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Group’s standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects products that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard
Toronto, Ontario, M9W 1R3
Canada



Standards Council of Canada
Conseil canadien des normes

A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at www.scc.ca.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Standards Council of Canada
600-55 Metcalfe Street
Ottawa, Ontario, K1P 6L5
Canada

Cette Norme Nationale du Canada est disponible en versions française et anglaise.

Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users to judge its suitability for their particular purpose.

®A trademark of the Canadian Standards Association, operating as “CSA Group”

National Standard of Canada

CSA Z460:20
**Control of hazardous
energy — Lockout and other
methods**



*®A trademark of the Canadian Standards Association,
operating as “CSA Group”*



*Published in February 2020 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at store.csagroup.org
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ICS 43.040.30
ISBN 978-1-4883-2772-8*

*© 2020 Canadian Standards Association
All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.*

Contents

Technical Committee on Hazardous Energy Control	3
Preface	8
0 Introduction	10
1 Scope	11
1.1 Scope	11
1.2 Purpose	11
1.3 Application	11
1.4 Exclusions	11
1.5 Terminology	11
2 Reference publications	12
3 Definitions	14
4 Responsibilities	16
4.1 Manufacturers, integrators, modifiers, and remanufacturers	16
4.2 Users	16
4.3 Authorized individuals	16
5 Design of machines, equipment, and processes	16
5.1 Manufacturer, integrator, modifier, and remanufacturer responsibilities	16
5.1.1 General	16
5.1.2 Exposure minimization	17
5.1.3 Partial energization	17
5.2 Energy-isolating devices	17
5.2.1 General	17
5.2.2 Capability	17
5.2.3 Location	17
5.2.4 Identification	18
5.2.5 Suitability	18
5.3 Special tools or devices	18
5.4 Warnings and special instructions	18
5.5 Component isolation	18
5.6 Documentation	19
5.7 Stored and residual energy	19
5.8 Control integration	19
5.9 Physical safeguards	19
6 Task and hazard identification	20
6.1 General	20
6.2 Task identification	20
6.3 Hazard identification	21
6.4 Documentation	21
7 Hazardous energy control program	21

7.1	User responsibilities	21
7.2	Methods of control	22
7.3	Lockout program	24
7.4	Other hazardous energy control methods	33
7.5	Communication and training	41
7.6	Program review	43

Annex A (informative)	— Examples of hazards, hazardous situations, and hazardous events	45
Annex B (informative)	— Risk assessment and risk reduction procedure	52
Annex C (informative)	— Examples of hazard identification and risk assessment methodologies	57
Annex D (informative)	— Sample lockout policy and program, sample general lockout procedure (individual lockout), and sample approved energy control procedure	79
Annex E (informative)	— Sample lockout placards, flowsheets, and nomenclature standards	91
Annex F (informative)	— Sample group lockout procedure	108
Annex G (informative)	— Complex group lockout (permit systems)	121
Annex H (informative)	— Sample lockout device and information tag removal report and sample warning notice	125
Annex I (informative)	— Guidance for construction sites	127
Annex J (informative)	— Remote low-voltage lockable systems	129
Annex K (informative)	— Other control methods involving trapped key interlock systems	131
Annex L (informative)	— Special method for freeze plug applications	134
Annex M (informative)	— Example applications for mobile equipment and machinery	135
Annex N (informative)	— Other control method for alternative energy systems	142
Annex O (informative)	— Other control method for the printing industry	148
Annex P (informative)	— Other control method for the plastics industry	149
Annex Q (informative)	— Other control method for robotic applications	151
Annex R (informative)	— Other control method for work on pressurized pipelines (hot-tapping)	152
Annex S (informative)	— Examples of tasks appropriate for other control methods	153
Annex T (informative)	— Human performance and hazardous energy control	161
Annex U (informative)	— Bibliography	173

Preface

This is the third edition of CSA Z460, *Control of hazardous energy — Lockout and other methods*. It supersedes the previous editions published in 2013 and 2005.

This Standard provides for flexibility in hazardous energy control methodology decisions as part of an occupational health and safety management system (see CSA Z1000). Other methods are based on risk assessment and application of the classic hazard control hierarchy (see Clause [7.4.4](#)). However, lockout is emphasized as the primary approach to hazardous energy control.

In the creation of this third edition, the following specified changes have been incorporated:

- a) clarification of requirement for viewing ports and reference to guidance on nomenclature in Clause [5.2.4](#);
- b) clarification of what is considered to be a remote location and changes to control requirements for remote locations in Clause [7.3.9](#);
- c) substantive changes to Clause [7.4](#) (other control methods) for purposes of clarity;
- d) expansion of Annex [C](#) updating examples on application of risk assessment;
- e) addition of guidance on nomenclature in Annex [E](#);
- f) realigned and expanded Annexes [D](#), [E](#), [F](#), [G](#), and [H](#) as follows:
 - i) D1 — Policy;
 - ii) D2 — Individual lock-out procedure;
 - iii) D3 — Individual lock-out flowchart;
 - iv) D4 — Sample approved energy control procedure;
 - v) E1 — Nomenclature standards;
 - vi) E2 — Placard examples;
 - vii) F1 — Group lockout procedures;
 - viii) F2 — Group lockout flowchart;
 - ix) F3 — Standard group lockout station — Picture;
 - x) F4 — Pictorial representation of a group lockout;
 - xi) F5 — Security pyramid example;
 - xii) F6 — Group lockout with use of satellite lockbox;
 - xiii) F7 — Flowchart for group lockout with use of satellite lockbox;
 - xiv) F8 — Complex group lockout; and
 - xv) F9 — Lock removal procedures;
- g) addition of Annex [I](#) — application to construction sites;
- h) expansion of Annex [M](#) on mobile equipment;
- i) addition of Annex [S](#) — example of decision-making process for other control methods; and
- j) addition of Annex [T](#) — consideration of human performance factors.

By permission of International Organization for Standardization (ISO) TC 199, Annexes [A](#) and [B](#) are based in part on ISO 12100:2010, *Safety machinery — General principles for design — Risk assessment and risk reduction*.

CSA Group acknowledges that the development of this Standard was made possible, in part, by the financial support of the Canadian Association of Administrators of Labour Law — Occupational Safety and Health (CAALL-OSH), including Provincial and Territorial Governments, as well as the Government of Canada. CSA Group is solely responsible for the content of this Standard, and CSA Group and the funding bodies disclaim any liability in connection with the use of the information contained herein.

This Standard was prepared by the Technical Committee on Hazardous Energy Control, under the jurisdiction of the Strategic Steering Committee on Occupational Health and Safety, and has been formally approved by the Technical Committee.

This Standard has been developed in compliance with Standards Council of Canada requirements for National Standards of Canada. It has been published as a National Standard of Canada by CSA Group.

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include “Request for interpretation” in the subject line:*
 - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - b) *provide an explanation of circumstances surrounding the actual field condition; and*
 - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca.
- 5) *This Standard is subject to review within five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line:*
 - a) *Standard designation (number);*
 - b) *relevant clause, table, and/or figure number;*
 - c) *wording of the proposed change; and*
 - d) *rationale for the change.*


CSA Z460:20

Control of hazardous energy — Lockout and other methods

0 Introduction

This Standard assigns responsibilities for hazardous energy control of machines, equipment, and processes to manufacturers, integrators, installers, and users. It is best read in its entirety for full comprehension of its requirements. Figure 1 provides a graphic representation of the organization of this Standard.

Figure 1
Organization of this Standard
(See Clause 0.)



1 Scope

1.1 Scope

This Standard specifies requirements for controlling hazardous energy associated with potentially harmful machines, equipment, and processes (including mobile machinery and equipment; see Annex [M](#)). Where a CSA Standard or other recognized Standard exists for a specific type of machinery, equipment, or process, it should be used with this Standard to provide the most effective protection.

1.2 Purpose

The purpose of this Standard is to specify requirements and performance objectives for procedures, techniques, designs, and methods to protect personnel from injury from the inadvertent release of hazardous energy. Release of hazardous energy can include any motion, energization, start-up, or release of stored energy that, from the perspective of the person(s) at risk, is either unintended or deliberate.

Lockout is recognized as the primary method of hazardous energy control. When the tasks specified in Clause [1.3](#) are integral to the production process (see Clause [7.4.2](#)), or full lockout prohibits completion of those tasks, other methods of control that provide effective personal protection are used. These other methods are based on risk assessment (see Clause [7.4.3](#)).

1.3 Application

This Standard applies to, but is not limited to, activities such as erecting, installing, constructing, repairing, adjusting, inspecting, unjamming, setting up, troubleshooting, testing, cleaning, dismantling, servicing, and maintaining machines, equipment, or processes.

Safeguarding of machines and the control of energy supply systems during normal production activities are addressed in CSA Z432, Z434, Z462, and Z767, and other machine- and system-specific standards.

Special considerations for work in confined spaces and under extreme conditions are addressed in CSA Z1006 and Z1010.

1.4 Exclusions

This Standard does not specify safety procedures for manually-operated machines or equipment where the only source of energy is the individual operator.

1.5 Terminology

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the Standard; “should” is used to express a recommendation or that which is advised but not required; “may” is used to express an option or that which is permissible within the limits of the Standard.

Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material.

Notes to tables and figures are considered part of the table or figure and may be written as requirements.

Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.