



CSA C900.6:21
(EN 1434-6:2015+A1:2019, MOD)
National Standard of Canada



CSA C900.6:21
**Thermal energy meters — Part 6: Installation,
commissioning, operational monitoring and
maintenance**
(EN 1434-6:2015+A1:2019, MOD)



Standards Council of Canada
Conseil canadien des normes

Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

CSA C900.6:21

April 2021

Title: *Thermal energy meters — Part 6: Installation, commissioning, operational monitoring and maintenance*

To register for e-mail notification about any updates to this publication

- go to www.csagroup.org/store/
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **2428549**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

Canadian Standards Association (operating as “CSA Group”), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Group’s standards development by volunteering their time and skills to Committee work and supporting CSA Group’s objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Group’s total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Group’s standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects products that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard
Toronto, Ontario, M9W 1R3
Canada

A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at www.scc.ca.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Standards Council of Canada
600-55 Metcalfe Street
Ottawa, Ontario, K1P 6L5
Canada



Standards Council of Canada
Conseil canadien des normes

Cette Norme Nationale du Canada est disponible en versions française et anglaise.

Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users to judge its suitability for their particular purpose.

**A trademark of the Canadian Standards Association, operating as “CSA Group”*

National Standard of Canada

CSA C900.6:21

Thermal energy meters — Part 6: Installation, commissioning, operational monitoring and maintenance (EN 1434-6:2015+A1:2019, MOD)

*Prepared by
European Committee for Standardization*



Reviewed by



*®A trademark of the Canadian Standards Association,
operating as “CSA Group”*



*Published in April 2021 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at www.csagroup.org/store/
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ICS 17.200.10
ISBN 978-1-4883-3213-5*

*© 2021 Canadian Standards Association
All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.*

CSA C900.6:21

Thermal energy meters — Part 6: Installation, commissioning, operational monitoring and maintenance

(EN 1434-6:2015+A1:2019, MOD)

CSA Preface

This is the third edition of CSA C900.6, *Thermal energy meters — Part 6: Installation, commissioning, operational monitoring and maintenance*, which is an adoption, with Canadian deviations, of the identically titled CEN (European Committee for Standardization) Standard EN 1434-6 (edition 3:2015 consolidated with Amendment 1:2018). It supersedes the previous edition published in 2013 as CAN/CSA-C900.6 (adopted EN 1434-6:2007), *Heat meters — Part 6: Installation, commissioning, operational monitoring and maintenance*.

For brevity, this Standard will be referred to as “CSA C900.6” throughout.

This Standard is one of a group of Standards on *Thermal energy meters* being adopted by CSA Group, which consists of the following:

- a) CSA C900.1 (adopted EN 1434-1) — *Part 1: General requirements*;
- b) CSA C900.2 (adopted EN 1434-2) — *Part 2: Constructional requirements*;
- c) CSA C900.3 (adopted EN 1434-3) — *Part 3: Data exchange and interfaces*;
- d) CSA C900.4 (adopted EN 1434-4) — *Part 4: Pattern approval tests*;
- e) CSA C900.5 (adopted EN 1434-5) — *Part 5: Initial verification tests*; and
- f) CSA C900.6 (adopted EN 1434-6) — *Part 6: Installation, commissioning, operational monitoring and maintenance*.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was reviewed for Canadian adoption by the CSA Technical Committee on Thermal Energy Meters, under the jurisdiction of the CSA Strategic Steering Committee on Fuels and Appliances, and has been formally approved by the Technical Committee.

This Standard has been developed in compliance with Standards Council of Canada requirements for National Standards of Canada. It has been published as a National Standard of Canada by CSA Group.

© 2021 Canadian Standards Association

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher. CEN material is reprinted with permission. Where the words “this European Standard” appear in the text, they should be interpreted as “this National Standard of Canada”.

Inquiries regarding this National Standard of Canada should be addressed to
CSA Group
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3
1-800-463-6727 • 416-747-4000
www.csagroup.org

To purchase standards and related publications, visit our Online Store at store.csagroup.org or call toll-free 1-800-463-6727 or 416-747-4044.

This Standard is subject to review within five years from the date of publication, and suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line:

- a) *Standard designation (number);*
- b) *relevant clause, table, and/or figure number;*
- c) *wording of the proposed change; and*
- d) *rationale for the change.*

Canadian deviations

The following deviations are intended to meet local product requirements and to align with energy efficiency requirements of relevant Canadian regulators.

2 Normative references

[Add the following]

In this Standard, any reference to European Standards shall be replaced by the relevant National Standard of Canada.

For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

The following National Standard of Canada, published by CSA Group, is an adoption of a CEN Standard. The requirements of this CSA Group Standard shall take precedence over the European Standard on which it is based. Any reference within CSA C900.6 to the European Standard shall be replaced by a reference to the equivalent Canadian Standard.

CSA Group

CSA C900.1:21

Thermal energy meters — Part 1: General requirements

[Replaces EN 1434-1:2015+A1:2018]

Annex A (informative)

Thermal energy meter installation

A.3 Quality of the heat conveying liquid

A.3.2 Primary water quality

[Add the following paragraph]

When purchasing or specifying thermal energy meters, the owner of the meter should consult with the meter manufacturer to determine any particular water quality requirements to minimize any impact on the meter's accuracy.

A.3.3 Secondary water quality

[Replace the second paragraph with the following]

When purchasing or specifying thermal energy meters, the owner of the meter should consult with the meter manufacturer to determine any particular water quality requirements to minimize any impact on the meter's accuracy.

EUROPEAN STANDARD

EN 1434-6:2015+A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

February 2019

ICS 17.200.10

Supersedes EN 1434-6:2015

English Version

Thermal energy meters - Part 6: Installation, commissioning, operational monitoring and maintenance

Compteurs d'énergie thermique - Partie 6 : Installation,
mise en service, surveillance et maintenance

Thermische Energiemessgeräte - Teil 6: Einbau,
Inbetriebnahme, Überwachung und Wartung

This European Standard was approved by CEN on 5 September 2015 and includes Amendment 1 approved by CEN on 5 February 2018.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents	Page
European foreword	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	4
4 Requirements	5
4.1 Design requirements	5
4.2 Installation requirements	6
4.3 A1 Thermal energy meter A1 commissioning	7
4.3.1 General	7
4.3.2 Certification check	7
4.3.3 Installation check	7
4.3.4 A1 Thermal energy meter A1 security	7
Annex A (informative) A1 Thermal energy meter A1 installation	8
Annex B (informative) A1 Thermal energy meter A1 operational monitoring and maintenance	18
Annex C (informative) Suggested gauge for checking the dimensions of installed temperature sensor pockets	21
Annex ZA (informative) Relationship between this European Standard and the essential requirements of Directive 2014/32/EU aimed to be covered	22
Bibliography	23

European foreword

This document (EN 1434-6:2015+A1:2019) has been prepared by Technical Committee CEN/TC 176 “Thermal energy meters”, the secretariat of which is held by SIS.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2019, and conflicting national standards shall be withdrawn at the latest by August 2019.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document includes Amendment 1 approved by CEN on 5 February 2018.

This document supersedes $\boxed{A_1}$ EN 1434-6:2015 $\langle A_1 \rangle$.

The start and finish of text introduced or altered by amendment is indicated in the text by tags $\boxed{A_1}$ $\langle A_1 \rangle$.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive.

For relationship with EU Directive, see informative Annex ZA, which is an integral part of this document.

EN 1434, *Thermal energy meters* consists of the following parts:

- *Part 1: General requirements*
- *Part 2: Constructional requirements*
- *Part 3: Data exchange and interfaces¹⁾*
- *Part 4: Pattern approval tests*
- *Part 5: Initial verification tests*
- *Part 6: Installation, commissioning, operational monitoring and maintenance*

In comparison to EN 1434-6:2007, the following changes have been made:

- special cases for combined $\boxed{A_1}$ thermal energy meters $\langle A_1 \rangle$ are added;
- additional functionalities for smart metering applications are added;
- installation requirements added for $\boxed{A_1}$ thermal energy meters $\langle A_1 \rangle$ which are located next to cables like data communication cables and mains supply cables;
- installation requirement changed for 4-wire connections;
- cooling meters are added.

According to the CEN-CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

¹⁾ EN 1434-3 is maintained by CEN/TC 294.

1 Scope

This European Standard specifies commissioning, operational monitoring and maintenance and applies to **A1** thermal energy meters **A1**. **A1** Thermal energy meters **A1** are instruments intended for measuring the energy which in a heat-exchange circuit is absorbed (cooling) or given up (heating) by a liquid called the heat-conveying liquid. The **A1** thermal energy meter **A1** indicates the quantity of heat in legal units.

Electrical safety requirements are not covered by this European Standard.

Pressure safety requirements are not covered by this European Standard.

Surface mounted temperature sensors are not covered by this European Standard.

This standard covers meters for closed systems only, where the differential pressure over the thermal load is limited.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

A1 EN 1434-1:2015+A1:2018, *Thermal energy meters — Part 1: General requirements* **A1**

3 Terms and definitions

For the purposes of this document, the terms and definitions given in **A1** EN 1434-1:2015+A1:2018 **A1** and the following apply.

A1 3.1

thermal energy system

heating or cooling installations of the dwelling or premises, including the exchange circuit, the thermal energy meter, the associated fittings and the electrical equipment

Note 1 to entry: The heating or cooling systems typically commences and finishes at the two connections to the heat or cooling mains.

3.2

thermal energy mains

heat or cooling suppliers distribution pipes to which the consumer's installation is connected

3.3

inlet and outlet limbs

pipes connecting the heating or cooling system to the thermal energy mains

3.4

primary circuit

circuit hydraulically connected to the thermal energy mains **A1**

3.5

secondary circuit

circuit hydraulically separated from the primary circuit