




Special requirements for plumbing installations in health care facilities



Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Standards Update Service

CSA Z317.1:21 October 2021

Title: *Special requirements for plumbing installations in health care facilities*

To register for e-mail notification about any updates to this publication

- go to www.csagroup.org/store/
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **2429571**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

Canadian Standards Association (operating as “CSA Group”), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

More than 10 000 members indicate their support for CSA Group’s standards development by volunteering their time and skills to Committee work.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects products that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in fourteen countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard
Toronto, Ontario, M9W 1R3
Canada

A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at www.scc.ca.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Standards Council of Canada
600-55 Metcalfe Street
Ottawa, Ontario, K1P 6L5
Canada



Cette Norme Nationale du Canada n'est disponible qu'en anglais.

Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users to judge its suitability for their particular purpose.

®A trademark of the Canadian Standards Association, operating as “CSA Group”

National Standard of Canada

CSA Z317.1:21

Special requirements for plumbing installations in health care facilities



*®A trademark of the Canadian Standards Association,
operating as "CSA Group"*



*Published in October 2021 by CSA Group
A not-for-profit private sector organization
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at www.csagroup.org/store/
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ICS 91.040.10; 91.140.60; 91.140.70
ISBN 978-1-4883-3896-0*

*© 2021 Canadian Standards Association
All rights reserved. No part of this publication may be reproduced in any form whatsoever
without the prior permission of the publisher.*

Contents

Technical Committee on Health Care Facilities 5

Subcommittee on Plumbing in Health Care Facilities 8

Preface 10

1 Scope 12

- 1.1 General 12
- 1.2 Supplemental requirements 12
- 1.3 Intended use 12
- 1.4 Exclusions 12
- 1.5 Class of HCFs 13
- 1.6 Retrofitting of existing systems 13
- 1.7 Terminology 13
- 1.8 Units of measurement 13

2 Reference publications 13

3 Definitions 17

4 General 22

- 4.1 System planning and design 22
 - 4.1.1 General 22
 - 4.1.2 Design criteria and redundancy requirements 22
 - 4.1.3 Design process 22
 - 4.1.4 Water management plan 22
 - 4.1.5 Design process for new or renovated plumbing systems 22
 - 4.1.6 Water quality requirements for specialized equipment 22
- 4.2 Construction 23
 - 4.2.1 General 23
 - 4.2.2 Materials for use 23
- 4.3 Commissioning 23
- 4.4 Risk management 23
 - 4.4.1 General 23
 - 4.4.2 Risk management approach 23
- 4.5 Operation and maintenance 24
 - 4.5.1 Maintenance program 24
 - 4.5.2 Infection prevention and control measures 25
 - 4.5.3 Evaluation, testing, and treatment of potable water systems 28
- 4.6 Sustainability 29
- 4.7 Application 30
 - 4.7.1 General 30
 - 4.7.2 Renovations or additions 30
 - 4.7.3 Plumbing systems serving areas that are renovated 30
 - 4.7.4 Design review of water supply and distribution systems for additions to HCF 30
 - 4.7.5 Legacy HCF plumbing systems 30

4.8	Catastrophic event management	31
4.9	Alarms	31
5	Hydraulic fire protection systems	31
5.1	General	31
5.2	Class of HCFs	31
5.3	Longevity of sprinkler system piping	31
5.4	Supply piping for hydraulic fire protection systems	31
5.5	Concealed sprinkler heads	31
5.6	Sprinkler heads in accessible areas	31
5.7	Sprinkler heads in patient care areas	32
5.8	Fire hose cabinets	32
6	Water systems	32
6.1	General	32
6.2	Potable water supply	32
6.3	Potable water distribution systems	32
6.3.1	Design and construction	32
6.3.2	System elements	34
6.3.3	Hot water systems	36
6.3.4	Water storage tanks	40
6.3.5	Initial system treatment	41
6.4	Specialized water systems	42
6.4.1	General	42
6.4.2	Deionization	44
6.4.3	Distillation	44
6.4.4	Reverse osmosis	44
6.4.5	Membrane and filter technology	45
6.5	Steam and condensate	45
7	Drainage systems	45
7.1	General requirements	45
7.1.1	General	45
7.1.2	Drainage systems in medical laboratories	45
7.2	Foreign objects	45
7.3	Insulation	46
7.4	Storm drainage systems	46
7.4.1	Discharge	46
7.4.2	Sump pumps	46
7.5	Sanitary drainage systems	47
7.5.1	Sewage pumps	47
7.5.2	Design	47
7.5.3	Hazardous waste	48
8	Plumbing fixtures and fittings	50
8.1	General	50
8.1.1	Fixtures and fittings	50
8.1.2	Tampering and vandalism	50
8.1.3	Backflow preventers	50

8.1.4	Lavatory faucets	50
8.1.5	Accessible design	51
8.1.6	Service space	51
8.1.7	Maintenance program	51
8.1.8	Automatic faucets	51
8.1.9	Main power loss to automatic faucets	51
8.1.10	Overflows	51
8.1.11	Cleaning program for overflows	52
8.2	Water closets	52
8.2.1	Class of HCFs	52
8.2.2	General requirements	52
8.2.3	Bedpan washing	52
8.2.4	Wheelchair-accessible water closets	52
8.2.5	Water closets for bariatric patients	52
8.2.6	Urinals	52
8.2.7	Hands-free activation of water closets	53
8.2.8	Automatic flushing	53
8.3	Other human waste disposal provisions	53
8.3.1	General	53
8.3.2	Closed waste management system	53
8.3.3	Aerosolization of fluids	53
8.3.4	Hoppers	53
8.4	Sinks and lavatories	54
8.4.1	General	54
8.4.2	Hand hygiene sinks	55
8.4.3	Accessible sinks	57
8.4.4	Scrub sinks	58
8.4.5	Hoppers	59
8.4.6	Utility sinks	59
8.5	Bathtubs and showers	60
8.5.1	General	60
8.5.2	Bathtubs	60
8.5.3	Showers	61
8.6	Floor drains	61
8.6.1	General	61
8.6.2	Birthing suites	62
8.6.3	Strainers	62
8.6.4	Combination funnel-type floor drains	62
8.6.5	Interceptors	62
8.6.6	Trap seals and trap guards	62
8.7	Decontamination showers	62
8.7.1	Installation	62
8.7.2	Product requirements	62
8.8	Eye wash stations	63
8.8.1	Installation	63
8.8.2	Product requirements	63
8.9	Drinking water fountains	63

9 Catastrophic event management 63

9.1	General	63
9.1.1	Contingency plans	63
9.1.2	Response strategies for continuing operation	63
9.1.3	Contingency plan requirements	63
9.1.4	Water conservation and prioritization measures	64
9.1.5	Fire protection system	64
9.1.6	Effects of a water outage	64
9.1.7	Coordination of emergency planning functions	64
9.1.8	Provisions for return to normal operation	64
9.1.9	Breaks in water lines and power outages	64
9.2	Alternative water supply	64
9.2.1	General	64
9.2.2	Methods of compliance	65
9.2.3	Private water sources	65

Annex A (informative)	— Health care facility examples according to class	68
Annex B (informative)	— Measures to prevent legionella growth and spread in water systems	71
Annex C (informative)	— Legionella testing	76
Annex D (informative)	— Antimicrobial remediation measures for hot water systems	78
Annex E (normative)	— Water management plan	83

Technical Committee on Health Care Facilities

G. D. Burrill	Teegor Consulting Inc., Fredericton, New Brunswick, Canada <i>Category: Engineering Consultant</i>	<i>Chair</i>
R. Snell	Parkin Architects Limited, Toronto, Ontario, Canada <i>Category: General Interest</i>	<i>Vice-Chair</i>
S. Aspinwall	Smith + Andersen, Toronto, Ontario, Canada <i>Category: Engineering Consultant</i>	
S. Bagworth	Agnew Peckham and Associates, Toronto, Ontario, Canada <i>Category: General Interest</i>	
R. J. Belanger	CSA Consumer Representative, Wasaga Beach, Ontario, Canada <i>Category: General Interest</i>	
S. Bogdan	St. Joseph's Health Centre, Toronto, Ontario, Canada <i>Category: User Interest</i>	
A. Bridge	Alberta Health Services, Red Deer, Alberta, Canada	<i>Non-voting</i>
B. Darrell	Nova Scotia Department of Transportation and Infrastructure Renewal, Halifax, Nova Scotia, Canada <i>Category: Government and/or Regulatory Authority</i>	
C. Drolet	Ministère de la Santé et des Services sociaux (MSSS) du Québec, Québec, Québec, Canada <i>Category: Government and/or Regulatory Authority</i>	
L. Ellinas	R Tec Consulting Ltd., Toronto, Ontario, Canada <i>Category: Engineering Consultant</i>	

M. Fontaine	Gibsons, British Columbia, Canada <i>Category: User Interest</i>	
J. Fullerton	The Ottawa Hospital, Ottawa, Ontario, Canada <i>Category: User Interest</i>	
C. Harvey	Niagara Health, Niagara Falls, Ontario, Canada <i>Category: User Interest</i>	
M. Keen	Unity Health Toronto, Toronto, Ontario, Canada <i>Category: General Interest</i>	
M. Lee	H. H. Angus & Associates Ltd., Toronto, Ontario, Canada <i>Category: Engineering Consultant</i>	
D. MacKay	Ontario Ministry of Health, Toronto, Ontario, Canada <i>Category: Government and/or Regulatory Authority</i>	
S. McEwan	Nelson, British Columbia, Canada	<i>Non-voting</i>
J. R. Persaud	JLSR Engineering Inc., Toronto, Ontario, Canada <i>Category: General Interest</i>	
L. M. Shea	Manitoba Health, Winnipeg, Manitoba, Canada <i>Category: Government and/or Regulatory Authority</i>	
N. Stark	H. H. Angus & Associates Ltd., Toronto, Ontario, Canada <i>Category: Engineering Consultant</i>	
K. Stockton	The Ottawa Hospital, Ottawa, Ontario, Canada <i>Category: User Interest</i>	
M. Weimer	Fraser Health Authority, New Westminster, British Columbia, Canada <i>Category: Government and/or Regulatory Authority</i>	

S. M. Wilson

Alberta Health Services,
Edmonton, Alberta, Canada
Category: User Interest

J. Vulovic

CSA Group,
Toronto, Ontario, Canada

Project Manager

Subcommittee on Plumbing in Health Care Facilities

M. Lee	H. H. Angus & Associates Ltd., Toronto, Ontario, Canada	<i>Chair</i>
K. Ernst	Oakville Stamping & Bending Limited, Oakville, Ontario, Canada	<i>Vice-Chair</i>
S. McEwan	Nelson, British Columbia, Canada	<i>Vice-Chair</i>
R. J. Belanger	CSA Consumer Representative, Wasaga Beach, Ontario, Canada	
G. D. Burrill	Teegor Consulting Inc., Fredericton, New Brunswick, Canada	
Y. Duchesne	Régie du bâtiment du Québec, Québec, Québec, Canada	
J. Fullerton	The Ottawa Hospital, Ottawa, Ontario, Canada	
D. Gleiberman	Sloan, Los Angeles, California, USA	
M. Leveque	Fraser Health Authority, Maple Ridge, British Columbia, Canada	
R. Marchand	Université de Montréal, Montréal, Québec, Canada	
A. Matte	Ministère de la Santé et des Services sociaux (MSSS) du Québec, Québec, Québec, Canada	
R. Owens	Shared Health/Health Sciences Centre, Winnipeg, Manitoba, Canada	
M. Prévost	Polytechnique Montréal, Montréal, Québec, Canada	

T. Runka	Chem-Aqua Environmental Services, Brampton, Ontario, Canada	
K. Sharples	Smith + Andersen, Toronto, Ontario, Canada	
F. Stauder	Masco Canada, St. Thomas, Ontario, Canada	
K. Wong	Uponor, Mississauga, Ontario, Canada	
K. Wyndham	Covenant Health, Grey Nuns Community Hospital, Edmonton, Alberta, Canada	
T. Qasim	CSA Group, Toronto, Ontario, Canada	<i>Project Manager</i>

Preface

This is the sixth edition of CSA Z317.1, *Special requirements for plumbing installations in health care facilities*, one of a series of Standards related to health care facility engineering. It supersedes the previous editions, published in 2016, 2009, 1999, 1988, and 1978.

This Standard is intended to assist health care facilities (HCFs) to manage the potential risks associated with plumbing installation and maintenance.

The main changes from the previous edition are as follows:

- a) new requirements for developing a water management plan (Clause [4.1.4](#) and Annex [E](#));
- b) a new clause containing requirements on risk management (Clause [4.4](#));
- c) new guidance on water features (Clause [4.5.2.2](#));
- d) expanded requirements regarding unused portions of water systems (Clause [4.5.2.8](#));
- e) a new requirement to conduct a risk assessment on HCF shutdown and restart procedures (Clause [4.5.2.11](#));
- f) revised requirements for plumbing systems that are renovated or new additions (Clauses [4.7.2](#) and [4.7.3](#));
- g) new requirements for water storage tanks (Clauses [6.3.4.1](#) and [6.3.4.7](#));
- h) additional requirements for power supply and control systems of sump pumps (Clause [7.4.2.3](#));
- i) revised requirements for lavatory faucets (Clause [8.1.4](#));
- j) revised requirements for hands-free activation of water closets (Clause [8.2.7](#));
- k) additional requirements for backsplashes and side splashes (Clause [8.4.2.5.1](#));
- l) revised requirements for hoppers (Clause [8.4.5](#));
- m) revised requirements for utility sinks (Clause [8.4.6](#));
- n) revised requirements for cleaning and disinfection of special-purpose bathtubs (Clause [8.5.2.3](#)); and
- o) new requirements for trap guards (Clause [8.6.6](#)).

CSA Group acknowledges that the development of this Standard was made possible, in part, by the financial support of the governments of Alberta, British Columbia, Manitoba, New Brunswick, Newfoundland and Labrador, Northwest Territories, Nova Scotia, Nunavut, Ontario, Prince Edward Island, Québec, Saskatchewan, and Yukon, as administered by the Canadian Agency for Drugs and Technologies in Health (CADTH).

This Standard was prepared by the Subcommittee on Plumbing in Health Care Facilities, under the jurisdiction of the Technical Committee on Health Care Facilities and the Strategic Steering Committee on Health and Well-being, and has been formally approved by the Technical Committee.

This Standard has been developed in compliance with Standards Council of Canada requirements for National Standards of Canada. It has been published as a National Standard of Canada by CSA Group.

Notes:

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*

- 4) To submit a request for interpretation of this Standard, please send the following information to inquiries@csagroup.org and include “Request for interpretation” in the subject line:
- define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;
 - provide an explanation of circumstances surrounding the actual field condition; and
 - where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.

Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at standardsactivities.csa.ca.

- 5) This Standard is subject to review within five years from the date of publication. Suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to inquiries@csagroup.org and include “Proposal for change” in the subject line:
- Standard designation (number);
 - relevant clause, table, and/or figure number;
 - wording of the proposed change; and
 - rationale for the change.

CSA Z317.1:21

Special requirements for plumbing installations in health care facilities

1 Scope

1.1 General

This Standard addresses the special requirements of plumbing systems pertinent to the design, construction, operation, and maintenance of health care facilities (HCFs). This Standard specifies requirements for the following in HCFs:

- a) water supply systems, including cold water systems and hot water systems;
- b) plumbing fixtures and fittings;
- c) drainage systems;
- d) risk management;
- e) monitoring and maintenance of water systems;
- f) infection control;
- g) catastrophic event planning;
- h) specialized water systems (e.g., reverse osmosis, deionized, distilled); and
- i) hydraulic fire protection systems.

Note: *Special requirements for plumbing systems apply in HCFs because of the need to protect occupants of the facility and the adjacent surroundings from*

- a) *infectious diseases;*
- b) *hazards created by improper temperatures, leaks, and inadequate drainage; and*
- c) *adverse conditions created by the failure or improper operation of plumbing systems.*

1.2 Supplemental requirements

This Standard supplements the relevant standards and other applicable requirements for plumbing systems, fixtures, and fittings in general building applications.

Notes:

- 1) *Relevant plumbing standards for plumbing fixtures and fittings can be found in the National Plumbing Code of Canada, adopted provincial/territorial plumbing codes, or both; local codes and bylaws; and other communications from authorities having jurisdiction.*
- 2) *Applicable requirements for plumbing systems are also contained in the National Building Code of Canada.*

1.3 Intended use

This Standard is not intended to preclude the use of design concepts and the adoption of construction, installation, operations, and maintenance procedures more stringent than those specified in this Standard and in the documents listed in Clause [2](#).

1.4 Exclusions

This Standard does not apply to medical gas systems.

Note: *See CSA Z7396.1 for pipelines for medical gases, medical vacuum, medical support gases, and anaesthetic gas scavenging systems.*