

**IEEE Std 80-2000**

(Revision of  
IEEE Std 80-1986)

# IEEE Guide for Safety in AC Substation Grounding

Sponsor

**Substations Committee**  
of the  
**IEEE Power Engineering Society**

Approved 30 January 2000

**IEEE-SA Standards Board**

**Abstract:** Outdoor ac substations, either conventional or gas-insulated, are covered in this guide. Distribution, transmission, and generating plant substations are also included. With proper caution, the methods described herein are also applicable to indoor portions of such substations, or to substations that are wholly indoors. No attempt is made to cover the grounding problems peculiar to dc substations. A quantitative analysis of the effects of lightning surges is also beyond the scope of this guide.

**Keywords:** ground grids, grounding, substation design, substation grounding

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2000 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 4 August 2000. Printed in the United States of America.

Print: ISBN 0-7381-1926-1 SH94807  
PDF: ISBN 0-7381-1927-X SS94807

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

**IEEE Standards** documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. Members of the committees serve voluntarily and without compensation. They are not necessarily members of the Institute. The standards developed within IEEE represent a consensus of the broad expertise on the subject within the Institute as well as those activities outside of IEEE that have expressed an interest in participating in the development of the standard.

Use of an IEEE Standard is wholly voluntary. The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of all concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
P.O. Box 1331  
Piscataway, NJ 08855-1331  
USA

Note: Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

IEEE is the sole entity that may authorize the use of certification marks, trademarks, or other designations to indicate compliance with the materials set forth herein.

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; (978) 750-8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

# Introduction

(This introduction is not part of IEEE Std 80-2000, IEEE Guide for Safety in AC Substation Grounding.)

This fourth edition represents the second major revision of this guide since its first issue in 1961. Major modifications include the further extension of the equations for calculating touch and step voltages to include L-shaped and T-shaped grids; the introduction of curves to help determine current division; modifications to the derating factor curves for surface material; changes in the criteria for selection of conductors and connections; additional information on resistivity measurement interpretation; and the discussion of multilayer soils. Other changes and additions were made in the areas of gas-insulated substations, the equations for the calculation of grid resistance, and the annexes. The fourth edition continues to build on the foundations laid by three earlier working groups: AIEE Working Group 56.1 and IEEE Working Groups 69.1 and 78.1.

The work of preparing this standard was done by Working Group D7 of the Distribution Substation Subcommittee and was sponsored by the Substation Committee of the IEEE Power Engineering Society. At the time this guide was completed, the Substation Grounding Safety Working Group, D7, had the following membership:

**Richard P. Keil**, *Chair*  
**Jeffrey D. Merryman**, *Secretary*

Hanna E. Abdallah  
Al Alexander  
Stan J. Arnot  
N. Barbeito  
Thomas M. Barnes  
Charles J. Blattner  
E. F. Counsel  
Frank A. Denbrock  
William K. Dick  
Gary W. DiTroia  
Victor L. Dixon  
S. L. Duong  
Jacques Fortin

David Lane Garrett  
Roland Heinrichs  
D. T. Jones  
G. A. Klein  
Allan E. Kollar  
Donald N. Laird  
M. P. Ly  
W. M. Malone  
A. Mannarino  
A. P. Sakis Meliopoulos  
Gino Menechella  
Jovan M. Nahman  
Benson P. Ng  
J. T. Orrell

Shashi G. Patel  
R. M. Portale  
F. Shainauskas  
Y. Shertok  
Gary Simms  
R. Singer  
Greg Steinman  
Brian Story  
J. G. Sverak  
W. Keith Switzer  
B. Thapar  
Mark Vainberg  
R. J. Wehling

This fourth edition of IEEE Std 80 is dedicated to the memory of J. G. Sverak, who, through his technical knowledge and expertise, developed the touch and step voltage equations and the grid resistance equations used in the 1986 edition of this guide. His leadership, humor, and perseverance as Chair of Working Group 78.1 led to the expansion of substation grounding knowledge in IEEE Std 80-1986.

The following members of the balloting committee voted on this standard:

Hanna E. Abdallah	David Lane Garrett	Shashi G. Patel
William J. Ackerman	Roland Heinrichs	Gene Pecora
Al Alexander	John J. Horwath	Trevor Pfaff
Stan J. Arnot	Donald E. Hutchinson	Percy E. Pool
Thomas M. Barnes	Richard P. Keil	Dennis W. Reisinger
George J. Bartok	Hermann Koch	Paulo F. Ribeiro
Michael J. Bio	Alan E. Kollar	Alan C. Rotz
Charles J. Blattner	Donald N. Laird	Jakob Sabath
Michael J. Bogdan	Thomas W. LaRose	Lawrence Salberg
Steven D. Brown	Alfred Leibold	Hazairin Samaulah
John R. Clayton	Rusko Matulic	David Shafer
Richard Cottrell	A. P. Sakis Meliopoulos	Gary Simms
Richard Crowdis	Gino Menechella	Mark S. Simon
Frank A. Denbrock	John E. Merando Jr.	Bodo Sojka
William K. Dick	Jeffrey D. Merryman	Greg Steinman
W. Bruce Dietzman	Jovan M. Nahman	Robert P. Stewart
Gary W. DiTroia	Benson P. Ng	Brian Story
Victor L. Dixon	Robert S. Nowell	W. Keith Switzer
Dennis Edwardson	John Oglevie	Duane R. Torgerson
Gary R. Engmann	James S. Oswald	Thomas P. Traub
Markus E. Etter	Michael W. Pate	Mark Vainberg
Jacques Fortin		John A. Yoder

When the IEEE-SA Standards Board approved this standard on 30 January 2000, it had the following membership:

**Richard J. Holleman, *Chair***  
**Donald N. Heirman, *Vice Chair***  
**Judith Gorman, *Secretary***

Satish K. Aggarwal	James H. Gurney	Louis-François Pau
Dennis Bodson	Lowell G. Johnson	Ronald C. Petersen
Mark D. Bowman	Robert J. Kennelly	Gerald H. Peterson
James T. Carlo	E. G. "Al" Kiener	John B. Posey
Gary R. Engmann	Joseph L. Koepfinger*	Gary S. Robinson
Harold E. Epstein	L. Bruce McClung	Akio Tojo
Jay Forster*	Daleep C. Mohla	Hans E. Weinrich
Ruben D. Garzon	Robert F. Munzner	Donald W. Zipse

\*Member Emeritus

Also included is the following nonvoting IEEE-SA Standards Board liaison:

Robert E. Hebner

Greg Kohn  
*IEEE Standards Project Editor*

# Contents

1.	Overview.....	1
1.1	Scope.....	1
1.2	Purpose.....	1
1.3	Relation to other standards.....	2
2.	References.....	2
3.	Definitions.....	3
4.	Safety in grounding.....	8
4.1	Basic problem .....	8
4.2	Conditions of danger.....	8
5.	Range of tolerable current.....	11
5.1	Effect of frequency .....	11
5.2	Effect of magnitude and duration .....	11
5.3	Importance of high-speed fault clearing .....	12
6.	Tolerable body current limit .....	13
6.1	Duration formula.....	13
6.2	Alternative assumptions.....	13
6.3	Comparison of Dalziel's equations and Biegelmeier's curve.....	14
6.4	Note on reclosing .....	15
7.	Accidental ground circuit.....	16
7.1	Resistance of the human body .....	16
7.2	Current paths through the body.....	16
7.3	Accidental circuit equivalents.....	17
7.4	Effect of a thin layer of surface material .....	20
8.	Criteria of tolerable voltage .....	23
8.1	Definitions.....	23
8.2	Typical shock situations.....	26
8.3	Step and touch voltage criteria.....	27
8.4	Typical shock situations for gas-insulated substations .....	28
8.5	Effect of sustained ground currents .....	29
9.	Principal design considerations.....	29
9.1	Definitions.....	29
9.2	General concept .....	30
9.3	Primary and auxiliary ground electrodes .....	31
9.4	Basic aspects of grid design.....	31
9.5	Design in difficult conditions.....	31
9.6	Connections to grid.....	32

10.	Special considerations for GIS.....	33
	10.1 Definitions.....	33
	10.2 GIS characteristics .....	34
	10.3 Enclosures and circulating currents .....	34
	10.4 Grounding of enclosures .....	35
	10.5 Cooperation between GIS manufacturer and user .....	35
	10.6 Other special aspects of GIS grounding.....	36
	10.7 Notes on grounding of GIS foundations .....	37
	10.8 Touch voltage criteria for GIS .....	37
	10.9 Recommendations.....	38
11.	Selection of conductors and connections .....	39
	11.1 Basic requirements.....	39
	11.2 Choice of material for conductors and related corrosion problems .....	40
	11.3 Conductor sizing factors .....	41
	11.4 Selection of connections .....	49
12.	Soil characteristics .....	49
	12.1 Soil as a grounding medium .....	49
	12.2 Effect of voltage gradient.....	49
	12.3 Effect of current magnitude .....	50
	12.4 Effect of moisture, temperature, and chemical content .....	50
	12.5 Use of surface material layer .....	51
13.	Soil structure and selection of soil model .....	51
	13.1 Investigation of soil structure.....	51
	13.2 Classification of soils and range of resistivity .....	52
	13.3 Resistivity measurements.....	52
	13.4 Interpretation of soil resistivity measurements .....	55
14.	Evaluation of ground resistance.....	64
	14.1 Usual requirements .....	64
	14.2 Simplified calculations.....	64
	14.3 Schwarz's equations.....	65
	14.4 Note on ground resistance of primary electrodes .....	68
	14.5 Soil treatment to lower resistivity .....	68
	14.6 Concrete-encased electrodes .....	68
15.	Determination of maximum grid current .....	72
	15.1 Definitions.....	72
	15.2 Procedure .....	73
	15.3 Types of ground faults .....	74
	15.4 Effect of substation ground resistance .....	76
	15.5 Effect of fault resistance .....	76
	15.6 Effect of overhead ground wires and neutral conductors .....	76
	15.7 Effect of direct buried pipes and cables .....	77
	15.8 Worst fault type and location .....	77
	15.9 Computation of current division .....	78

15.10	Effect of asymmetry.....	83
15.11	Effect of future changes .....	85
16.	Design of grounding system .....	86
16.1	Design criteria.....	86
16.2	Critical parameters .....	87
16.3	Index of design parameters .....	88
16.4	Design procedure .....	88
16.5	Calculation of maximum step and mesh voltages.....	91
16.6	Refinement of preliminary design .....	95
16.7	Application of equations for $E_m$ and $E_s$ .....	95
16.8	Use of computer analysis in grid design .....	95
17.	Special areas of concern.....	96
17.1	Service areas .....	96
17.2	Switch shaft and operating handle grounding.....	96
17.3	Grounding of substation fence .....	99
17.4	Results of voltage profiles for fence grounding.....	107
17.5	Control cable sheath grounding .....	108
17.6	GIS bus extensions.....	108
17.7	Surge arrester grounding.....	108
17.8	Separate grounds.....	108
17.9	Transferred potentials .....	109
18.	Construction of a grounding system .....	112
18.1	Ground grid construction—trench method .....	112
18.2	Ground grid construction—conductor plowing method .....	112
18.3	Installation of connections, pigtails, and ground rods .....	113
18.4	Construction sequence consideration for ground grid installation .....	113
18.5	Safety considerations during subsequent excavations .....	113
19.	Field measurements of a constructed grounding system .....	113
19.1	Measurements of grounding system impedance .....	113
19.2	Field survey of potential contours and touch and step voltages .....	116
19.3	Assessment of field measurements for safe design.....	117
19.4	Ground grid integrity test.....	117
19.5	Periodic checks of installed grounding system.....	118
20.	Physical scale models .....	118
	Annex A (informative) Bibliography.....	119
	Annex B (informative) Sample calculations.....	129
	Annex C (informative) Graphical and approximate analysis of current division.....	145
	Annex D (informative) Simplified step and mesh equations.....	164
	Annex E (informative) Equivalent uniform soil model for nonuniform soils .....	167
	Annex F (informative) Parametric analysis of grounding systems.....	170
	Annex G (informative) Grounding methods for high-voltage stations with grounded neutrals.....	185



# IEEE Guide for Safety in AC Substation Grounding

## 1. Overview

### 1.1 Scope

This guide is primarily concerned with outdoor ac substations, either conventional or gas-insulated. Distribution, transmission, and generating plant substations are included. With proper caution, the methods described herein are also applicable to indoor portions of such substations, or to substations that are wholly indoors.<sup>1</sup>

No attempt is made to cover the grounding problems peculiar to dc substations. A quantitative analysis of the effects of lightning surges is also beyond the scope of this guide.

### 1.2 Purpose

The intent of this guide is to provide guidance and information pertinent to safe grounding practices in ac substation design.

The specific purposes of this guide are to

- a) Establish, as a basis for design, the safe limits of potential differences that can exist in a substation under fault conditions between points that can be contacted by the human body.
- b) Review substation grounding practices with special reference to safety, and develop criteria for a safe design.
- c) Provide a procedure for the design of practical grounding systems, based on these criteria.
- d) Develop analytical methods as an aid in the understanding and solution of typical gradient problems.

---

<sup>1</sup>Obviously, the same ground gradient problems that exist in a substation yard should not be present within a building. This will be true provided the floor surface either assures an effective insulation from earth potentials, or else is effectively equivalent to a conductive plate or close mesh grid that is always at substation ground potential, including the building structure and fixtures.

Therefore, even in a wholly indoor substation it may be essential to consider some of the possible hazards from perimeter gradients (at building entrances) and from transferred potentials described in Clause 8. Furthermore, in the case of indoor gas-insulated facilities, the effect of circulating enclosure currents may be of concern, as discussed in Clause 10.