

Fuel Gas Measurement

API TECHNICAL REPORT 2571
FIRST EDITION, MARCH 2011



AMERICAN PETROLEUM INSTITUTE

Fuel Gas Measurement

Measurement Coordination

API TECHNICAL REPORT 2571
FIRST EDITION, MARCH 2011



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Copyright © 2011 American Petroleum Institute

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

Contents

Page

1	Scope	1
2	Terms and Definitions	1
3	Performance Characteristics and Measurement by Meter Type	3
3.1	General	3
3.2	Differential Pressure Type Flow Meters	4
3.3	Linear Flow Meters	10
3.4	Selection Criteria and Documentation of Fuel Gas Meters	14
4	Secondary and Tertiary Instrumentation	15
4.1	Introduction	15
4.2	Equipment Selection Considerations	15
4.3	Equipment Location and Installation	17
5	Uncertainty Calculations	18
5.1	Objective	18
5.2	Uncertainty Analysis Procedure	18
5.3	Combining the Uncertainty of Multiple Meters	20
5.4	Differential Producers	21
5.5	Linear Meters (Vortex, Ultrasonic, Turbine, PD)	25
5.6	Linear Meter (Coriolis)	28
6	Inspection, Verification, and Calibration	28
6.1	General	28
6.2	System Overview for Selection of Maintenance Activity, Frequency, and Tolerance	29
6.3	Relative Stream Significance	29
6.4	Identify Devices to be Inspected, Verified, or Calibrated	30
6.5	Influence of Meter Type on Frequency Selection	31
6.6	Calibration Results Influence on Frequency Selection	33
	Annex A (informative) Uncertainty Examples	34
	Bibliography	65
Figures		
1	Schematic of a Fuel Gas Measurement System	15
2	Example of Fuel Gas Measurement System	16
A.1	Example of Fuel Gas Measurement System (for Illustration Purposes Only)	35
Tables		
1	Installation Effect Sensitivity and Secondary Instrument Requirements	3
2	Significant Common DP Meter Influence Parameters	5
3	Additional Orifice Meter Influence Parameters	6
4	Additional Venturi and Nozzle Meter Influence Parameters	7
5	Additional Multiport Averaging Pitot, and Wedge Meter Influence Parameters	8
6	Variable Area Meter Influence Parameters	9
7	Additional Pitot, Pitot-Static Tube Meter Influence Parameters	9
8	Common Volumetric Linear Meter Influence Parameters	10
9	Additional Displacement Meter Influence Parameters	11
10	Additional Turbine Meter Influence Parameters	11
11	Additional Ultrasonic Meter Influence Parameters	12

Contents

	Page
12 Additional Vortex Meter Influence Parameters	12
13 Additional Thermal Meter Influence Parameters	13
14 Additional Coriolis Meter Influence Parameters	14
15 Static Pressure Tap Location	17
16 DP Meter Static Pressure Variance Effect	23
17 DP Meter Temperature Variance Effect	24
18 DP Meter Compressibility Effect Typical Natural Gas vs Typical Natural Gas + 20 % H ₂	25
19 Linear Meter Static Pressure Variance Effect	26
20 Linear Meter Temperature Variance Effect	26
21 Compressibility–Typical Natural Gas	27
22 Linear Meter Compressibility Effect Typical Natural Gas vs Typical Natural Gas + 20 % H ₂	27
23 Plant Determination of Relative Stream Significance	30
24 Inspection, Verification, and Calibration Summary	31
25 Meter Station F101: Initial Calibration Program	32
26 Meter Station F101: Revised Calibration Program	33
A.1 Instrumentation on Meter Types	34

Introduction

This document provides a performance-based methodology for the measurement and reporting of fuel gas consumption. Specifically, considerations are provided for measurement device selection, installation, maintenance, calibration and documentation to achieve the targeted performance in terms of availability and uncertainty. If the performance of any installed measurement device is determined not to be in compliance with an acceptable level of uncertainty, the measurement device, its installation, or maintenance practices, etc. can be upgraded. Techniques are described to assess the uncertainty contribution of individual components of fuel gas measurement systems and the overall facility fuel gas measurement uncertainty. By following the guidance and calculation procedures of this document, cost effective fuel gas measurements of appropriate quality can be achieved. In most cases the rigorous requirements of industry standards intended for custody transfer quality measurements can be reduced and still achieve the desired measurement uncertainty. For this document, a fuel gas system in a facility could be comprised of multiple fuel gas meters or a single meter.

This document addresses the most common fuel gas measurement devices in use at the time of its development. This does not advocate the use of these devices or preclude the utilization of other types of devices, provided the targeted performance is achieved.

This Technical Report (TR) includes a brief description of the working principles of different types of fuel gas meters and their influence parameters, installation recommendations, a uniform method to ascertain the measurement uncertainty, a recommended method to determine the frequency of maintenance, performance verification or calibration of the meter and secondary instruments, and other relevant and necessary information.

Fuel gas can be measured by different types of flow meters. The selection of a meter typically depends on several factors such as:

- desired accuracy for the application;
- desired accuracy verification capability (i.e. calibration, inspection, replacement);
- life expectancy;
- operating conditions and their variability—flow rate, pressure, temperature, gas composition/density, etc.;
- cost of initial installation;
- operational requirements;
- regulatory requirements.

Listed below are different flow meters that are typically installed to measure the fuel gas flows in the industry. The selection of the fuel gas meter by the user may include other types of meters not included in this list:

- differential-pressure or head-type flow meters;
- displacement flow meters;
- turbine flow meters;
- thermal dispersion flow meters;
- Coriolis force flow meters;
- ultrasonic flow meters;
- vortex flow meter.

Fuel Gas Measurement

1 Scope

This Technical Report (TR) provides guidance in the following areas to allow the user to achieve a targeted uncertainty of measurement:

- selection of flow meter type; differential pressure (DP), displacement, ultrasonic, Coriolis, vortex, turbine, thermal, and others;
- associated instrumentation for measuring fluid properties and flowing conditions, such as pressure and temperature transmitters, densitometers, gas chromatographs;
- obtaining and use of gas composition or other analytical data;
- design and installation requirements of the measurement system;
- inspection, verification and calibration practices of flow meters and their associated accessory instrumentation; and
- simplified uncertainty calculations with examples to illustrate the methodology.

2 Terms and Definitions

For the purposes of this document, the following definitions apply.

2.1

accuracy

The ability of a measurement instrument to indicate values closely approximating the true value of the quantity measured.

2.2

bias

Any influence on a result that produces an incorrect approximation of the true value of the variable being measured. Bias is the result of a predictable systematic error.

2.3

calibration

The process or procedure of adjusting an instrument so that its indication or registration is in satisfactorily close agreement with a reference standard.

2.4

carbon content

The fraction of carbon in the fluid expressed as percent by weight.

2.5

compensation

The adjustment of the measured value to reference conditions (e.g. pressure compensation).

2.6

fuel gas

Typically a mixture of light hydrocarbon and other molecules (e.g. H₂, N₂) in a gaseous state that are consumed in fired heaters. Fuel gas is often a mixture of recovered gaseous molecules from plant operations and purchased natural gas.