

Recommended Practice for Field Testing Oil-based Drilling Fluids

API RECOMMENDED PRACTICE 13B-2
FIFTH EDITION, APRIL 2014

ERRATA 2, FEBRUARY 2018
ERRATA 1, AUGUST 2014

ADDENDUM 1, AUGUST 2019

Date of Issue: August 2019

Affected Publication: API Recommended Practice 13B-2, *Recommended Practice for Field Testing Oil-based Drilling Fluids*, Fifth Edition, April 2014

Addendum 1

Pages 18 to 24: Section 8, Sub-sections 8.1, 8.2, and 8.3, and Table 3 shall be replaced by the following:

8 Static Filtration

8.1 Principle

8.1.1 Measurement of the filtration behavior and the filter cake characteristics of an oil-based drilling fluid are fundamental to the treatment and control of a drilling fluid, as are the characteristics of the filtrate, such as the oil, aqueous phase, or emulsion concentration.

8.1.2 Filtration characteristics of an oil-based drilling fluid are affected by the quantity, type and size of solid particles and emulsified aqueous phase in the drilling fluid, and by properties of the liquid phase. Interactions of these various components can be influenced by temperature and pressure.

8.1.3 Filtration tests are performed at high-temperature/high pressure static conditions. Field static high-temperature/high-pressure filtration tests are conducted using a differential pressure of 3450 kPa (500 psi). Two filtration procedures are given: one for testing up to 175 °C (350 °F) and one for testing from 175 °C (350 °F) to 230 °C (450 °F). Use only the filtration equipment and procedure specified for the temperature required.

NOTE No low-temperature filtration test procedure for oil-based drilling fluids is specified herein, but it can be performed much like the water-based drilling fluid test provided in API 13B-1.

8.1.4 The 175 ml, 250 ml, or 500 ml unit may be used for static filtration testing up to and including 175 °C (350 °F).

8.1.5 For testing above 175 °C (350 °F), only the 500 ml unit shall be used. It is recommended that the cell be equipped with a thermocouple in direct contact with the fluid contained in the cell to more accurately measure the temperature.

8.2 High-temperature/High-pressure Test up to 175 °C (350 °F)

8.2.1 Apparatus

8.2.1.1 High-temperature/high-pressure filter press, consisting of:

- a) filter cell, to contain working pressures up to 9000 kPa (1300 psi) at temperature;
- b) pressurized gas source, such as carbon dioxide or nitrogen, with regulators;

NOTE Nitrogen is preferred.

- c) heating system with temperature controller or thermostat, to heat to 175 °C (350 °F);
- d) high-pressure filtrate collection vessel, maintained at proper back-pressure (see Table 3) to avoid flashing or evaporation of the filtrate;
- e) filter cell containing a thermometer well or thermocouple in direct contact with the fluid near the center of the cell, fitted with a removable end, a filter-media support and with oil-resistant seals.

NOTE Valve stems on each end of the cell can be opened or closed during the test.

WARNING—Not all manufacturers' equipment can be used above 150 °C (300 °F). Failure to know the pressure/temperature rating of equipment in use can result in serious injury. Testing at high temperature and high pressure calls for added safety precautions. Strict adherence to manufacturer's recommendations as to sample volumes, equipment temperatures and pressures, O-ring material selection and inspection, and other operating instructions is essential. Using appropriate personal protective equipment and safety barriers is recommended when operating HTHP equipment. Failure to follow these precautions could result in serious injury.

Do not use nitrous oxide cartridges as pressure sources for HTHP filtration. Under temperature and pressure, nitrous oxide can detonate in the presence of grease, oil, or carbonaceous materials. Nitrous oxide cartridges shall be used only for Garrett gas train carbonate analysis, in accordance with API 13B-1.

Table 3—Recommended Minimum Back-pressure

Test Temperature		Vapor Pressure		Minimum Back-pressure	
°C	°F	kPa	lbf/in. ²	kPa	lbf/in. ²
95–149	200–299	84–462	12.1–67	700	100
150–189	300–374	462–1269	67–184	1400	200
190–199	375–399	1269–1704	184–247	1900	275
200–219	400–424	1704–2245	247–326	2500	350
220–230	425–450	2245–2912	326–422	3100	450

8.2.1.2 Filter medium: Hardened, low-ash grade filter paper², for temperatures up to 200 °C (400 °F) a new paper is required for each test.

8.2.1.3 Mechanical or electronic timer, with at least a 30 min interval.

8.2.1.4 Thermometer, with a range up to 260 °C (500 °F), and with a 12.5 cm (5 in.) or longer stem, or a thermocouple with a range up to 260 °C (500 °F), preferred.

8.2.1.5 Graduated cylinder (TC), long, slender glass tube, with a capacity of 10 ml or 20 ml.

8.2.1.6 Graduated cylinder (TC), optional, with a capacity of 25 ml.

8.2.1.7 Field mixer, cup type, to operate at 10,000 r/min to 15,000 r/min.

8.2.1.8 Ruler, graduated in millimeters (¹/₃₂ in.), to measure filter cake thickness.

² This filter paper is a calendered, hardened, qualitative, low-ash filter paper made from cotton linters. The filter paper has the following typical properties which may vary slightly by manufacturer: Slow filtration rate: 2685 Herzbergs; Particle retention in liquid: 2-5 µm; Ash Content: 0.015% by weight; Basis weight: 92 g/m²; Diameter: 63.5 mm (2.5 in.); Thickness: 0.137 mm

8.2.2 Procedure

In order to conduct a HTHP filtration test on a sample of drilling fluid up to 175 °C (350 °F) using a differential pressure of 3450 kPa (500 psi), the following procedure shall be used.

8.2.2.1 Place the thermometer in the well of the heating jacket. Preheat the jacket to approximately 6 °C (10 °F) above the desired test temperature. Adjust the thermostat to maintain this temperature.

WARNING—The outside of the jacket can get hot enough to cause burns.

If the filtration unit is equipped with a thermocouple in direct contact with the drilling fluid, then that temperature should be monitored and reported during the filtration test. Under the “Comments” section, record if the results were based on fluid temperature measured with a direct contact thermocouple or using the 30 min heat-up time (after the cell wall reaches test temperature).

8.2.2.2 Stir the drilling fluid sample for 10 min using the field mixer set at the 10,000 r/min speed. Install and close the upper valve stem on the test cell. Pour the fluid sample into the filter cell, leaving at least a 2.5 cm (1 in.) space in the cell to allow for fluid expansion. Install the filtration media.

8.2.2.3 Ensuring that all O-rings are in place, install the lower end cap, with the valve stem open, above the filtration media and secure. Close the lower valve stem.

8.2.2.4 Complete the assembly of the filter cell and place it in the preheated heating jacket with the filter media on the bottom. Rotate the cell to lock it in place with the pin inside the heating jacket. If the filtration unit is not equipped with a thermocouple in direct contact with the drilling fluid, insert a thermometer into the well of the filter cell wall.

8.2.2.5 Ensure that the filtrate collection vessel is completely free of water or oil. Connect the regulated-pressure filtrate collection vessel assembly onto the lower valve stem and lock it in place. Connect the regulated-pressure assembly to the upper valve and lock it in place.

8.2.2.6 Keeping the two valve stems closed, adjust the pressure on the upper and lower pressure regulators to 700 kPa (100 psi) for temperatures below 150 °C (300 °F) or 1400 kPa (200 psi) for temperatures between 150 °C (300 °F) and 175 °C (350 °F). Open the upper valve stem and readjust the upper pressure regulator to maintain this pressure. Maintain these pressures with the upper valve open during the heat-up time. If the filtration unit is equipped with a thermocouple in direct contact with the drilling fluid, proceed to step 8.2.2.7 when the thermocouple temperature reaches the test temperature. If the filtration unit is not equipped with a thermocouple in direct contact with the drilling fluid, wait 30 min after the filter cell wall reaches the test temperature before proceeding to step 8.2.2.7.

NOTE If the total time required to begin the test exceeds 1 h, the heater might be defective, and the validity of the test is questionable.

8.2.2.7 When the sample reaches the selected test temperature, as indicated by the thermocouple or after the 30 min heat-up time, ensure that the lower pressure regulator is at 700 kPa (100 psi) for temperatures below 150 °C (300 °F) or 1400 kPa (200 psi) for temperatures between 150 °C (300 °F) and 175 °C (350 °F). Open the lower valve stem and immediately increase the pressure on the upper regulator to 4150 kPa (600 psi) for temperatures below 150 °C (300 °F) or 4850 kPa (700 psi) for temperatures between 150 °C (300 °F) and 175 °C (350 °F). This will start the filtration process. Start the timer. Maintain the test temperature to within ± 3 °C (± 5 °F) during the test, as indicated by the thermocouple or thermometer in the filter cell wall. Maintain these pressures with both valves open during the test, if the back pressure rises above the selected back pressure, cautiously draw off and collect a portion of the filtrate to reduce the back pressure.

WARNING—Filtrate will be hot, and steam may escape if the valve is left open too long.

8.2.2.8 Collect the filtrate in the graduated cylinder. Record the total volume of filtrate collected during the 30 min test, in milliliters. Correct the filtrate volume, V_F , to a filter area of 45.8 cm² (7.1 in.²). For example, if the filter area is 22.6 cm² (3.5 in.²), double the filtrate volume reported. Also note the presence of, or volumes of, any solids, water, or emulsions, if present.

8.2.2.9 Immediately after collecting the 30 min filtrate, close the lower, then the upper valve stems. Switch off the heating jacket and unplug from the electrical power source. Following the manufacturer's detailed instructions, bleed pressure off the regulators and hoses, and then carefully disconnect the pressurization system.

WARNING—Cell and heating jacket are still hot!

8.2.2.10 Using appropriate personal protective equipment, carefully remove the cell from the heating jacket and allow cell to cool to below 50 °C (125 °F). Keep the cell upright during cooling, depressurization, and disassembly.

WARNING—The filter cell may still be pressurized even after the cell is cooled. To avoid possible serious injury, keep cell upright and cool to room temperature, and then bleed pressure from cell before disassembling.

8.2.2.11 After cooling the cell, bleed pressure from the filter cell by slowly opening the upper valve stem. Avoid spraying drilling fluid as gas exits the stem. Ensure that pressure is fully released before removing the cap. Carefully disassemble the cell.

NOTE If there is resistance when loosening the cap, pressure may still be inside the cell. Ensure that all pressure is released before attempting to remove the end cap.

8.2.2.12 Pour the liquid from the cell.

8.2.2.13 Remove the filter cake with the filtration medium. Measure the filter cake thickness, at its center, to the nearest millimeter ($1/32$ in.).

8.2.2.14 Settling of solids onto the filter cake may have occurred during the test. Observe indications of this, such as an abnormally thick cake or coarse texture. Record these cake characteristics under the "Comments" on the Mud Report Form. To minimize settling, the times for heat-up and cool-down should be minimized, and the cake should be recovered and examined promptly.

8.2.3 Calculation

8.2.3.1 The filtrate volume, V_F , should be corrected to a filter area of 45.8 cm² (7.1 in.²). HTHP filter cells usually have half the standard filter area 22.6 cm² (3.5 in.²), thus double the observed volume before reporting.

8.2.3.2 Report the cake thickness to the nearest millimeter ($1/32$ in.), its texture and the presence of any emulsion or water in the filtrate.

8.3 High-temperature/High-pressure Test from 175 °C (350 °F) up to and Including 230 °C (450 °F)

8.3.1 Apparatus

8.3.1.1 High-temperature/high-pressure filter press, consisting of the following components:

a) 500 ml volume cell, only;

NOTE For safety reasons, it is advisable that only the 500 ml cell be used for testing up to and above 230 °C (450 °F).

b) filter cell, to contain working pressures up to 15,500 kPa (2250 psi) at a temperature of 230 °C (450 °F);

c) pressurized gas source, nitrogen with regulators (preferred);

d) heating system with temperature controller or thermostat, to heat to 260 °C (500 °F);

e) high-pressure filtrate collection vessel, maintained at proper back pressure (see Table 3), to avoid flashing or evaporation of the filtrate;

NOTE For temperatures >190 °C (>375 °F) the back-pressure gauge of the high-pressure filtrate collection vessel will need to be capable of measuring pressures above 1400 kPa (200 psi).

- f) filter cell containing a thermometer well or thermocouple in direct contact with the fluid near the center of the cell, fitted with a removable end, a filter-media support and with oil-resistant seals.

NOTE Valve stems on each end of the cell can be opened or closed during a test.

WARNING—Not all manufacturers' equipment can be used above 150 °C (300 °F). Failure to know the pressure/temperature rating of equipment in use can result in serious injury. Testing at high temperature and high pressure calls for added safety precautions. The 175 ml and 250 ml filtration cells are not recommended for use at these higher temperatures and pressures. Strict adherence to manufacturer's recommendations as to sample volumes, equipment temperatures and pressures, O-ring material selection and inspection, and other operating instructions is essential. High temperature O-rings and elastomer seals are required for high temperatures. Equipment manufacturers often recommend replacement or inspection after every test. Inspection should include making sure the O-rings and elastomer seals are pliable with no permanent deformations, nicks, or cuts, etc. A loss of pressure during a test may be an indication of an O-ring or elastomer seal failure and should be corrected. Using appropriate personal protective equipment and safety barriers is recommended when operating HTHP equipment. Failure to follow these precautions could result in serious injury.

WARNING—Do not use nitrous oxide cartridges as pressure sources for HTHP filtration. Under temperature and pressure, nitrous oxide can detonate in the presence of grease, oil, or carbonaceous materials. Nitrous oxide cartridges shall be used only for Garrett gas train carbonate analysis, in accordance with API 13B-1.

8.3.1.2 Filter medium;

- a) Hardened, low-ash grade filter paper³ and glass fiber backing disk³ for temperatures up to 200 °C (400 °F) a new paper is required for each test;
- b) Porous sintered stainless-steel disc, Dynalloy X-5, for temperatures above 200 °C (400 °F): a new disc is required for each test.

8.3.1.3 Mechanical or electronic timer, with at least a 30 min interval.

8.3.1.4 Thermometer, with a range up to 260 °C (500 °F), and with a 12.5 cm (5 in.) or longer stem, or a thermocouple with a range up to 260 °C (500 °F), preferred.

8.3.1.5 Graduated cylinder (TC), long, slender with a volume of 10 ml or 20 ml.

8.3.1.6 Graduated cylinder (TC), optional, with a volume of 25 ml.

8.3.1.7 Field mixer, cup type, to operate at 10,000 r/min to 15,000 r/min.

8.3.1.8 Ruler, graduated in millimeters (¹/₃₂ in.), to measure filter cake thickness.

8.3.2 Procedure

In order to conduct a HTHP test at 175 °C (350 °F) up to and including 230 °C (450 °F) test using a differential pressure of 3450 kPa (500 psi), the following procedure shall be used.

8.3.2.1 Place the thermometer in the well of the heating jacket. Preheat the jacket to approximately 6 °C (10 °F) above the desired test temperature. Adjust the thermostat to maintain this temperature.

³ Glass fiber backing disks are required for testing between 175 °C (350 °F) up to 200 °C (400 °F). These backing disks are a separate item and are inserted between the filter paper and the filter-media support of the filter cell.

WARNING—The outside of the jacket can get hot enough to cause burns.

If the filtration unit is equipped with a thermocouple in direct contact with the drilling fluid, then that temperature should be monitored and reported during the filtration test. Under the “Comments” section, record if the results were based on fluid temperature measured with a direct contact thermocouple or using the 30 min of heat-up time (after the cell wall reaches test temperature).

8.3.2.2 Stir the drilling fluid sample for 10 min using the field mixer set at the 10,000 r/min speed. Install and close the upper valve stem on the test cell. Pour the fluid sample into the filter cell, leaving at least a 5.0 cm (2 in.) space in the cell to allow for fluid expansion. Install the filtration media.

8.3.2.3 Ensuring that all O-rings are in place, install the lower end cap, with the valve stem open, above the filtration media and secure. Close the lower valve stem.

8.3.2.4 Complete the assembly of the filter cell and place it in the preheated heating jacket with the filter media on the bottom. Rotate the cell to lock it in place with the pin inside the heating jacket. If the filtration unit is not equipped with a thermocouple in direct contact with the drilling fluid, insert a thermometer into the well of the filter cell wall.

8.3.2.5 Ensure that the filtrate collection vessel is completely free of water or oil. Connect the regulated-pressure filtrate collection vessel assembly onto the lower valve stem and lock it in place. Connect the regulated pressurized gas source to the upper valve and lock in place.

8.3.2.6 Keeping the two valve stems closed, adjust the pressure on the upper and lower pressure regulators to the minimum back-pressure for the test temperature as shown in Table 3. Open the upper valve stem and readjust the upper pressure regulator to the minimum back-pressure temperature. Maintain these pressures with the upper valve open during the heat-up time. If the filtration unit is equipped with a thermocouple in direct contact with the drilling fluid, proceed to 8.3.2.7 when the thermocouple temperature reaches the test temperature. If the filtration unit is not equipped with a thermocouple in direct contact with the drilling fluid, wait 30 min after the filter cell wall reaches the test temperature before proceeding to 8.3.2.7.

NOTE If the total time required to begin the test exceeds 1 h, the heater might be defective, and the validity of the test is questionable.

8.3.2.7 When the sample reaches the selected test temperature, as indicated by the thermocouple or after the 30 min heat-up time, ensure that the lower pressure regulator is at the minimum back-pressure for the test temperature as shown in Table 3. Open the lower valve stem and immediately increase the pressure on the upper regulator to a value 3450 kPa (500 psi) higher than the back-pressure. This will start the filtration process. Start the timer. Maintain the test temperature to within ± 3 °C (± 5 °F) during the test, as indicated by the thermocouple or thermometer in the filter cell wall. Maintain these pressures with both valves open during the test, if the back pressure rises above the selected back pressure, cautiously draw off and collect a portion of the filtrate to reduce the back pressure.

WARNING—Filtrate will be hot, and steam may escape if the valve is left open too long.

8.3.2.8 Collect the filtrate in the graduated cylinder. Record the total volume of filtrate collected during the 30 min test, in milliliters. Correct the filtrate volume, V_F , to a filter area of 45.8 cm² (7.1 in.²). For example, if the filter area is 22.6 cm² (3.5 in.²), double the filtrate volume reported. Also note the presence of, or volumes of, any solids, water, or emulsions, if present.

8.3.2.9 Immediately after collecting the 30 min filtrate, close the lower, then the upper valve stems. Switch off the heating jacket and unplug from the electrical power source. Following the manufacturer’s detailed instructions, bleed pressure off the regulators and hoses, and then carefully disconnect the pressurization system.

WARNING—Cell and heating jacket are still hot!

8.3.2.10 Using appropriate personal protective equipment, carefully remove the cell from the heating jacket and allow cell to cool to below 50 °C (125 °F). Keep the cell upright during cooling, depressurization, and disassembly.

WARNING—The filter cell may still be pressurized even after the cell is cooled. To avoid possible serious injury, keep cell upright and cool to room temperature, and then bleed pressure from cell before

disassembling.

8.3.2.11 After cooling the cell, bleed pressure from the filter cell by slowly opening the upper valve stem. Avoid spraying drilling fluid as gas exits the stem. Ensure that pressure is fully released before removing the cap. Carefully disassemble the cell.

NOTE If there is resistance when loosening the cap, pressure may still be inside the cell. Ensure that all pressure is released before attempting to remove the end cap.

8.3.2.12 Pour the liquid from the cell.

8.3.2.13 Remove the filter cake with the filtration medium. Measure the filter cake thickness, at its center, to the nearest millimeter ($^{1/32}$ in.).

8.3.2.14 Settling of solids onto the filter cake may have occurred during the test. Observe indications of this, such as an abnormally thick cake or coarse texture. Record these cake characteristics under the "Comments" on the Mud Report Form. To minimize settling, the times for heat-up and cool-down should be minimized, and the cake should be recovered and examined promptly.

8.3.3 Calculation

8.3.3.1 The filtrate volume, V_F , should be corrected to a filter area of 45.8 cm^2 (7.1 in.^2). HTHP filter cells usually have half the standard filter area 22.6 cm^2 (3.5 in.^2), thus double the observed volume before reporting.

8.3.3.2 Report the cake thickness to the nearest millimeter ($^{1/32}$ in.), its texture and the presence of any emulsion or water in the filtrate.

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

Users of this recommended practice should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue NW, Suite 1100, Washington, DC 20001.

Copyright © 2014 American Petroleum Institute

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the specification.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the specification.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

This standard shall become effective on the date printed on the cover but may be used voluntarily from the date of distribution.

Standards referenced herein may be replaced by other international or national standards that can be shown to meet or exceed the requirements of the referenced standard.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

This standard replaces the Fourth Edition of API Recommended Practice 13B-2.

Contents

	Page
1 Scope	1
2 Normative References	2
3 Terms and Definitions	2
4 Symbols and Abbreviations	3
4.1 Symbols	3
4.2 Abbreviations	9
5 Determination of Drilling Fluid Density (Mud Weight)	10
5.1 Principle	10
5.2 Apparatus	10
5.3 Procedure	10
5.4 Calculation	11
6 Alternative Method for Determination of Drilling Fluid Density	13
6.1 Principle	13
6.2 Apparatus	13
6.3 Procedure	13
6.4 Calculation	14
7 Viscosity and Gel Strength	14
7.1 Principle	14
7.2 Determination of Viscosity Using the Marsh Funnel	14
7.3 Determination of Viscosity and Gel Strengths Using a Direct-reading Viscometer	15
8 Static Filtration	18
8.1 Principle	18
8.2 High-temperature/High-pressure Test up to 175 °C (350 °F)	18
8.3 High-temperature/High-pressure Test 175 °C (350 °F) up to and Including 230 °C (450 °F)	22
9 Retort Test for Oil, Water, and Solids Concentrations	25
9.1 Principle	25
9.2 Apparatus	25
9.3 Procedure-Volumetric Method	26
9.4 Calculation-Volumetric Method	28
9.5 Procedure-Gravimetric Method	29
9.6 Calculation-Gravimetric Method	31
9.7 Calculation-Volume Fractions of Oil, Water, and Solids	32
10 Chemical Analysis of Oil-based Drilling Fluids	34
10.1 Principle	34
10.2 Reagents and Apparatus	35
10.3 Base alkalinity demand (BAD), VB	36
10.4 Whole-drilling-fluid Alkalinity, VK	36
10.5 Whole-drilling-fluid Chloride Concentration	38
10.6 Whole-drilling-fluid Calcium Concentration	39
11 Electrical Stability Test	40
11.1 Principle	40
11.2 Apparatus	41
11.3 Equipment Calibration/Performance Test	42
11.4 Procedure	42

Contents

	Page
12 Lime, Salinity, and Solids Calculations	43
12.1 Principle	43
12.2 Apparatus	44
12.3 Whole-drilling-fluid Calculations	44
12.4 Aqueous Phase Calculations	47
12.5 Soluble and Insoluble Whole-drilling-fluid Sodium Chloride Calculations	51
12.6 Calculation-Solids in the Whole Drilling Fluid	52
Annex A (informative) Measurement of Shear Strength Using Shearometer Tube	57
Annex B (informative) Determination of Oil and Water Retained on Cuttings	59
Annex C (informative) Determination of Aqueous-phase Activity of Emulsified Water Using an Electro Hygrometer	64
Annex D (informative) Determination of Aniline Point	67
Annex E (informative) Lime, Salinity, and Solids Calculations	70
Annex F (informative) Sampling, Inspection, and Rejection of Drilling Materials	82
Annex G (informative) Rig-site Sampling	84
Annex H (informative) Determination of Cuttings Activity by the Chenevert Method	87
Annex I (informative) Chemical Analysis of Active Sulfides by the Garrett Gas Train Method	91
Annex J (informative) Calibration and Verification of Glassware, Thermometers, Viscometers, Retort Kit Cup, and Drilling Fluid Balances	96
Annex K (informative) High-temperature/High-pressure Filtration Testing of Drilling Fluids Using the Permeability-plugging Apparatus (PPA)	101
Annex L (informative) Compatibility of Elastomeric Materials with Non-aqueous-Based Drilling Fluids	112
Annex M (informative) Sand Content Procedure for Non-aqueous Fluids	116
Annex N (informative) Identification and Monitoring of Weight-material Sag	117
Annex O (informative) Oil-based Drilling Fluid Report Form	139
Bibliography	141
Figures	
1 Maximum Concentrations of NaCl in CaCl₂ Brine at 25 °C (77 °F)	48
G.1 Side-stream Sampling Device	85
G.2 Sample Scoop	86
K.1 Typical Permeability Plugging Apparatus	105
N.1 Example of Surface Density Variation with Temperature (Oil-based Drilling Fluid)	120
N.2 Example Surface Profile Based on Bottoms-up Data	122
N.3 Downhole Density Changes Measured While Running the Drill String in the Hole	123
N.4 Weight-material Sag Occurrence During Dynamic Conditions	124
N.5 Effect of Changes in Drill Pipe Rotational Speed on Downhole Pressure	125
N.6 North Sea Fingerprinting for Three Flow Rates and Four Drill String Rotation Speeds	126
N.7 Distribution of Fluid Viscosity Across the Annular Gap Caused by Drill String Rotation in a Non-circulating Drilling Fluid	128

Contents

	Page
N.8 Key Equipment for VSST Method	129
N.9 Published "Sag Window" for Drilling Fluids Versus Shear Rate	136
N.10 Predicted Dynamic Sag as a Function of Calculated Values of Tau Wall, τ_w	138
Tables	
1 Conversion of Density Units	11
2 Density Conversion	12
3 Recommended Minimum Back-pressure	19
4 Precision of Liquid Receiver	26
5 Commonly Used Densities	55
B.1 Precision of Liquid Receiver	60
C.1 Standard Saturated Salt Solutions	64
E.1 Physical and Chemical Properties of Examples of Drilling Fluids	70
H.1 Saturated Salt Solutions	87
I.1 Dräger H ₂ S Analysis Tubes	91
I.2 Dräger Tube (or Equivalent) Identification, Sample Volume, and Tube Factors to be Used for Various Sulfide Concentration Ranges	94
J.1 Density of Water as a Function of Temperature	98
K.1 Ceramic Discs, API Designation and Pore Throat Diameter	106
K.2 Starting Cell Pressures and Back-pressures for Various Test Temperatures	108
N.1 Sample Trip-out Sag Reporting Sheet	121
N.2 Matrix for Fingerprinting Drill String Rotation Effects on Downhole Density	126

Introduction

This standard is based on API Recommended Practice 13B-2, *Recommended Practice for Field Testing of Oil-based Drilling Fluids*, Fourth Edition.

As with any laboratory procedure requiring the use of potentially hazardous chemicals and equipment, the user is expected to have received proper training and knowledge in the use and disposal of these potentially hazardous materials. The user is responsible for compliance with all applicable local, regional, and national requirements for worker and local health, safety, and environmental liability.

In this standard, quantities expressed in the international System of Units (SI) are also, where practical, expressed in U.S. customary units (USC) in parentheses for information. The units do not necessarily represent a direct conversion of SI units to USC units, or USC units to SI units. Consideration has been given to the precision of the instrument making the measurement. For example, thermometers are typically marked in one degree increments, thus temperature values have been rounded to the nearest degree.

Calibrating an instrument refers to ensuring the accuracy of the measurement. Accuracy is the degree of conformity of a measurement of a quantity to its actual or true value. Accuracy is related to precision, or reproducibility, of a measurement. Precision is the degree to which further measurements or calculations will show the same or similar results. Precision is characterized in terms of the standard deviation of the measurement. The results of calculations or a measurement can be accurate but not precise, precise but not accurate, neither accurate nor precise, or both accurate and precise. A result is valid if it is both accurate and precise.

This document uses a format for numbers which follows the examples given in *API Document Format and Style Manual*, First Edition, June 2007 (Editorial Revision, January 2009). This numbering format is different than that used in API 13B-2, Fourth Edition. In this document the decimal mark is a period and separates the whole part from the fractional part of a number. No spaces are used in the numbering format. The thousands separator is a comma and is only used for numbers greater than 10,000 (i.e. 5000 items, 12,500 bags).

Recommended Practice for Field Testing Oil-Based Drilling Fluids

1 Scope

This recommended practice provides standard procedures for determining the following characteristics of oil-based drilling fluids:

- a) drilling fluid density (mud weight);
- b) viscosity and gel strength;
- c) filtration;
- d) oil, water, and solids concentrations;
- e) alkalinity, chloride concentration, and calcium concentration;
- f) electrical stability;
- g) lime and calcium concentrations, calcium chloride, and sodium chloride concentrations;
- h) low-gravity solids and weighting material concentrations.

The annexes provide additional test methods or examples that can optionally be used for the determination of:

- shear strength (Annex A);
- oil and water concentrations from cuttings (Annex B);
- drilling fluid activity (Annex C);
- aniline point (Annex D);
- lime, salinity, and solids concentration (Annex E);
- sampling, inspection and rejection (Annex F);
- rig-site sampling (Annex G);
- cuttings activity (Annex H);
- active sulfide (Annex I);
- calibration and verification of glassware, thermometers, viscometers, retort kit cups, and drilling fluid balances (Annex J);
- high-temperature/high-pressure filtration using the permeability-plugging apparatus (PPA) (Annex K);
- elastomer compatibility (Annex L);
- sand content of oil-based fluid (Annex M);
- identification and monitoring of weight-material sag (Annex N);
- oil-based drilling fluid test report form (Annex O).