

Product Quality in Light Product Storage and Handling Operations

API RECOMMENDED PRACTICE 1640
FIRST EDITION, AUGUST 2013



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

Users of this Recommended Practice should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

Information concerning safety and health risks and proper precautions with respect to particular materials and conditions should be obtained from the employer, the manufacturer or supplier of that material, or the material safety data sheet.

Where applicable, authorities having jurisdiction should be consulted.

Work sites and equipment operations may differ. Users are solely responsible for assessing their specific equipment and premises in determining the appropriateness of applying the Recommended Practice. At all times users should employ sound business, scientific, engineering, and judgment safety when using this Recommended Practice.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees, and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the specification.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the specification.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 1220 L Street, NW, Washington, DC 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

Contents

	Page
1 General	1
1.1 Scope and Purpose	1
1.2 Non-Applicability	1
2 Normative References	2
3 Terms and Definitions	3
4 Health, Safety, Security, Environment	9
4.1 General	9
4.2 Management Responsibility and Accountability	9
4.3 Quality Assurance System	9
4.4 Training	10
4.5 Risk Assessments	11
4.6 Incident Management	12
5 Storage Terminals—Equipment Design	13
5.1 General	13
5.2 Tankage	15
5.3 Product Receipt System Design	17
5.4 Pipework within Storage and Distribution Terminals	17
5.5 Component and Fuel Blending Systems	18
5.6 Road and Rail Transport Loading and Unloading	18
5.7 Filtration	19
6 General Operating, Maintenance, Inspection and Test Requirements	19
6.1 Planned Maintenance, Inspection, and Testing	19
6.2 Filtration Equipment	19
6.3 Tank Movement Indicators (Level Alarms)	20
6.4 Tank Vents	20
6.5 Tank Inspections and Cleaning	20
6.6 Piping Systems	21
7 Strainer and Filtration Equipment Management	21
7.1 Strainers	21
7.2 Filters	22
7.3 Element Change Criteria	23
7.4 Filter Vessel Change Out Procedure	23
8 Sampling and Testing	24
8.1 General	24
8.2 Sampling—Basic Requirements	24
8.3 Testing	26
8.4 Sample Retains	26
9 Fuel Quality Control	27
9.1 General	27
9.2 Product Segregation	27
9.3 Additives	28
9.4 Product and Component Inventory Variations	29

Contents

	Page
9.5 Settling	29
9.6 Post-receipt Tank Testing	30
9.7 Product Release for Custody Transfer	30
9.8 Oversight Testing	31
10 Receipt Procedures	31
10.1 Receipt—General	31
10.2 Receipts from Pipeline	35
10.3 Receipts from Ocean Tanker Coastal and Inland Waterway Vessel	35
10.4 Receipt by Truck or Rail Car	37
10.5 Other Receipts	38
10.6 Interface	38
11 Storage Procedures	38
11.1 Routine Checks	38
11.2 Storage Tank Changes	39
11.3 Storage of Biodiesel	42
11.4 Storage of Ethanol	43
11.5 VRU Procedures	44
11.6 Product Returns	44
11.7 Water Management	45
12 Product Blending	46
12.1 General	46
12.2 Product Blending (in-tank)	46
12.3 Ethanol Blending	47
12.4 Biodiesel Blending	48
12.5 Transmix Blending	50
13 Delivery Procedures	51
13.1 General	51
13.2 Documentation	52
13.3 Product Delivery from Running Tanks	53
13.4 Product Transfer	53
14 Transportation Equipment from Storage Terminals	56
14.1 General	56
14.2 Pipelines	56
14.3 Waterborne Vessels	57
14.4 Road Vehicles and Rail Tank Cars	57
14.5 Grade Change Procedures for Road Tankers and Railcars—Switch Loading	57
14.6 Transport and Delivery of Biodiesel Blends	58
15 Fuel Additives, Dyes, Markers	58
15.1 General	58
15.2 Receipt and Storage	58
15.3 Additive Transloading	60
15.4 Check Valves and Recycle Systems	60
15.5 Inventory Control	60

Contents

	Page
16 Butane Blending	60
16.1 General	60
16.2 Butane Quality Oversight	60
16.3 Quality Oversight of Gasoline Blended with Butane	61
17 Documentation	62
17.1 Records	62
17.2 Records—Construction and Commissioning	62
17.3 Records—Quality Control	63
17.4 Volumetric Additive Reconciliation (VAR)	63
17.5 Records—Maintenance	64

Figures

1 Illustration of Common Spot Sample Positions	6
---	----------

Tables

1 Spot Sample Requirements	7
2 Tap Sampling Requirements	7
3 Material Compatibilities with Biodiesel (B100)	15
4 Minimum Sample Size, Storage Container Type and Retention Time	26
5 Potential Effects of Cross Contamination of Products	29
6 Basic Testing for Management of Change and Oversight Testing	32
7 Typical Handling Properties for Biodiesel Manufactured from Different Feedstocks	49
8 Minimum Cleaning Requirements for Tank Trucks and Tank Cars	54
9 Minimum Cleaning Requirements for Marine Vessels	55
10 Recommended Oversight Testing	56

Product Quality in Light Product Storage and Handling Operations

1 General

1.1 Scope and Purpose

This recommended practice (RP) is intended to provide guidance on the minimum equipment standards and operating procedures for the receipt, storage blending and delivery of non-aviation light products, their blend components, and additives at distribution and intermediate storage terminals, including related operations of pipeline, marine vessel (barge or ship) and road and rail transport.

This publication is intended to provide recommended practices, rather than set rigid guidelines. Users of this publication should be aware that due consideration shall be given to the effect of any unusual or abnormal circumstance on which it is not possible to generalize within the scope of this publication. Specialist advice shall be sought in these cases.

This publication should assist those involved in fuel handling at distribution and intermediate storage facilities. Every effort has been made by API to assure the accuracy and reliability of the data contained in this publication; however, API makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any local or regional laws or regulations with which this publication may conflict.

This RP is intended to provide guidance on the minimum equipment standards and operating procedures for the receipt, storage, blending of light products, including but not limited to gasoline, kerosene, diesel, heating oil and their blend components (i.e. ethanol, biodiesel, and butane) at distribution and storage terminals, as well as light product shipments directly via a pipeline, marine vessel (barge or ship) or road and rail transport.

In addition, this RP provides guidance for the design, construction, operation and maintenance of light products storage and distribution terminals with the specific intent of protecting or ensuring product quality.

This document incorporates by reference a number of other standards and recommended practices. The distinction between mandatory, recommended and optional provisions in the referenced documents is not changed by nature of their reference in this standard.

The values stated in this RP are International Units (SI); US Customary (USC) units are in parentheses.

1.2 Non-Applicability

This document is not intended to cover fuels addressed in other applicable documents (i.e. aviation fuels) covered under API 1595.

This RP does not cover intermediate or residual fuels (i.e. bunker fuels, #4 oils and #6 oils).

The design and construction provisions of this standard are intended for application at new facilities. Application of the design and construction provisions of this standard to facilities, equipment, structures or installations that are already in place, that are in the process of construction or that are installed before the date of this publication should be evaluated when circumstances merit. Such an evaluation should consider the site-specific circumstances and detailed accounting for both the potential and tolerance for risk, existing conditions at the installation and overall benefit for applying the required design and construction provisions.