

# Cathodic Protection of Aboveground Petroleum Storage Tanks

API RECOMMENDED PRACTICE 651  
THIRD EDITION, JANUARY 2007





# Cathodic Protection of Aboveground Petroleum Storage Tanks

**Downstream Segment**

API RECOMMENDED PRACTICE 651  
THIRD EDITION, JANUARY 2007



## SPECIAL NOTES

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

*All rights reserved. No part of this work may be reproduced, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, N.W., Washington, D.C. 20005.*

## FOREWORD

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, N.W., Washington, D.C. 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually and updated quarterly by API, 1220 L Street, N.W., Washington, D.C. 20005.

Suggested revisions are invited and should be submitted to the Standards and Publications Department, API, 1220 L Street, NW, Washington, D.C. 20005, [standards@api.org](mailto:standards@api.org).

Persons planning to construct an aboveground storage facility, replace existing aboveground storage tanks and associated piping systems, or cathodically protect existing aboveground storage tanks and associated piping should refer to applicable local, state, and federal fire, safety, and environmental regulations as well as the most recent edition of the following publications:

- a. API Std 650;
- b. API RP 652;
- c. API Std 653;
- d. API Spec 12B;
- e. API Spec 12D;
- f. API Spec 12F;
- g. API Std 2610;
- h. NACE RP0193;
- i. NACE RP0285;
- j. NFPA 30;
- k. NFPA 70; and,
- l. PEI RP200.

The appropriate government authority having jurisdiction should be consulted for regulations that apply to the area of installation prior to taking any action suggested in this recommended practice.



# CONTENTS

	Page
1 SCOPE.....	1
2 REFERENCES .....	1
2.1 Standards, Codes, Publications, and Specifications .....	1
2.2 Other References .....	2
3 DEFINITIONS.....	2
4 CORROSION OF ABOVEGROUND STEEL STORAGE TANKS .....	5
4.1 Introduction .....	5
4.2 Corrosion Mechanisms .....	6
4.3 Internal Corrosion .....	7
5 DETERMINATION OF NEED FOR CATHODIC PROTECTION .....	8
5.1 Introduction .....	8
5.2 Tank History.....	9
5.3 Tank Pad and Soil Conditions .....	10
5.4 Other Factors Affecting Cathodic Protection .....	13
6 METHODS OF CATHODIC PROTECTION FOR CORROSION CONTROL .....	14
6.1 Introduction .....	14
6.2 Galvanic Systems.....	14
6.3 Impressed Current Systems.....	15
7 DESIGN OF CATHODIC PROTECTION SYSTEMS.....	16
7.1 Introduction .....	16
7.2 Influence of Replacement Bottoms, External Liners (Release Prevention Barriers), and Secondary Containment on Cathodic Protection System Design .....	17
7.3 External Cathodic Protection.....	19
7.4 Internal Cathodic Protection .....	23
8 CRITERIA FOR CATHODIC PROTECTION .....	23
8.1 Introduction .....	23
8.2 Protection Criteria .....	23
8.3 Measurement Techniques .....	24
8.4 Alternative Reference Electrodes .....	24
9 INSTALLATION OF CATHODIC PROTECTION SYSTEMS .....	25
9.1 Introduction .....	25
9.2 Galvanic Anode Systems.....	25
9.3 Impressed Current Systems.....	26
9.4 Corrosion Control Test Stations, Undertank Monitoring Methods, and Bonds .....	29
10 INTERFERENCE CURRENTS .....	30
10.1 Introduction .....	30
10.2 Sources of Interference Currents.....	31
10.3 Detection of Interference Currents .....	31
10.4 Control of Interference Currents .....	31

11	OPERATION AND MAINTENANCE OF CATHODIC PROTECTION SYSTEMS . . . . .	31
11.1	Introduction . . . . .	31
11.2	Safety . . . . .	32
11.3	Cathodic Protection Surveys . . . . .	32
11.4	Cathodic Protection Records . . . . .	33

#### Figures

1	Electrochemical Corrosion Cell . . . . .	5
2	Oxygen Concentration Cell Caused by Rocks or Clay in Tank Pad . . . . .	6
3	Example of Stray Current Corrosion of an Unprotected Tank Bottom . . . . .	7
4	Galvanic Corrosion . . . . .	7
5	Cathodic Protection with Galvanic Anodes . . . . .	15
6	Impressed Current Cathodic Protection . . . . .	15
7	Impervious External Liner Beneath Storage Tank . . . . .	17
8	New Steel Bottom on Top of Old Bottom . . . . .	18
9	Current Requirement Test Setup . . . . .	22
10	Potential Measurement Schematic . . . . .	25
11	Typical Galvanic Anode Installation . . . . .	26
12	Typical Shallow Anode Bed Installation . . . . .	27
13	Commonly Installed Deep Anode Bed . . . . .	28
14	Permanently Installed Reference Electrode and Test Station . . . . .	29
15	Perforated Pipe Installed for Reference Electrode . . . . .	30

#### Tables

1	General Classification of Resistivity . . . . .	10
2	Partial Galvanic Series . . . . .	14
3	Commonly Used Reference Electrodes . . . . .	25

# Cathodic Protection of Aboveground Petroleum Storage Tanks

## 1 Scope

**1.1** The purpose of this recommended practice is to present procedures and practices for achieving effective corrosion control on aboveground storage tank bottoms through the use of cathodic protection. It contains provisions for the application of cathodic protection to existing and new storage tanks. Corrosion control methods based on chemical control of the environment or the use of protective coatings are not covered in detail.

**1.2** When cathodic protection is used for aboveground storage tank applications, it is the intent of this recommended practice to provide information and guidance specific to aboveground steel storage tanks in hydrocarbon service. Certain practices recommended herein may also be applicable to tanks in other services. It is intended to serve only as a guide to persons interested in cathodic protection. Specific cathodic protection designs are not provided. Such designs should be developed by a person thoroughly familiar with cathodic protection practices.

**1.3** This recommended practice does not designate specific practices for every situation because the varied conditions in which tank bottoms are installed preclude standardization of cathodic protection practices.

## 2 References

### 2.1 STANDARDS, CODES, PUBLICATIONS, AND SPECIFICATIONS

Unless otherwise specified, the most recent editions or revisions of the following standards, codes, and specifications shall, to the extent specified herein, form a part of this standard.

#### API

Spec 12B	<i>Bolted Tanks for Storage of Production Liquids</i>
Spec 12D	<i>Field Welded Tanks for Storage of Production Liquids</i>
Spec 12F	<i>Shop Welded Tanks for Storage of Production Liquids</i>
RP 500	<i>Recommended Practice for Classification of Locations for Electrical Installations at Petroleum Facilities</i>
RP 575	<i>Inspection of Atmospheric and Low Pressure Storage Tanks</i>
Std 620	<i>Design and Construction of Large, Welded, Low-pressure Storage Tanks</i>
Std 650	<i>Welded Steel Tanks for Oil Storage</i>
RP 652	<i>Lining of Aboveground Petroleum Storage Tank Bottoms</i>
Std 653	<i>Tank Inspection, Repair, Alteration, and Reconstruction</i>
RP 1615	<i>Installation of Underground Petroleum Product Storage Systems</i>
RP 1621	<i>Bulk Liquid Stock Control at Retail Outlets</i>
RP 1632	<i>Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems</i>
RP 2003	<i>Protection Against Ignitions Arising Out of Static, Lightning, and Stray Currents</i>

#### ASTM<sup>1</sup>

C 144	<i>Standard Specification for Aggregate for Masonry Mortar</i>
C 778	<i>Standard Specification for Standard Sand</i>
D 512	<i>Standard Test Methods for Chloride Ion in Water</i>
D 516	<i>Standard Test Method for Sulfate Ion in Water</i>
D 1557	<i>Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/ft<sup>3</sup> (2,700 kN-m/m<sup>3</sup>))</i>
G 51	<i>Standard Test Method for Measuring pH of Soil for Use in Corrosion Testing</i>
G 57	<i>Method for Field Measurement of Soil Resistivity Using the Wenner Four Electrode Method</i>

#### EPA<sup>2</sup>

0376.1	<i>Test Method for Sulfide—Titrimetric Iodine</i>
--------	---

<sup>1</sup>ASTM International, 100 Bar Harbor Drive, West Conshohocken, Pennsylvania 19428, [www.astm.org](http://www.astm.org).

<sup>2</sup>U.S. Environmental Protection Agency, Ariel Rios Building, 1200 Pennsylvania Avenue, N.W., Washington, D.C. 20460, [www.epa.gov](http://www.epa.gov).