

Valve Selection Guide

API RECOMMENDED PRACTICE 615
SECOND EDITION, AUGUST 2016



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Users of this recommended practice should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API is not undertaking to meet the duties of employers, manufacturers, or suppliers to warn and properly train and equip their employees and others exposed, concerning health and safety risks and precautions, nor undertaking their obligations to comply with authorities having jurisdiction.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Copyright © 2016 American Petroleum Institute

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Shall: As used in a recommended practice, “shall” denotes a minimum requirement in order to conform to the recommended practice.

Should: As used in a recommended practice, “should” denotes a recommendation or that which is advised but not required in order to conform to the recommended practice.

May: As used in a recommended practice, “may” denotes a course of action permissible within the limits of a recommended practice.

Can: As used in a recommended practice, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 1220 L Street, NW, Washington, DC 20005.

Suggested revisions are invited and should be submitted to the Standards Department, API, 1220 L Street, NW, Washington, DC 20005, standards@api.org.

Contents

1	Scope.....	1
2	Terms and Definitions	1
3	Considerations for Valve Selection	3
3.1	Valve Functions.....	3
3.2	Valve Types	4
3.3	Other Considerations	4
4	Primary Valve Types	4
4.1	Valves to Stop Flow or to Provide for Equipment Isolation (Block Valves)	4
4.2	Valves for Preventing Flow Reversal (Check Valves).....	8
4.3	Valves for Throttling (Controlling) Flow—Globe Valves	10
5	Service Considerations	10
5.1	General.....	10
5.2	Chlorine Service.....	10
5.3	Cryogenic (Low-temperature) Service	11
5.4	Hydrofluoric Acid Service.....	11
5.5	Hydrogen Service.....	11
5.6	Oxygen Service	11
5.7	Sour Service (Wet H ₂ S Service).....	11
5.8	Viscous or Solidifying Service	12
6	Valve Material Selection.....	12
6.1	Body Material Selection.....	12
6.2	Valve Trim Selection.....	12
6.3	Seating Surfaces—Soft Seats	13
6.4	Stem Sealing—Fugitive Emissions.....	13
6.5	Valve Bonnet Gaskets	14
7	Valve Specific Features and Options	14
7.1	Valve Operation	14
7.2	Position Indication	14
7.3	Hot Tap Valves.....	14
7.4	Double Block Valves for Positive Isolation	14
7.5	Double Block-and-Bleed (DB&B) Valves (Single Valve)	15
7.6	“Fire Tested” Valves.....	15
7.7	Valve End Connections.....	15
7.8	Cavity Overpressure	15
7.9	Flange Shields.....	15
7.10	Valve Purge Connections	16
8	Steps for Valve Selection and Procurement	16
	Annex A (informative) Schematic Drawings for Typical Valve Types.....	17
	Annex B (informative) Examples of Typical Valve Purchase Descriptions	34
	Bibliography.....	35

Contents

Figures

A.1	Typical API 600 Bolted Bonnet Gate Valve—Outside Screw and Yoke	17
A.2	Typical API 602 Bolted Bonnet Gate Valve.....	18
A.3	Typical API 602 Welded Bonnet Gate Valve	18
A.4	Typical Valve Nomenclature Example from API 603.....	19
A.5	Typical Example of Floating Ball Valve—One Piece Body Design Illustrated.....	20
A.6	Typical Trunnion Mounted Ball Valves—Two Examples of Split Body Designs	21
A.7	Typical Sleeve Lined Plug Valve.....	22
A.8	Typical Nonlubricated Plug Valve.....	22
A.9	Typical Lubricated Plug Valve.....	23
A.10	Typical Category A Butterfly Valve.....	24
A.11a	Typical Category B Butterfly Valve—Double Offset Type.....	24
A.11b	Detail of Double Offset Butterfly Valve—Disc and Seats (Seal)	25
A.12	Detail of Triple Offset Butterfly Valve—Disc and Seats (Seal).....	26
A.13	Typical Single-plate Wafer Check Valve	27
A.14	Typical Dual-plate Wafer Check Valve	28
A.15	Typical Flanged Swing Check Valve	29
A.16	Typical Ball Check Valve—Threaded End.....	29
A.17	Typical Piston Check Valve—Threaded End	30
A.18	Typical Threaded Globe Valve.....	31
A.19	Typical Flanged Globe Valve.....	32
A.20	Example of API 602 Bellows Stem Seal	33

Introduction

API Recommended Practice (RP) 615 was developed to aid in the selection of valves for the hydrocarbon processing industry (HPI), which includes refineries and petrochemical and chemical plants and the various processes associated with them. This RP may assist in the selection of valves for other industrial processes, such as power or general industry process applications. The task force members who developed this document represent many years of experience in the design and selection of valves and are comprised of professionals from manufacturing, engineering contractors, and end users.

The objective of this RP is to disseminate suggested information on valve selection recommendations as an aid to reduce operational problems and maintenance costs.

Although this RP provides guidance on the selection of valves, the valve specifier or end user is required to pay particular attention to, and is ultimately responsible for, all aspects of the application involving process, metallurgical, and mechanical considerations.

Typical purchase descriptions are provided in the Annex to assist in the complete definition of valve details to help ensure that the correct product is specified for the intended application.

Of prime importance, however, is that this RP is a general guideline for valve selection; the final responsibility is that of the user of this document.

Valve Selection Guide

1 Scope

This Recommended Practice (RP) provides general guidance on valve selection for the hydrocarbon processing industry (HPI), which includes refineries and petrochemical, chemical, and liquefied natural gas (LNG) plants and their various associated processes. Selection guidance is provided for valve types covered by ASME B16.34 and API Valve Standards for the Downstream Segment, which include gate, ball, plug, butterfly, check, and globe valves.

Modulating control valves and pressure relief valves are outside the scope of this RP.

2 Terms and Definitions

For the purposes of this document, the following terms and definitions apply.

2.1

abrasive service

Abrasive service is a term used to identify fluids containing particulates that are likely to damage a valve's pressure boundary or internals through erosion. Fluids containing rust, scale, welding slag, sand, catalyst fines, grit, and hydrocarbon particles (coke) may fall in this category.

2.2

bellows seal

A flexible metal bellows used in place of or in addition to valve stem packing to provide a positive seal against leakage to atmosphere.

2.3

chlorine service

Services containing liquid or vapor chlorine in concentrations higher than 1 ppm as defined in 29 *CFR* 1910. This does not include water services containing chlorine for pH balancing or as a biocide.

2.4

clean service

Clean service is a term used to identify fluids free from solids or contaminants that could interfere with proper valve operation and/or closure. Clean fluids include most light hydrocarbons, instrument air, nitrogen, water, steam, lube oil, diesel oil, methanol, etc.

2.5

closure member

This refers to the component in the valve that serves to stop flow (internal disc, ball, and plug, for example). A closure member may also be referred to as the valve obturator.

2.6

cryogenic service

The lower end of low temperature service (such as liquefied gas) typically between $-163\text{ }^{\circ}\text{C}$ to $-196\text{ }^{\circ}\text{C}$ ($-261\text{ }^{\circ}\text{F}$ to $-320\text{ }^{\circ}\text{F}$).

2.7

dirty service

Dirty service is a general term used to identify fluids with suspended solids that may impair the proper performance of a valve. Detrimental effects of suspended solids on valve performance can be mitigated by minimizing or purging dead zones where suspended solids may accumulate. Dirty service can also be an abrasive service.