

Safe Access/Egress Involving Floating Roofs of Storage Tanks in Petroleum Service

API RECOMMENDED PRACTICE 2026
THIRD EDITION, JUNE 2017



AMERICAN PETROLEUM INSTITUTE

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 1220 L Street, NW, Washington, DC 20005.

Copyright © 2017 American Petroleum Institute

Foreword

This recommended practice (RP) is intended to provide information associated with safe access/egress involving floating roofs of tanks in petroleum service. This RP includes a discussion of the common hazards associated with these operations and the appropriate precautions for preventing accidents and injuries.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any federal, state or municipal regulation with which this publication may conflict.

Suggested revisions are invited and should be submitted to the director of the Health and Environmental Affairs Department, American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005.

Contents

	Page
1	Scope and Objectives 1
1.1	Scope 1
1.2	Objectives 1
2	Normative References 1
3	Terms, Definitions, Acronyms, and Abbreviations 2
3.1	Terms and Definitions 2
3.2	Acronyms and Abbreviations 5
4	General Precautions for Descent onto Floating Roofs 6
4.1	General Conditions 6
4.2	Permit Space Program Requirements 6
4.3	Requirements for Descent onto Floating Roofs 7
5	Potential Hazards Associated with Entry onto Floating Roofs 7
5.1	Potential Atmospheric Hazards 7
5.2	Potential Oxygen Content Hazards 7
5.3	Potential Flammable Vapor Hazards 8
5.4	Potential Toxic Vapor and Gas Hazards 8
5.5	Potential Vapor Exposures 9
5.6	Potential Fire Hazards 9
5.7	Potential Physical Hazards 10
6	Preparation for Entry onto Floating Roofs: Ventilation, Testing, and Rescue 11
6.1	Ventilation Requirements 11
6.2	Atmospheric Testing Requirements 12
6.3	Emergency Rescue Planning 14
7	Additional Procedures for Descent onto External Floating Roofs 14
7.1	Additional Procedures 14
7.2	Permissible Work on External Floating Roofs 16
8	Additional Procedures for Descent onto Internal and Covered External Floating Roofs 17
8.1	General 17
8.2	Preparations Prior to Descent onto Internal and Covered External Floating Roofs 18
8.3	Working on Internal and Covered External Floating Roofs of Tanks in Service 18
8.4	Permissible Work on Internal and Covered External Floating Roofs 18

Safe Access/Egress Involving Floating Roofs of Storage Tanks in Petroleum Service

1 Scope and Objectives

1.1 Scope

1.1.1 This recommended practice (RP) addresses the hazards associated with access/egress onto external and internal floating roofs of in-service petroleum storage tanks and identifies some of the most common practices and procedures for safely accomplishing this activity.

1.1.2 This RP is intended primarily for those persons who are required to perform inspection, service, maintenance, or repair activities that involve descent onto floating roofs of in-service petroleum tanks.

1.1.3 This RP does not cover general considerations that apply to climbing onto petroleum storage tanks and other structures, including, but not limited to:

- a) slippery or ice-covered stairways and walkways,
- b) access during electrical storms, and
- c) access during emergency conditions (such as to extinguish a fire or cover exposed product with foam).

This RP may not apply to daily or routine tasks of tank gaugers and other personnel involved in non-permit-required confined spaces; however, such persons shall be trained and shall be made aware of the potential hazards described herein.

1.1.4 Preparations and precautions for entering petroleum storage tanks that have been removed from service for cleaning are covered in API 2015.

1.1.5 Some owner/operators have policies that are more stringent than those in this document. Some owner/operators do not permit access onto floating roofs while the tanks are in service. In these cases, owner/operator policies will supersede this document with respect to safe access requirements and limitations.

1.2 Objectives

This RP has the following objectives:

- a) to identify the potentially hazardous conditions associated with access/egress onto external and internal floating roofs of storage tanks while the tanks are in petroleum service; and
- b) to establish general precautionary measures appropriate to individual situations.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Standard 650, *Welded Tanks for Oil Storage*

API Standard 2015, *Requirements for Safe Entry and Cleaning of Petroleum Storage Tanks*

API Recommended Practice 2027, *Ignition Hazards Involved in Abrasive Blasting of Atmospheric Storage Tanks in Hydrocarbon Service*