

Manual of Petroleum Measurement Standards Chapter 7.1

Temperature Determination— Liquid-in-Glass Thermometers

THIRD EDITION, OCTOBER 2024



Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue NW, Suite 1100, Washington, DC 20001.

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard. Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue NW, Suite 1100, Washington, DC 20001, standards@api.org.

Contents

	Page
1	Scope..... 1
2	Normative References 1
3	Terms and Definitions..... 2
4	General Precautions 3
4.1	Safety..... 3
5	Units of Measure 4
6	Equipment and Design Requirements 4
6.1	Liquid-in-Glass Thermometers 4
6.2	Liquid-in-Glass Thermometer Assemblies 7
6.3	Thermowells 8
7	Procedures for Temperature Determination..... 10
7.1	Static Temperature Determination Using Liquid-in-Glass Thermometers..... 10
7.2	Dynamic Temperature Determination Using Liquid-in-Glass Thermometers..... 19
8	Inspection, Verification, and Calibration Requirements 20
8.1	Inspection..... 20
8.2	Verification..... 20
8.3	Calibration..... 22
Annex A (informative) Mercury-in-Glass Thermometer Alternative Testing Phase I— Tank Measurement..... 24	
Annex B (normative) Emergent-stem Correction for Liquid-in-Glass Thermometers 26	
Annex C (normative) Test Procedure for Determining Immersion Times of Liquid-in-Glass Tank Thermometers and Their Assemblies..... 35	
Annex D (informative) Local Direct-reading Thermometers..... 37	

Figures

1	Types of Glass Thermometers..... 5
2	Typical Cup-case Assembly..... 8
3	Typical Armored-cased Assembly 9
4	Typical Angle-stem Thermometer 9
B.1	Thermometers Immersed in Bath 27
B.2	Total-immersion Thermometer Partially Immersed in a Thermowell..... 28
B.3	Clip to Suspend Ambient Temperature Thermometer 29
B.4	Measuring Temperature of the Emergent Liquid Column..... 30
B.5	Measuring Between Immersion Ring and Start of Temperature Scale (34 mm)..... 31
B.6	Determining How Many Degrees on the Thermometer 32

Tables

1	Allowable Tolerances: Operating Thermometer vs Temperature Standard 6
2	Tank Thermometers 6
3	Dynamic Temperature Thermometers 7
4	Minimum Number of Temperature Measurements for Various Depths of Hydrocarbon Liquid in Storage, Lease, Ship, and Barge Tanks..... 11
5	Comparison of Recommended Immersion Times for Woodback Cup-case Assemblies..... 13
6	Thermometer Assemblies and Temperature Levels for Tanks and Cargo Carriers..... 17
7	Temperature Measurements for Horizontal Cylindrical Tanks..... 18
C.1	Suggested Bath Temperatures 35
C.2	Time Intervals for Reading Thermometers 36
D.1	Tank Appurtenances for Temperature Measurement..... 37

Introduction

This section describes how to correctly use various types of liquid-in-glass thermometers to accurately determine the temperatures of hydrocarbon liquids. Other methods, equipment, and procedures for temperature determination are described in the other subsections of *API Manual of Petroleum Measurement Standards (MPMS) Chapter 7*.

Temperature Determination—Liquid-in-Glass Thermometers

1 Scope

This section describes how to correctly use various types of liquid-in-glass thermometers to accurately determine the temperatures of hydrocarbon liquids. Other methods, equipment, and procedures for temperature determination are described in the other subsections of API *MPMS* Chapter 7.

This chapter describes the methods, equipment, and procedures for manually determining the temperature of liquid petroleum and petroleum products with liquid-in-glass thermometers. This chapter discusses temperature measurement requirements in general for custody transfer, inventory control, and marine measurements. The actual method and equipment selected for temperature determination are left to the agreement of the parties involved.

The manual method covers:

- non-pressurized tanks and non-pressurized marine vessels;
- gas-blanketed tanks and gas-blanketed marine vessels.

It does not cover hydrocarbons under pressures in excess of 21 kPa gauge (3 psi gauge) or cryogenic temperature measurement, unless equipped with a thermowell.

The requirements of this chapter are based on practices for crude oils and petroleum products covered by API *MPMS* Ch. 11.1 (ASTM D1250). Requirements in this chapter may be used for other fluids and other applications. However, other applications may require different performance and installation specifications.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API Manual of Petroleum Measurement Standards (MPMS) Chapter 1, Terms and Definitions
(<https://chapter1.api.org>)

API Manual of Petroleum Measurement Standards (MPMS) Chapter 2 (all sections), Tank Calibration

API Manual of Petroleum Measurement Standards (MPMS) Chapter 3 (all sections), Tank Gauging

API Manual of Petroleum Measurement Standards (MPMS) Chapter 8.1, Standard Practice for Manual Sampling of Petroleum and Petroleum Products

API Manual of Petroleum Measurement Standards (MPMS) Chapter 9.4, Continuous Density Measurement Under Dynamic (Flowing) Conditions

API Manual of Petroleum Measurement Standards (MPMS) Chapter 11.1, Temperature and Pressure Volume Correction Factors for Generalized Crude Oils, Refined Products, and Lubricating Oils

API Manual of Petroleum Measurement Standards (MPMS) Chapter 12.1.1, Calculation of Static Petroleum Quantities—Upright Cylindrical Tanks and Marine Vessels

API Manual of Petroleum Measurement Standards (MPMS) Chapter 12.2, Calculation of Petroleum Quantities Using Dynamic Methods and Volumetric Correction Factors