

# Inspection of Pressure-relieving Devices

API RECOMMENDED PRACTICE 576  
FIFTH EDITION, SEPTEMBER 2024



## Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

Users of this Recommended Practice should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

## Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, [standards@api.org](mailto:standards@api.org).



# Contents

	Page
1	Scope ..... 1
2	Normative References ..... 1
3	Terms, Definitions, Acronyms, and Abbreviations ..... 2
3.1	Terms and Definitions ..... 2
3.2	Acronyms and Abbreviations ..... 6
4	Pressure-relieving Devices (PRDs) ..... 6
4.1	General ..... 6
4.2	Pressure-relief Valve (PRV) ..... 6
4.3	Direct-acting PRV ..... 7
4.4	Pilot-operated PRVs ..... 10
4.5	Rupture Disk Devices ..... 13
4.6	Pin-actuated Devices ..... 22
5	Causes of Improper Performance ..... 24
5.1	Corrosion ..... 24
5.2	Damaged Seating Surfaces ..... 28
5.3	Failed Springs ..... 30
5.4	Improper Setting and Adjustment ..... 32
5.5	Plugging and Fouling ..... 33
5.6	Galling ..... 35
5.7	Misapplication of Materials ..... 35
5.8	Improper Location, History, or Identification ..... 36
5.9	Improper Handling ..... 36
5.10	Improper Differential Between Operating and Set Pressures ..... 39
5.11	Improper Inlet/Outlet Piping Test Procedures ..... 39
6	Inspection and Testing ..... 39
6.1	Responsibilities ..... 39
6.2	Operating History ..... 40
6.3	Reasons for Inspection and Testing ..... 41
6.4	Inspection Methods ..... 41
6.5	Inspection, Testing, Maintenance, and Setting of Direct Spring-operated Safety Valves When Used on Fired Pressure Vessels ..... 56
6.6	Inspection, Testing, Maintenance, and Setting of Pilot-operated PRVs ..... 56
6.7	Inspection, Testing, Maintenance, and Setting of Weight-loaded Pressure and/or Vacuum Vents on Tanks ..... 57
6.8	Inspection and Replacement of Rupture Disk Devices ..... 58
6.9	Inspection Frequency ..... 62
7	Records and Reports ..... 65
7.1	General ..... 65
7.2	The Need to Keep Records ..... 66
7.3	Sample Record and Report System ..... 66
	Annex A (informative) Pressure-relief Valve Testing ..... 67
	Annex B (informative) Sample Record and Report Forms ..... 70
	Bibliography ..... 76
<b>Figures</b>	
1	Pressure/Vacuum-relief Valve ..... 7
2	Weight-loaded Emergency Vent ..... 8
3	Open Bonnet, Direct-acting Spring-loaded Pressure-relief Valve ..... 8
4	Closed Bonnet, Direct-acting Spring-loaded Relief Valve ..... 9
5	Balanced Bellows Direct-acting Spring-loaded Pressure-relief Valve ..... 10
6	Unbalanced Piston Main Valve, Pilot-operated Pressure-relief Valve ..... 11

7	Diaphragm Main Valve, Pilot-operated Pressure-relief Valve .....	12
8	Diaphragm Main Valve, Pilot-operated Pressure- and Vacuum-relief Valve .....	13
9	Forward-acting Conventional Rupture Disk.....	14
10	Forward-acting Scored Rupture Disk .....	15
11	Reverse-acting Knife Blade Rupture Disk.....	16
12	Reverse-acting Scored Rupture Disk.....	17
13	Graphite Rupture Disk.....	18
14	Rupture Disk in Union Holder .....	19
15	Rupture Disk in Screw-type Holder.....	19
16	Rupture Disk with Insert-type Holder.....	19
17	Insert-type Holder Installation .....	20
18	Conventional Domed Rupture Disk (Disk Is in an Insert-type Holder).....	20
19	Piston-type Pin-actuated Device .....	23
20	Butterfly-type Pin-actuated Device .....	24
21	Acid Corrosion in Carbon Steel Bonnet Caused by Leaking Seating Surfaces.....	25
22	Chloride Corrosion on 18Cr-8Ni Steel Nozzle (with Machined Seating Surface) .....	25
23	Sulfide Corrosion on Carbon Steel Disc from Crude Oil Distillation Unit.....	26
24	Chloride Attack on 18Cr-8Ni Steel Disc .....	26
25	Pit-type Corrosion on 18Cr-8Ni Steel Bellows .....	27
26	Alloy 400 Rupture Disks Corroded in Sour Gas Service .....	27
27	Body and Bonnet Coated with Epoxy for Corrosion Protection.....	28
28	Seating Surface of Disc Deformed by Chattering.....	29
29	Seating Surface of Disc Damaged by Frequent Operation of Valve due to Excessive Cycling.....	30
30	Spring Failure Due to Corrosion .....	31
31	Spring Failure Due to Stress Corrosion .....	31
32	Inlet Nozzle Plugged with Coke and Catalyst After Nine Months in Reactor Vapor Line.....	33
33	Outlet Valve Plugged with Deposits from Other Valves in Common Discharge Header.....	34
34	Moving Parts of Valve Fouled with Iron Sulfide (FeS <sub>2</sub> ).....	34
35	Disc Frozen in Guide Because of Buildup of Products of Corrosion in Sour Oil Vapor Service.....	35
36	Improper Storage of Valves .....	36
37	Example of Improper Storage of Valves .....	37
38	Identification Tag for Pressure-relieving Device .....	43
39	Identification Tag for Pressure-relieving Device (Pre-2013).....	43
40	Identification Tag for Pressure-relieving Device (Mandatory January 1, 2013) .....	44
41	Block Valves on Pressure-relief Valve Inlet and Outlet Sealed Open .....	48
42	Sulfur Deposits in Body of Valve .....	50
43	Safety Valve and Relief Valve Leak Detector .....	55
44	Operating Ratio Exceeded, Then Subjected to Vacuum.....	58
45	Operating Ratio Exceeded—Tabs Are Stretched .....	59
46	Disk Subjected to Corrosion.....	59
47	Rupture Disk Holder Subjected to Excessive Corrosion.....	60
48	Rupture Disk Holder Subjected to Corrosion .....	60
49	Rupture Disk Holder Corrosion Due to Leakage .....	61
50	Dent Caused by Water Freezing in Discharge Line.....	61
51	Rupture Disk Holder Subjected to Over-torque.....	62
A.1	Typical Safety Valve and Relief Valve Test Block Using Air As a Test .....	69
B.1	Sample Form for Recording Pressure-relieving Device Specifications.....	71
B.2	Sample Historical Record .....	72
B.3	Sample Inspection and Repair Work Order Form.....	73
B.4	Sample Testing Report.....	74
B.5	Sample In-service Report.....	75



# Inspection of Pressure-relieving Devices

## 1 Scope

This recommended practice (RP) describes the inspection and repair practices for self-actuated pressure-relieving devices (PRDs) commonly used in the oil/gas and petrochemical industries. As a guide to the inspection and repair of these devices in the owner-operator's plant, it is intended to ensure their proper performance. This publication covers self-actuated devices such as direct-acting spring-loaded valves, pilot-operated pressure-relief valves (PRVs), rupture disks, pin-actuated devices, and weight-loaded pressure vacuum vents.

The recommendations in this publication are not intended to supersede requirements established by regulatory bodies. This publication excludes tank weak seams and/or sections or tank thief hatches, explosion doors, fusible plugs, control valves, pressure-regulating devices, integral rotating equipment components, other devices that either depend on an external source of power for operation or are manually operated, or devices not designed to be inspected or recertified. Inspections and tests made at manufacturers' plants, which are usually covered by codes or purchase specifications, are not covered by this publication.

This publication does not cover training requirements for personnel involved in the inspection and repair of PRDs. Those seeking these requirements should see API 510 and API 570, which give the requirements for a quality control system and specify that the repair organization maintain and document a training program ensuring that personnel are qualified.

## 2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

API 510, *Pressure Vessel Inspection Code: In-service Inspection, Rating, Repair, and Alteration*

API Standard 520 (all parts), *Sizing, Selection, and Installation of Pressure-relieving Devices*

API Standard 521, *Pressure-relieving and Depressuring Systems*

API Standard 526, *Flanged Steel Pressure-relief Valves*

API Standard 527, *Seat Tightness of Pressure Relief Valves*

API 570, *Piping Inspection Code: In-service Inspection, Rating, Repair, and Alteration of Piping Systems*

API Recommended Practice 580, *Elements of a Risk-Based Inspection*

API Standard 2000, *Venting Atmospheric and Low-pressure Storage Tanks*

ASME Boiler and Pressure Vessel Code (BPVC) <sup>1</sup>, *Section I, Rules for Construction of Power Boilers*

ASME Boiler and Pressure Vessel Code (BPVC), *Section VIII: Rules for Construction of Pressure Vessels; Division 1*

ASME Boiler and Pressure Vessel Code (BPVC), *Section XIII, Rules for Overpressure Protection*

ASME PTC 25, *Pressure Relief Devices—Performance Test Codes*

---

<sup>1</sup> ASME International, Two Park Avenue, New York, NY 10016-5990, [www.asme.org](http://www.asme.org).