

Australian Standard™

**Boilers—Unattended and limited  
attendance**

This Australian Standard was prepared by Committee ME-001, Pressure Equipment. It was approved on behalf of the Council of Standards Australia on 13 April 2001 and published on 13 July 2001.

---

The following interests are represented on Committee ME-001:

A.C.T. WorkCover  
Australasian Corrosion Association  
Australasian Institute of Engineer Surveyors  
Australian Aluminium Council  
Australian Building Codes Board  
Australian Chamber of Commerce and Industry  
Australian Industry Group  
Australian Institute of Energy  
Australian Institute of Petroleum  
Australian Liquefied Petroleum Gas Association  
Boilers and Pressure Vessel Manufacturers Association of Australia  
Bureau of Steel Manufacturers of Australia  
Department for Administrative and Information Services, S.A.  
Department of Employment, Training and Industrial Relations, Qld  
Department of Infrastructure, Energy and Resources, Tas.  
Department of Labour, New Zealand  
Electricity Engineers Association, New Zealand  
Electricity Supply Association of Australia  
Institute of Materials Engineering Australasia  
Institution of Engineers, Australia  
Institution of Professional Engineers, New Zealand  
National Association of Testing Authorities, Australia  
New Zealand Engineering Federation  
New Zealand Heavy Engineering Research Association  
New Zealand Institute of Welding  
New Zealand Petrochemical Users Group  
Victorian WorkCover Authority  
Welding Technology Institute of Australia  
WorkCover N.S.W.  
WorkSafe W.A.

---

### **Keeping Standards up-to-date**

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Australia web site at [www.standards.com.au](http://www.standards.com.au) and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Australian Standard*, has a full listing of revisions and amendments published each month.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at [mail@standards.com.au](mailto:mail@standards.com.au), or write to the Chief Executive, Standards Australia International Ltd, GPO Box 5420, Sydney, NSW 2001.

---

Australian Standard™

## **Boilers—Unattended and limited attendance**

Originated as AS 2593—1983.  
Previous edition AS 2593—1995.  
Fourth edition 2001.  
Reissued incorporating Amendment No. 1 (October 2001).

### **COPYRIGHT**

© Standards Australia International

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia International Ltd  
GPO Box 5420, Sydney, NSW 2001, Australia

ISBN 0 7337 3878 8

## PREFACE

This Standard was prepared by Standards Australia/Standards New Zealand Committee ME-001, Pressure Equipment to supersede AS 2593—1995.

*This Standard incorporates Amendment No. 1 (October 2001). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.*

This Standard is the result of a consensus among representatives on the Joint Committee to produce it as an Australian Standard.

This edition proposes, in addition to the existing requirements for boilers operating for periods without human supervision, further requirements for attended boilers.

This edition introduces requirements for accredited boiler attendants, as boiler attendants will no longer be certificated by the regulatory authorities.

Users of this Standard are reminded that it has no legal authority in its own right but may acquire legal standing in one or more of the following circumstances:

- (a) Adoption by a government authority.
- (b) Adoption by a purchaser as a required standard of construction when placing a contract.
- (c) Adoption where a manufacturer states that a vessel is in accordance with this Standard.

Statements expressed in mandatory terms in footnotes to tables are deemed to be requirements of this Standard.

The terms 'normative' and 'informative' have been used in this Standard to define the application of the appendix to which they apply. A 'normative' appendix is an integral part of a Standard, whereas an 'informative' appendix is only for information and guidance.

## CONTENTS

	<i>Page</i>
<b>SECTION 1 SCOPE AND GENERAL</b>	
1.1 SCOPE.....	5
1.2 REFERENCED DOCUMENTS.....	6
1.3 DEFINITIONS.....	6
1.4 NEW DESIGNS, MATERIALS AND CONSTRUCTION METHODS .....	7
<b>SECTION 2 DESIGN AND CONSTRUCTION</b>	
2.1 GENERAL REQUIREMENTS.....	9
2.2 STEAM BOILERS (OTHER THAN ELECTRIC BOILERS).....	9
2.3 HOT WATER BOILERS.....	10
2.4 WASTE HEAT BOILERS .....	10
2.5 ELECTRIC BOILERS .....	11
2.6 SUPERHEATERS .....	11
<b>SECTION 3 BOILER MANAGEMENT SYSTEM</b>	
3.1 GENERAL.....	12
3.2 FAIL-SAFE TECHNIQUES.....	12
3.3 TEMPERATURE SUITABILITY OF COMPONENTS .....	12
3.4 COMBUSTION MANAGEMENT .....	12
3.5 WATER MANAGEMENT SYSTEM.....	13
3.6 ELECTRICAL POWER ISOLATION .....	17
3.7 POWER FAILURE PROTECTION.....	18
3.8 CONTROL EQUIPMENT .....	18
3.9 ALARMS.....	18
3.10 VISUAL DISPLAY (FOR BOILERS EXCEEDING A POWER OUTPUT OF 500 kW).....	18
3.11 COMBUSTION EQUIPMENT FOR FUEL-FIRED BOILERS .....	19
3.12 MULTIPLE-BURNER INSTALLATIONS .....	22
3.13 AIR SUPPLY AND CONTROL SYSTEM.....	22
3.14 IGNITION SYSTEM.....	22
3.15 MAIN FUEL FIRING RATE.....	23
<b>SECTION 4 ADDITIONAL REQUIREMENTS FOR OIL-FIRED, GAS-FIRED AND SOLID-FUEL-IN-SUSPENSION-FIRED BOILERS</b>	
4.1 APPLICATION .....	25
4.2 OPERATIONAL REQUIREMENTS FOR OIL, GAS AND SOLID-FUEL- IN-SUSPENSION MANAGEMENT SYSTEMS .....	25
4.3 SPECIFIC REQUIREMENTS FOR OIL-FIRED BOILERS.....	29
4.4 SPECIFIC REQUIREMENTS FOR GAS-FIRED BOILERS .....	29
4.5 SPECIFIC REQUIREMENTS FOR SOLID-FUEL-IN-SUSPENSION-FIRED BOILERS.....	30
<b>SECTION 5 ADDITIONAL REQUIREMENTS FOR SOLID-FUEL-FIRED (BED OR GRATE) BOILERS</b>	
5.1 APPLICATION .....	31
5.2 OPERATIONAL REQUIREMENTS FOR SOLID FUEL (BED OR GRATE) MANAGEMENT SYSTEMS .....	31
5.3 SPECIFIC REQUIREMENTS FOR SOLID-FUEL-FIRED (BED OR GRATE) BOILERS.....	32

SECTION 6 INSTALLATION	
6.1	STATUTORY REQUIREMENTS..... 34
6.2	HOUSING, ACCESS AND SECURITY ..... 34
6.3	FEEDWATER SUPPLY..... 34
6.4	WATER TREATMENT ..... 34
6.5	BLOWDOWN..... 34
6.6	FLUES AND CHIMNEYS ..... 34
SECTION 7 MARKING AND INSTRUCTIONS	
7.1	MARKING ..... 35
7.2	ELECTRICAL DATA ..... 35
7.3	INSTRUCTIONS..... 35
7.4	LANGUAGE AND UNITS ..... 35
7.5	CERTIFICATES..... 35
SECTION 8 CHECKING, TESTING AND MAINTENANCE	
8.1	GENERAL..... 36
8.2	ORGANIZATION AND PERSONNEL ..... 36
8.3	RESPONSIBILITIES CHECKING, TESTING AND MAINTENANCE..... 36
8.4	CHECKING AND TESTING ..... 36
8.5	MAINTENANCE ..... 38
8.6	RETENTION OF RECORDS ..... 39
8.7	MAINTENANCE CONTRACT ..... 39
APPENDICES	
A	LIST OF REFERENCED DOCUMENTS ..... 40
B	ACCEPTABLE CRITERIA FOR ORGANIZATIONS AND PERSONNEL UNDERTAKING BOILER CONTROL DESIGN, TESTING AND SERVICING .... 41
C	TYPE TEST FOR A BOILER SUBJECT TO POWER FAILURE ..... 44
D	TYPICAL OIL OR GAS BURNER FIRING SEQUENCE..... 45
E	TYPICAL OIL SUPPLY AND CONTROL SYSTEMS ..... 46

## STANDARDS AUSTRALIA

**Australian Standard****Boilers—Unattended and limited attendance**

## SECTION 1 SCOPE AND GENERAL

**1.1 SCOPE**

This Standard specifies requirements for unattended and limited attendance boilers which are intended to be operated for periods without human supervision. It includes special features within the control, management and supervision systems, associated valves and fittings, housing and installation, as well as requirements and responsibilities for checking, testing and maintenance of these boilers.

The limits on the type, design criteria, and usage of unattended and limited attendance boilers to which this Standard is intended to apply are as follows:

- (a) Boilers for fixed land installations.
- (b) Boilers having a design pressure as shown in Table 1.1.
- (c) Boilers having a power output within the capacity specified in Table 1.1 for the boiler type and category. (See Note 1.)
- (d) Boilers complying with the supervision and maintenance requirements specified in Table 1.1 for the boiler type and category.
- (e) Boilers for the generation of steam, or other vapour, for which duty the types of boilers permitted are—
  - (i) water-tube type, electric type or small boiler types (see Table 1.1) for unattended operation; and
  - (ii) any type of boiler for limited attendance operation (see Table 1.1).
- (f) Boilers for the heating of water or other liquids at a pressure above that of the atmosphere and to a temperature not less than the normal atmospheric boiling temperature of the liquid, for which duty any type of boiler complying with AS 1228 is permitted for unattended operation, provided that for other than water-tube and electric type boilers, steam or vapour is not generated in the boiler and the boiler drum or shell is fully flooded.
- (g) Boilers having any of the following sources of energy input:
  - (i) Gas fuel (mains or other gases).
  - (ii) Oil fuel with a closed flashpoint greater than 23°C.
  - (iii) Solid fuels, including solid-fuel-in-suspension.
  - (iv) Waste heat fluids.
  - (v) Electric power.
  - (vi) Solar energy.

## NOTES:

- 1 This Standard may also be applied to boilers outside the limits specified in Items (a) to (g) in Clause 1.1 where equivalent safety and reliability are ensured.
- 2 Except for definitions in Clause 1.3, other clauses in the Standard refer to steam and water only. The Standard may be applied to other fluids.