

An ACI Standard

Requirements for Reinforced Concrete Chimneys— Code and Commentary

Reported by ACI Committee 307

ACI CODE-307-23



American Concrete Institute
Always advancing



Requirements for Reinforced Concrete Chimneys—Code and Commentary

Copyright by the American Concrete Institute, Farmington Hills, MI. All rights reserved. This material may not be reproduced or copied, in whole or part, in any printed, mechanical, electronic, film, or other distribution and storage media, without the written consent of ACI.

The technical committees responsible for ACI committee reports and standards strive to avoid ambiguities, omissions, and errors in these documents. Despite these efforts, the users of ACI documents occasionally find information or requirements that may be subject to more than one interpretation or may be incomplete or incorrect. Users who have suggestions for the improvement of ACI documents are requested to contact ACI via the errata website at <http://concrete.org/Publications/DocumentErrata.aspx>. Proper use of this document includes periodically checking for errata for the most up-to-date revisions.

ACI committee documents are intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. Individuals who use this publication in any way assume all risk and accept total responsibility for the application and use of this information.

All information in this publication is provided “as is” without warranty of any kind, either express or implied, including but not limited to, the implied warranties of merchantability, fitness for a particular purpose or non-infringement.

ACI and its members disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, including without limitation, lost revenues or lost profits, which may result from the use of this publication.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations regarding health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

Participation by governmental representatives in the work of the American Concrete Institute and in the development of Institute standards does not constitute governmental endorsement of ACI or the standards that it develops.

ACI documents are written via a consensus-based process. The characteristics of ACI technical committee operations include:

- (a) Open committee membership
- (b) Balance/lack of dominance
- (c) Coordination and harmonization of information
- (d) Transparency of committee activities to public
- (e) Consideration of views and objections
- (f) Resolution through consensus process

The technical committee documents of the American Concrete Institute represent the consensus of the committee and ACI. Technical committee members are individuals who volunteer their services to ACI and specific technical committees.

American Concrete Institute
38800 Country Club Drive
Farmington Hills, MI 48331
Phone: +1.248.848.3700
Fax: +1.248.848.3701

Requirements for Reinforced Concrete Chimneys— Code and Commentary

An ACI Standard

Reported by ACI Committee 307

Denis J. Radecki, Chair

David J. Bird
Victor A. Bochicchio
Shu-Jin Fang
Jon K. Galsworthy
David C. Mattes

Joseph F. Peters
Kelly D. Scott
John C. Sowizal
F. Alan Wiley
John L. Wilson

Consulting Members

John J. Carty

Barry J. Vickery

Note: Special acknowledgments to R. Porthouse (deceased) and S. Richart (deceased) for their contributions to this Code.

This Code provides material, design, and detailing requirements for cast-in-place and precast reinforced concrete chimneys. It sets forth minimum loadings for design and contains methods for determining the concrete and reinforcement required to obtain the strength required by the loadings. The methods of analysis apply primarily to circular chimney walls, but guidance is included for applying the general principles to noncircular chimney walls.

Keywords: across-wind load; construction requirements; earthquake load; flexural strength; load combinations; reinforced concrete; reinforced concrete chimneys; structural design; thermal load; vortex shedding; windload.

CONTENTS

PREFACE, p. 3

CHAPTER 1—GENERAL, p. 4

1.1—Scope, p. 4

1.2—General, p. 4

1.3—Purpose, p. 4

1.4—Applicability, p. 5

1.5—Interpretation, p. 5

1.6—Building official, p. 6

1.7—Licensed design professional, p. 6

1.8—Construction documents and design records, p. 7

1.9—Testing and inspection, p. 7

CHAPTER 2—NOTATION AND DEFINITIONS, p. 8

2.1—Notation, p. 8

2.2—Definitions, p. 13

CHAPTER 3—REFERENCED STANDARDS, p. 14

**CHAPTER 4—STRUCTURAL SYSTEM
REQUIREMENTS, p. 15**

4.1—Materials, p. 15

ACI CODE-307-23 supersedes ACI 307-08 and was approved by the ACI Standards Board for publication January 2023, and published September 2023. This Code was first published in 1954 under Committee 505 and revised in 1969, 1988, 1995, 1998, and 2008.

Copyright © 2023, American Concrete Institute.

All rights reserved including rights of reproduction and use in any form or by any means, including the making of copies by any photo process, or by electronic or mechanical device, printed, written, or oral, or recording for sound or visual reproduction or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the copyright proprietors.

- 4.2—Design loads, p. 15
- 4.3—Structural system, p. 15

CHAPTER 5—CONCRETE: MATERIALS, DESIGN, AND DURABILITY REQUIREMENTS, p. 16

- 5.1—General, p. 16
- 5.2—Materials, p. 16
- 5.3—Concrete properties for design, p. 17
- 5.4—Durability requirements, p. 18

CHAPTER 6—REINFORCING STEEL: MATERIALS, DESIGN, AND DURABILITY REQUIREMENTS, p. 19

- 6.1—General, p. 19
- 6.2—Materials, p. 19
- 6.3—Steel properties for design, p. 19
- 6.4—Durability requirements, p. 19

CHAPTER 7—LOADS, p. 20

- 7.1—General, p. 20
- 7.2—Dead load, p. 20
- 7.3—Temperature gradient load, p. 20
- 7.4—Wind load, p. 23
- 7.5—Earthquake load, p. 29
- 7.6—Load combinations, p. 33

CHAPTER 8—DESIGN OF HORIZONTAL CROSS SECTIONS, p. 35

- 8.1—General, p. 35
- 8.2—Design limits, p. 36
- 8.3—Required strength, p. 38
- 8.4—Design strength, p. 38
- 8.5—Reinforcement limits, p. 39
- 8.6—Reinforcement detailing, p. 40

CHAPTER 9—DESIGN OF VERTICAL CROSS SECTIONS FOR CIRCUMFERENTIAL RING MOMENTS, p. 42

- 9.1—General, p. 42
- 9.2—Design limits, p. 42
- 9.3—Required strength, p. 42
- 9.4—Design strength, p. 42
- 9.5—Reinforcement limits, p. 43
- 9.6—Reinforcement detailing, p. 43

CHAPTER 10—OPENING DETAILS, p. 45

- 10.1—General, p. 45
- 10.2—Minimum wall thickness at openings, p. 45
- 10.3—Vertical reinforcement at openings, p. 45
- 10.4—Circumferential reinforcement at openings, p. 46
- 10.5—Corner reinforcement at openings, p. 47
- 10.6—Seismic detailing, p. 48

CHAPTER 11—FOUNDATION, p. 49

- 11.1—Foundation geotechnical capacity, p. 49
- 11.2—Foundation structural design, p. 49
- 11.3—Reinforcement detailing, p. 50
- 11.4—Mass concrete, p. 50

CHAPTER 12—CONSTRUCTION REQUIREMENTS, p. 51

- 12.1—General, p. 51
- 12.2—Concrete strength, p. 51
- 12.3—Concrete strength tests, p. 51
- 12.4—Formwork, p. 51
- 12.5—Concrete placement, p. 52
- 12.6—Concrete curing, p. 52
- 12.7—Reinforcement placement, p. 52
- 12.8—Construction tolerances, p. 53
- 12.9—Precast erection, p. 53

COMMENTARY REFERENCES, p. 54

APPENDIX A—HORIZONTAL CROSS-SECTION STRENGTH FOR CIRCULAR CHIMNEYS BY MODIFIED STRESS BLOCK METHOD, p. 56

- A.1—Notation, p. 56
- A.2—Procedure for computing combined nominal axial and flexural strength, p. 56
- A.3—Stress block modification factor, p. 58
- A.4—Derivation of equations, p. 58

APPENDIX B—HORIZONTAL CROSS-SECTION STRENGTH FOR CIRCULAR CHIMNEYS BY STRESS-STRAIN RELATIONSHIP INTEGRATION METHOD, p. 62

- B.1—Notation, p. 62
- B.2—Procedure for computing combined nominal axial and flexural strength, p. 62
- B.3—Derivation of equations, p. 63

APPENDIX C—TEMPERATURE GRADIENTS FOR CIRCULAR CHIMNEYS, p. 67

- C.1—General, p. 67
- C.2—Notation, p. 67
- C.3—Unlined chimney, p. 67
- C.4—Chimney with lining material applied directly to the inside concrete surface, p. 67
- C.5—Chimney with insulation completely filling the space between the liner and the chimney wall (no annular airspace), p. 68
- C.6—Chimney with unventilated air space between liner and chimney wall, p. 68
- C.7—Chimney with ventilated air space between liner and chimney wall, p. 69

APPENDIX D—THERMAL STRESSES FOR CIRCULAR CHIMNEYS, p. 70

- D.1—General, p. 70
- D.2—Notation, p. 70
- D.3—Vertical thermal stresses, p. 70
- D.4—Horizontal thermal stresses, p. 70

APPENDIX E—CRACKING MOMENT, p. 72

- E.1—Notation, p. 72
- E.2—Cracking moment calculation, p. 72

APPENDIX F—REVISION HISTORY, p. 73

PREFACE

ACI CODE-307 is based on ACI 318-19 and ASCE/SEI 7-16. Updated requirements in ACI 318 and ASCE/SEI 7, as well as recent studies and research, have resulted in the following revisions of this Code:

- (a) The Code has been reorganized to follow the current ACI 318 format as much as possible.
- (b) Wind loads are based on a strength-level wind speed.
- (c) The damping ratio at the strength-level wind speed for the across-wind load has been decreased from 4% to 2.5%.

(d) Seismic loading and detailing are consistent with ASCE/SEI 7.

(e) Foundation requirements are expanded and revised. Refer to Appendix F for a more comprehensive list of changes.

This Code was developed by an ANSI-approved consensus process. This Code can supplement a current (ICC) building code, supplement the codes governing new and existing structures of a local jurisdiction authority, or act as a stand-alone code in a locality that has not adopted an existing building code.



CODE

CHAPTER 1—GENERAL

1.1—Scope

1.1.1 ACI 307 includes provisions for the structural design of nonprestressed cast-in-place and nonprestressed precast reinforced concrete chimneys.

1.2—General

1.2.1 ACI 307, “Requirements for Reinforced Concrete Chimneys—Code and Commentary,” is hereafter referred to as “this Code.”

1.2.2 In this Code, the general building code refers to the building code adopted in a jurisdiction. When adopted, this Code forms part of the general building code.

1.2.3 This Code provides minimum requirements for the materials, design, construction, and strength evaluation of cast-in-place or nonprestressed precast reinforced concrete chimneys designed and constructed under the requirements of the general building code.

1.2.4 Modifications to this Code that are adopted by a particular jurisdiction are part of the laws of that jurisdiction but are not a part of this Code.

1.2.5 If no general building code is adopted, this Code provides minimum requirements for the materials, design, construction, and strength evaluation of any reinforced concrete chimney within the scope of this Code.

1.3—Purpose

1.3.1 The purpose of this Code is to provide for public health and safety by establishing minimum requirements for strength, stability, serviceability, and durability of reinforced concrete chimneys.

1.3.2 This Code does not address all design considerations.

COMMENTARY

CHAPTER R1—GENERAL

R1.1—Scope

R1.1.1 The provisions apply to circular and noncircular reinforced concrete chimneys.

A precast reinforced concrete chimney is defined as a chimney constructed from precast reinforced concrete sections (360-degree sections only, which may include openings), assembled one on top of another, to form a self-supporting cantilevered structure. Vertical reinforcement and grout are placed in cores as the precast sections are erected to provide structural continuity and stability during construction and for the completed structure. The design of precast concrete chimneys incorporating post-tensioning of the segments is beyond the scope of this Code.

R1.2—General

R1.2.5 This Code applies to reinforced concrete chimneys having circular or noncircular cross sections.

This Code provides minimum requirements and exceeding these minimum requirements is not a violation of this Code. The licensed design professional is permitted to specify project requirements that exceed the minimum requirements of this Code.

R1.3—Purpose

R1.3.1 This Code provides a means of establishing minimum requirements for the design and construction of reinforced concrete chimneys as well as for acceptance of the design and construction of reinforced concrete chimneys by the building officials or their designated representatives.

R1.3.2 The minimum requirements in this Code do not replace professional judgment or the licensed design professional’s knowledge of the specific factors surrounding a project, including its design, the project site, and other specific or unusual circumstances related to the project.