



# IEEE Recommended Practice for Sizing Lead-Acid Batteries for Stand-Alone Photovoltaic (PV) Systems

---

## IEEE Standards Coordinating Committee 21

Sponsored by the  
IEEE Standards Coordinating Committee 21 on  
Fuel Cells, Photovoltaics, Dispersed Generation, and Energy Storage

1013<sup>TM</sup>

---

IEEE  
3 Park Avenue  
New York, NY 10016-5997, USA  
20 July 2007

**IEEE Std 1013<sup>TM</sup>-2007**  
(Revision of  
IEEE Std 1013-2000)



# **IEEE Recommended Practice for Sizing Lead-Acid Batteries for Stand-Alone Photovoltaic (PV) Systems**

Sponsored by the

**IEEE Standards Coordinating Committee 21 on  
Fuel Cells, Photovoltaics, Dispersed Generation, and Energy Storage**

Approved 22 March 2007

**IEEE-SA Standards Board**

**Abstract:** A method for determining the energy-capacity requirements (sizing) of both vented and valve-regulated lead-acid batteries used in terrestrial stand-alone photovoltaic (PV) systems is described. Sizing batteries for hybrid or grid-connected PV systems is beyond the scope of this recommended practice. Installation, maintenance, safety, testing procedures, and consideration of battery types other than lead-acid are beyond the scope of this recommended practice. Recommended practices for the remainder of the electrical systems associated with PV installations are also beyond the scope of this recommended practice.

**Keywords:** battery capacity, battery requirements, lead-acid batteries, photovoltaic (PV), photovoltaic power systems, sizing, sizing lead-acid batteries, solar, stand-alone

---

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2007 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 20 July 2007. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

Print: ISBN 0-7381-5593-4                      SH95682  
PDF: ISBN 0-7381-5594-2                      SS95682

*No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

**IEEE Standards** documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied “**AS IS.**”

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
Piscataway, NJ 08854  
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

## Introduction

This introduction is not part of IEEE Std 1013-2007, IEEE Recommended Practice for Sizing Lead-Acid Batteries for Stand-Alone Photovoltaic (PV) Systems.

This recommended practice describes a method for sizing both vented and valve-regulated lead-acid batteries used in stand-alone terrestrial photovoltaic (PV) systems. Sizing batteries for hybrid or grid-connected PV systems is beyond the scope of this recommended practice. Installation, maintenance, safety, testing procedures, and consideration of battery types other than lead-acid are beyond the scope of this recommended practice. Recommended practices for the remainder of the electrical systems associated with PV installations are also beyond the scope of this recommended practice.

## Notice to users

### Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

### Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

### Patents

Attention is called to the possibility that implementation of this recommended practice may require use of subject matter covered by patent rights. By publication of this recommended practice, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents or patent applications for which a license may be required to implement an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

## Participants

At the time this recommended practice was completed, the Energy Storage Subsystems Working Group had the following membership:

**Jay L. Chamberlin**, *Chair*  
**Kenneth S. Sanders**, *Secretary*

Howard Barikmo  
Rob Cary  
Garth P. Corey  
James Dunlop  
Lauren Giles

Robert Hammond  
Thomas D. Hund  
Liang Ji  
Peter F. McNutt  
Haissam Nasrat

Michael T. Nispel  
Carl Parker  
Robert F. Rallo  
Stephen Vechy  
John Wiles

The following members of the individual balloting committee voted on this recommended practice. Balloters may have voted for approval, disapproval, or abstention.

William J. Ackerman  
Munnu Bajpai  
Thomas S. Basso  
Richard T. Bolgeo  
Steven R. Brockschink  
William A. Byrd  
Thomas Carpenter  
Jay L. Chamberlin  
Weijen Chen  
Keith Chow  
Stephen P. Conrad  
Tommy P. Cooper  
Garth P. Corey  
C. G. Currin  
Stephen Dare  
Randall L. Dotson  
Gary R. Engmann

Randall C. Groves  
David A. Horvath  
Thomas D. Hund  
Jim Kulchisky  
Saumen K. Kundu  
William G. Lowe  
G. L. Luri  
Keith N. Malmedal  
James A. McDowall  
Mark F. McGranaghan  
Peter F. McNutt  
Gary L. Michel  
Haissam Nasrat  
Michael S. Newman  
Michael T. Nispel  
Chris L. Osterloh

Donald M. Parker  
Percy E. Pool  
Robert F. Rallo  
Charles W. Rogers  
Joseph R. Rostron  
Randall M. Safier  
Kenneth S. Sanders  
Steven Sano  
Bartien Sayogo  
Stephen C. Schwarm  
Tarkeshwar Singh  
Herbert J. Sinnock  
David R. Smith  
S. Thamilarasan  
Joe D. Watson  
James W. Wilson, Jr.  
Oren Yuen

At the time this recommended practice was approved, the IEEE Standards Coordinating Committee 21 on Fuel Cells, Photovoltaics, Dispersed Generation, and Energy Storage had the following membership:

**Richard DeBlasio**, *Chair*  
**Stephen Chalmers**, *Vice-Chair*  
**Thomas S. Basso**, *Secretary*  
**Bill Ash**, *IEEE SCC21 Liaison*

David L. Bassett  
John J. Bzura  
Jay L. Chamberlin  
James M. Daley

Douglas C. Dawson  
Frank Goodman  
Kelvin Hecht  
Joseph Koepfinger

Benjamin Kroposki  
Robert Saint  
Mallur N. Satyanarayan  
Timothy P. Zgonena

When the IEEE-SA Standards Board approved this recommended practice on 22 March 2007, it had the following membership:

**Steve M. Mills**, *Chair*  
**Robert M. Grow**, *Vice-Chair*  
**Donald F. Wright**, *Past Chair*  
**Judith Gorman**, *Secretary*

Richard DeBlasio  
Alexander D. Gelman  
William R. Goldbach  
Arnold M. Greenspan  
Joanna N. Guenin  
Julian Forster\*  
Kenneth S. Hanus  
William B. Hopf

Richard H. Hulett  
Hermann Koch  
Joseph L. Koepfinger\*  
John D. Kulick  
David J. Law  
Glenn Parsons  
Ronald C. Petersen  
Tom A. Prevost

Narayanan Ramachandran  
Greg Ratta  
Robby Robson  
Anne-Marie Sahazizian  
Virginia Sulzberger  
Malcolm V. Thaden  
Richard L. Townsend  
Howard L. Wolfman

\*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish K. Aggarwal, *NRC Representative*  
Alan H. Cookson, *NIST Representative*

Jennie Steinhagen  
*IEEE Standards Program Manager, Document Development*

Bill Ash  
*IEEE Standards Program Manager, Technical Program Development*

## Contents

1. Overview .....	1
1.1 Scope .....	1
1.2 Purpose .....	1
2. Definitions, acronyms, and abbreviations .....	2
2.1 Definitions .....	2
2.2 Acronyms and abbreviations .....	2
3. Outline of sizing methodology .....	3
4. Autonomy considerations .....	3
5. Load determination .....	4
5.1 General considerations .....	4
5.2 Load data .....	5
5.3 Data analysis .....	6
6. Battery capacity and functional-hour rate determination .....	6
6.1 Unadjusted capacity .....	6
6.2 Battery type selection .....	6
6.3 Capacity adjustment .....	7
6.4 Functional-hour rate .....	8
7. Determining number of series-connected cells .....	8
7.1 Nominal system voltage .....	8
7.2 Voltage window .....	8
7.3 Calculating the number of series-connected cells .....	9
8. Battery size determination .....	10
8.1 Cell size selection .....	11
8.2 Number of parallel strings .....	11
8.3 Final number of cells .....	11
8.4 Final battery capacity .....	11
8.5 Checks and considerations .....	11
9. Battery sizing worksheets .....	12
Annex A (informative) Battery characteristics .....	23
A.1 Capacity .....	23
A.2 Type .....	23

A.3 Cyclability .....	23
A.4 Cycle life.....	24
A.5 Economic considerations .....	25
A.6 Physical characteristics.....	25
A.7 Maintenance.....	26
A.8 Handling Precautions.....	26
Annex B (informative) Examples.....	27
Annex C (informative) Bibliography.....	44

# IEEE Recommended Practice for Sizing Lead-Acid Batteries for Stand-Alone Photovoltaic (PV) Systems

## 1. Overview

This recommended practice provides a systematic approach for determining the appropriate energy capacity of a lead-acid battery to satisfy the energy requirements of the electrical loads of a stand-alone photovoltaic (PV) system. Since this capacity determination (sizing) assumes that no power is available from the array, the resulting battery capacity should be more than adequate to meet the PV system's load requirements during its normal operation.

### 1.1 Scope

This recommended practice describes a method for sizing both vented and valve-regulated lead-acid batteries in stand-alone PV systems. Installation, maintenance, safety, testing procedures, and consideration of battery types other than lead-acid are beyond the scope of this recommended practice. Sizing batteries for hybrid and grid-connected PV systems is beyond the scope of this recommended practice. Recommended practices for the remainder of the electrical systems associated with stand-alone PV installations are also beyond the scope of this recommended practice.

Sizing examples are given for various representative system applications. Iterative techniques to optimize battery costs, which include consideration of the interrelationship between battery size, PV array size, and weather, are beyond the scope of this recommended practice.

### 1.2 Purpose

This recommended practice is meant to assist system designers in sizing lead-acid batteries for residential, commercial, and industrial stand-alone PV systems.